

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:	Douglas
Month/Year:	November, 25

System Name: Sutherlin, City of ID#: 41 00847 WTP : TP-B, Cooper Creek WTP

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	0.074	0.075	OFF	OFF	0.075
18	OFF	OFF	0.064	0.039	OFF	OFF	0.073
19	OFF	OFF	0.069	0.069	OFF	OFF	0.083
20	OFF	OFF	0.060	0.059	OFF	OFF	0.067
21	OFF	OFF	0.065	0.059	OFF	OFF	0.072
22	OFF	OFF	0.052	0.040	OFF	OFF	0.052
23	OFF	OFF	0.077	0.078	OFF	OFF	0.078
24	OFF	OFF	0.041	0.036	OFF	OFF	0.064
25	OFF	OFF	0.037	0.043	OFF	OFF	0.053
26	OFF	OFF	0.043	0.045	OFF	OFF	0.058
27	OFF	OFF	0.043	0.038	OFF	OFF	0.047
28	OFF	OFF	0.036	OFF	OFF	OFF	0.049
29	OFF	OFF	0.034	0.033	OFF	OFF	0.041
30	OFF	OFF	0.035	0.032	OFF	OFF	0.041

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:

NAME: Alan Taylor
SIGNATURE: Alan Taylor
DATE: 12-3-25
PHONE #: (541) 459-5768
CERT #: 08797

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: B - Cooper Creek

System Name: Sutherlin, City of

ID#: 41 00847

Month/Year: Nov, 2025

Disinfection
Giardia Log
Inactiv:

0.500

Day	Time	Residual at 1st User	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
17	13:30	1.3	70.00	91	14	7.00	19	Yes	1300
18	12:30	1.7	70.00	119	14	7.07	25	Yes	1300
19	11:20	1.4	70.00	98	13	6.90	19	Yes	1300
20	12:30	1.6	70.00	112	13	7.10	24	Yes	1300
21	12:00	1.4	70.00	98	13	7.18	23	Yes	1300
22	12:00	1.8	70.00	126	13	6.95	20	Yes	1300
23	13:30	1.8	70.00	126	13	6.92	20	Yes	1300
24	12:45	1.4	70.00	98	13	7.00	19	Yes	1300
25	1:05	1.5	70.00	105	13	6.97	20	Yes	1300
26	12:15	1.5	70.00	105	13	6.92	20	Yes	1300
27	13:05	1.5	70.00	105	13	6.97	20	Yes	1300
28	10:11	1.5	70.00	105	13	6.89	20	Yes	1300
29	12:45	1.6	70.00	112	13	7.04	24	Yes	1300
30	13:30	1.6	70.00	112	12	7.07	24	Yes	1300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013