


System Name:		Swisshome Village		ID#: 4100854	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	50.00	48.00	2.00		NP	
2	50.00	48.00	2.00		NP	
3	50.00	48.00	2.00		NP	
4	50.00	48.00	2.00		0.14	
5	50.00	48.00	2.00		0.09	
6	50.00	48.00	2.00		0.08	
7	50.00	46.00	4.00		0.14	
8	50.00	46.00	4.00		0.20	
9	50.00	46.00	4.00		0.18	
10	50.00	46.00	4.00		0.22	
11	50.00	46.00	4.00		0.24	
12	50.00	50.00	0.00		NP	
13	50.00	50.00	0.00		NP	
14	50.00	50.00	0.00		NP	
15	50.00	50.00	0.00		NP	
16	50.00	50.00	0.00		NP	
17	50.00	50.00	0.00		NP	
18	50.00	50.00	0.00		NP	
19	50.00	50.00	0.00		NP	
20	50.00	46.00	4.00		0.18	
21	50.00	46.00	4.00		0.19	
22	50.00	44.00	6.00		0.25	
23	50.00	44.00	6.00		0.20	
24	50.00	44.00	6.00		0.13	
25	50.00	44.00	6.00		0.17	
26	50.00	44.00	6.00		0.18	
27	50.00	44.00	6.00		0.23	
28	50.00	44.00	6.00		0.18	
29						
30						
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
Notes: PSI = pounds per square inch		PRINTED NAME: Matt Grassauer	
PSID = pounds per square inch difference (before filter - after filter)		SIGNATURE: 	DATE: 3/9/2021
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PHONE #: (541) 972.1859	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	Swisshome Village	ID#: 41 00854	Month/Year:	Feb-21	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	-------------------	---------------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1320	1.2	232	278.4	7.5	7.20	49.9	YES	
2/915	1.2	232	278.4	7.1	7.20	51.3	YES	
3/1240	1.2	232	278.4	6.9	7.20	52.0	YES	
4/1617	1.2	232	278.4	9.3	7.20	44.3	YES	
5/1315	1.1	232	255.2	9.2	7.20	44.1	YES	
6/1725	1	232	232.0	9.0	7.20	44.2	YES	
7/1715	0.5	232	116.0	8.8	7.20	42.3	YES	
8/1734	0.3	232	69.6	8.6	7.20	41.9	YES	
9/1800	0.4	232	92.8	8.9	7.20	41.6	YES	
10/1311	0.4	232	92.8	9.1	7.20	41.0	YES	
11/1025	0.6	232	139.2	8.5	7.20	43.6	YES	
12/1700	0.6	232	139.2	8.0	7.20	45.1	YES	
13/1645	0.5	232	116.0	8.4	7.20	43.4	YES	
14/1552	0.5	232	116.0	8.1	7.20	44.3	YES	
15/1645	0.5	232	116.0	7.9	7.20	44.9	YES	
16/1500	0.4	232	92.8	8.4	7.20	43.0	YES	
17/1430	0.5	232	116.0	8.0	7.20	44.6	YES	
18/1041	0.7	232	162.4	8.3	7.20	44.7	YES	
19/1100	0.7	232	162.4	8.4	7.20	44.4	YES	
20/1040	0.7	232	162.4	8.6	7.20	43.9	YES	
21/1435	0.6	232	139.2	8.2	7.20	44.5	YES	
22/1710	0.6	232	139.2	8.8	7.20	42.8	YES	
23/1215	0.6	232	139.2	9.0	7.20	42.2	YES	
24/1942	0.5	232	116.0	8.7	7.20	42.6	YES	
25/950	0.7	232	162.4	8.5	7.20	44.1	YES	
26/1405	0.7	232	162.4	9.0	7.20	42.7	YES	
27/1833	0.8	232	185.6	8.8	7.20	43.8	YES	
28/1720	0.6	232	139.2	9.2	7.20	41.7	YES	
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwn_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350