

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Wasco

Conventional or Direct Filtration

Month/Year: Dec-25

System Name:	City of The Dalles		ID#: 41-00869				WTP :	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.08	0.08	0.06	0.06	0.06	0.06	0.08	
2	0.08	0.06	0.06	0.09	0.06	0.06	0.09	
3	0.07	0.06	0.08	0.08	0.07	0.07	0.08	
4	0.06	0.08	0.05	0.05	0.06	0.06	0.08	
5	0.08	0.07	0.06	0.06	0.06	0.06	0.08	
6	0.06	0.08	0.07	0.06	0.06	0.06	0.08	
7	0.07	0.06	0.06	0.07	0.05	0.06	0.07	
8	0.08	0.07	0.06	0.05	0.06	0.06	0.08	
9	0.06	0.07	0.08	0.07	0.06	0.07	0.08	
10	0.06	0.06	0.08	0.06	0.07	0.07	0.08	
11	0.09	0.07	0.07	0.08	0.08	0.05	0.09	
12	0.07	0.07	0.07	0.07	0.07	0.07	0.07	
13	0.08	0.08	0.07	0.06	0.07	0.07	0.08	
14	0.07	0.08	0.08	0.07	0.06	0.07	0.08	
15	0.06	0.08	0.06	0.06	0.05	0.05	0.08	
16	0.06	0.06	0.06	0.06	0.06	0.06	0.06	
17	0.06	0.06	0.07	0.08	0.07	0.07	0.08	
18	0.06	0.07	0.06	0.07	0.06	OFFLINE	0.07	
19	OFFLINE	OFFLINE	OFFLINE	OFFLINE	OFFLINE	OFFLINE	0.00	
20	OFFLINE	0.08	0.08	0.07	0.07	0.06	0.08	
21	0.07	0.07	0.08	0.07	0.07	0.07	0.08	
22	0.09	0.08	0.07	0.08	0.09	0.09	0.09	
23	0.07	0.07	0.08	0.08	0.09	0.08	0.09	
24	0.06	0.07	0.07	0.06	0.07	0.07	0.07	
25	0.07	0.07	0.07	0.08	0.08	0.08	0.08	
26	0.07	0.07	0.08	0.07	0.08	0.07	0.08	
27	0.08	0.08	0.07	0.08	0.07	0.07	0.08	
28	0.08	0.08	0.08	0.07	0.08	0.08	0.08	
29	0.07	0.07	0.07	0.08	0.07	0.07	0.08	
30	0.07	0.06	0.08	0.08	0.06	0.07	0.08	
31	0.07	0.07	0.07	0.07	0.06	0.07	0.07	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes/ No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes/ No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes/ No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes/ No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes/ No		

Notes: Plant taken offline on the evening of Dec 18th to morning of Dec 20th due to source water turbidity exceeding 200 NTU. Also, a large boulder rolled down the hill and struck the side of treatment basin. Basin was drained for inspection and no structural damage was found.

PRINTED NAME: Tyler Mitchell
 SIGNATURE: *[Signature]* DATE: 1-9-2026
 PHONE #: (541) 298-2248 x5010 CERT #: T-09274

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form


System Name: City of The Dalles						ID#: 41	-00869	Month/Year: Dec-25	WTP : A
								Disinfection Giardia Log Inactive:	1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 0900	1.15	1170	1345.5	4.6	7.47	66.6	YES	2360
2 / 0900	1.16	1170	1357.2	4.2	7.55	70.5	YES	2360
3 / 0900	1.18	1244	1467.9	4.9	7.56	67.6	YES	2220
4 / 0900	1.19	1170	1392.3	4.7	7.46	66.2	YES	2360
5 / 0900	1.21	1170	1415.7	6.0	7.60	63.9	YES	2360
6 / 0900	1.13	1170	1322.1	8.1	7.58	54.5	YES	2360
7 / 0900	1.03	1170	1205.1	7.6	7.47	53.6	YES	2360
8 / 0900	1.09	1170	1275.3	8.7	7.69	54.2	YES	2360
9 / 0900	1.12	1170	1310.4	9.5	7.68	51.4	YES	2360
10 / 0900	1.05	1170	1228.5	9.1	7.54	49.8	YES	2360
11 / 0900	1.01	1170	1181.7	11.2	7.47	42.1	YES	2360
12 / 0900	1.00	1170	1170.0	9.3	7.41	46.6	YES	2360
13 / 0900	1.03	1328	1367.8	7.4	7.71	59.2	YES	2080
14 / 0900	1.00	1328	1328.0	7.9	7.58	54.4	YES	2080
15 / 0900	1.02	1328	1354.6	8.8	7.73	54.2	YES	2080
16 / 0900	1.03	1328	1367.8	9.4	7.53	48.5	YES	2080
17 / 0900	1.03	1328	1367.8	9.0	7.50	49.3	YES	2080
18 / 0900	1.01	1328	1341.3	7.0	7.57	57.7	YES	2080
19 / 0900	0.86	1328	1142.1	6.0	7.52	59.6	YES	2080
20 / 0900	0.87	2488	2164.6	6.0	7.39	56.9	YES	1110
21 / 0900	0.78	2488	1940.6	5.4	7.49	60.8	YES	1110
22 / 0900	0.88	1526	1342.9	6.8	7.42	54.6	YES	1810
23 / 0900	0.95	1328	1261.6	5.9	7.31	56.2	YES	2080
24 / 0900	1.00	1244	1244.0	6.3	7.31	55.0	YES	2220
25 / 0900	1.02	1244	1268.9	5.8	7.47	60.4	YES	2220
26 / 0900	1.09	1424	1552.2	5.8	7.53	62.3	YES	1940
27 / 0900	1.10	1424	1566.4	7.0	7.46	56.0	YES	1940
28 / 0900	1.15	1424	1637.6	5.6	7.63	65.9	YES	1940
29 / 0900	1.06	1424	1509.4	4.3	7.32	63.7	YES	1940
30 / 0900	1.14	1424	1623.4	3.1	7.44	72.9	YES	1940
31 / 0900	1.14	1424	1623.4	2.5	7.51	77.9	YES	1940

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PRINTED NAME: Tylar Mitchell	DATE: 1-9-2026
SIGNATURE: 	CERT #: T-09274
PHONE #: (541) 296-2248 x5010	