


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Wasco

Conventional or Direct Filtration

Month/Year: Mar-21

System Name:	City of The Dalles		ID#: 41-00869	WTP : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.06	0.05	0.05	0.05	0.05	0.05	0.06
2	0.05	0.05	0.05	0.06	0.05	0.05	0.06
3	0.05	0.05	0.05	0.06	0.05	0.05	0.06
4	0.05	0.05	0.06	0.05	0.05	0.06	0.06
5	0.06	0.05	0.05	0.05	0.05	0.05	0.06
6	0.05	0.05	0.05	0.05	0.05	0.05	0.05
7	0.05	0.05	0.05	0.05	0.05	0.05	0.05
8	0.05	0.06	0.05	0.06	0.05	0.05	0.06
9	0.05	0.05	0.05	0.05	0.06	0.05	0.06
10	0.05	0.05	0.05	0.06	0.06	0.05	0.06
11	0.05	0.05	0.05	0.06	0.06	0.05	0.06
12	0.05	0.05	0.06	0.06	0.07	0.05	0.07
13	0.05	0.05	0.06	0.06	0.05	0.05	0.06
14	0.05	0.06	0.06	0.05	0.05	0.05	0.06
15	0.06	0.05	0.05	0.05	0.05	0.06	0.06
16	0.05	0.05	0.06	0.05	0.05	0.05	0.06
17	0.06	0.05	0.05	0.05	0.05	0.06	0.06
18	0.05	0.05	0.05	0.06	0.06	0.05	0.06
19	0.05	0.05	0.05	0.05	0.05	0.06	0.06
20	0.06	0.06	0.05	0.05	0.06	0.05	0.06
21	0.05	0.06	0.06	0.05	0.05	0.05	0.06
22	0.05	0.05	0.06	0.05	0.05	0.06	0.06
23	0.05	0.05	0.06	0.06	0.05	0.06	0.06
24	0.05	0.05	0.06	0.05	0.05	0.05	0.06
25	0.06	0.06	0.05	0.05	0.05	0.06	0.06
26	0.05	0.05	0.06	0.05	0.08	0.06	0.08
27	0.05	0.05	0.05	0.05	0.07	0.08	0.08
28	0.06	0.05	0.05	0.05	0.05	0.06	0.06
29	0.06	0.05	0.05	0.05	0.05	0.05	0.06
30	0.05	0.05	0.05	0.06	0.06	0.06	0.06
31	0.05	0.06	0.05	0.05	0.05	0.05	0.06

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: Larry McCollum	
	SIGNATURE: 	DATE: April 2, 2021
	PHONE #: (541) 298-2248 x5000	CERT #: T-08756

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A


System Name:	City of The Dalles	ID#: 41	-00869	Month/Year:	Mar-21	Disinfection Giardia Log Inactive:	1
--------------	--------------------	---------	--------	-------------	--------	--	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 0900	0.99	1654	1637.5	4.8	7.47	64.5	YES	1670
2 / 0900	0.92	1654	1521.7	5.0	7.44	62.4	YES	1670
3 / 0900	0.95	1424	1352.8	4.7	7.45	64.1	YES	1940
4 / 0900	1.16	1424	1651.8	5.0	7.42	63.7	YES	1940
5 / 0900	1.07	1424	1523.7	4.9	7.61	68.0	YES	1940
6 / 0900	1.05	1424	1495.2	5.6	7.47	61.5	YES	1940
7 / 0900	1.08	1424	1537.9	5.2	7.34	60.5	YES	1940
8 / 0900	1.07	1424	1523.7	3.9	7.55	71.2	YES	1940
9 / 0900	1.06	1424	1509.4	4.4	7.44	66.1	YES	1940
10 / 0900	1.09	1424	1552.2	4.6	7.35	63.3	YES	1940
11 / 0900	1.12	1244	1393.3	5.3	7.41	61.9	YES	2220
12 / 0900	1.13	1244	1405.7	5.4	7.44	62.2	YES	2220
13 / 0900	1.15	1244	1430.6	4.3	7.40	66.2	YES	2220
14 / 0900	1.22	1244	1517.7	4.9	7.49	66.2	YES	2220
15 / 0900	1.18	1424	1680.3	4.9	7.31	61.8	YES	1940
16 / 0900	1.28	1424	1822.7	4.5	7.43	67.1	YES	1940
17 / 0900	1.19	1244	1480.4	4.6	7.37	64.5	YES	2220
18 / 0900	1.3	1244	1617.2	5.7	7.31	59.3	YES	2220
19 / 0900	1.33	1244	1654.5	6.0	7.42	60.7	YES	2220
20 / 0900	1.3	1244	1617.2	5.5	7.31	60.1	YES	2220
21 / 0900	1.25	1424	1780.0	5.8	7.25	57.3	YES	1940
22 / 0900	1.28	1424	1822.7	5.0	7.12	57.9	YES	1940
23 / 0900	1.24	1424	1765.8	6.3	7.15	53.4	YES	1940
24 / 0900	1.26	1244	1567.4	6.5	7.62	62.6	YES	2220
25 / 0900	1.31	1244	1629.6	6.4	7.58	62.4	YES	2220
26 / 0900	1.34	994	1332.0	6.2	7.73	67.1	YES	2780
27 / 0900	1.22	1105	1348.1	5.8	7.59	64.6	YES	2500
28 / 0900	1.19	1105	1315.0	6.4	7.58	61.6	YES	2500
29 / 0900	1.19	1244	1480.4	5.6	7.46	62.2	YES	2220
30 / 0900	1.32	1046	1380.7	4.8	7.60	70.2	YES	2640
31 / 0900	1.21	1046	1265.7	5.5	7.51	64.0	YES	2640

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PRINTED NAME: Larry McCollum	DATE: 06 APR 21
SIGNATURE: 	CERT #: T-08756
PHONE #: (541) 298-2248 x5000	