

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: Wasco
 Month/Year: Oct-23


Conventional or Direct Filtration

System Name: City of The Dalles ID#: 41-00869 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.04	0.04	0.05	0.06	0.05	0.04	0.06
2	0.05	0.06	OFFLINE	0.05	0.06	0.06	0.06
3	0.05	0.05	0.06	0.06	0.04	0.05	0.06
4	0.04	0.05	0.05	0.06	0.05	0.05	0.06
5	0.05	0.05	0.05	0.06	0.05	0.05	0.06
6	0.05	0.06	0.05	0.05	0.07	0.04	0.07
7	0.06	0.07	0.06	0.05	0.05	0.05	0.07
8	0.05	0.05	0.06	0.05	0.05	0.07	0.07
9	0.06	0.05	0.05	0.05	0.06	0.05	0.06
10	0.05	0.05	0.08	0.05	0.05	0.05	0.08
11	0.02	0.02	0.04	OFFLINE	0.03	0.03	0.04
12	0.05	0.05	0.05	0.05	0.05	0.06	0.06
13	0.05	0.04	0.05	0.05	0.05	0.05	0.05; Note: corrected 8am value LJM
14	0.06	0.06	0.05	0.05	0.05	0.06	0.06
15	0.05	0.05	0.06	0.06	0.06	0.06	0.06
16	0.05	0.05	0.05	0.05	0.04	0.05	0.05
17	0.05	0.05	0.05	0.05	0.04	0.04	0.05
18	0.06	0.05	0.05	0.05	0.05	0.04	0.06
19	0.06	0.05	0.05	0.05	0.05	0.05	0.06
20	0.06	0.06	0.06	0.06	0.06	0.04	0.06
21	0.06	0.06	0.07	0.07	0.04	0.06	0.07
22	0.06	0.05	0.07	0.04	0.06	0.07	0.07
23	0.05	0.06	0.06	0.06	0.05	0.05	0.06
24	0.06	0.06	0.05	0.06	0.05	0.06	0.06
25	0.05	0.05	0.05	0.06	0.06	0.04	0.06
26	0.05	0.04	0.05	0.05	0.06	0.06	0.06
27	0.07	0.08	0.05	0.05	0.05	0.05	0.08
28	0.06	0.06	0.05	0.05	0.06	0.06	0.06
29	0.06	0.05	0.05	0.06	0.06	0.06	0.06
30	0.05	0.06	0.05	0.05	0.06	0.06	0.06
31	0.06	0.05	0.05	0.06	0.04	0.06	0.06

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		

Notes: Resubmitted on 22 Nov 23 to correct entry error of 13 Oct 8am turb value. 

PRINTED NAME: Larry McCollum	DATE: Nov 22, 2023
SIGNATURE: 	CERT #: T-08756
PHONE #: (541) 298-2248 x5000	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))