

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Feb-21


System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.013	0.013	0.01
2	0.014	OFF	0.014	0.014	0.013	0.013	0.01
3	0.014	OFF	OFF	OFF	OFF	OFF	0.01
4	OFF	0.014	0.014	0.014	0.014	0.014	0.01
5	0.014	OFF	OFF	OFF	OFF	OFF	0.01
6	OFF	0.014	OFF	0.014	OFF	OFF	0.01
7	OFF	0.014	OFF	OFF	OFF	0.014	0.01
8	0.014	0.014	0.014	0.014	0.014	OFF	0.01
9	OFF	OFF	OFF	OFF	OFF	0.014	0.01
10	0.014	0.013	OFF	OFF	OFF	OFF	0.01
11	OFF	OFF	0.014	0.014	0.014	0.014	0.01
12	0.014	OFF	OFF	0.014	0.014	OFF	0.01
13	OFF	0.014	0.014	OFF	0.027	OFF	0.03
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	0.014	0.014	0.014	0.01
16	0.014	0.014	0.014	0.014	0.014	0.014	0.01
17	0.014	0.014	0.014	0.014	OFF	OFF	0.01
18	0.016	0.014	OFF	0.014	0.015	OFF	0.02
19	OFF	OFF	0.014	0.014	0.015	OFF	0.02
20	OFF	OFF	OFF	0.014	OFF	OFF	0.01
21	0.016	0.015	0.014	0.014	0.016	OFF	0.02
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	0.015	OFF	0.014	0.02
24	0.013	0.013	OFF	OFF	OFF	OFF	0.01
25	0.013	0.014	0.014	0.013	OFF	OFF	0.01
26	OFF	OFF	OFF	OFF	0.013	0.013	0.01
27	OFF	OFF	OFF	OFF	OFF	0.014	0.01
28	0.013	OFF	OFF	OFF	OFF	0.014	0.01

Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
		<input checked="" type="radio"/> Yes <input type="radio"/> No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

PHONE #: (503) 842- 6462

CERT #: T08918

3/3/2021

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Feb-21

Disinfection *Giardia*
Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.010	170	171.7	8.2	7.30	24.2	YES	100
2	1.000	170	170.0	8.4	7.36	24.3	YES	100
3	0.940	170	159.8	8.2	7.25	23.5	YES	100
4	0.820	170	139.4	8.0	7.06	22.0	YES	100
5	0.820	170	139.4	8.4	6.98	20.8	YES	100
6	0.830	170	141.1	8.3	7.19	22.6	YES	100
7	0.850	170	144.5	8.4	7.25	23.0	YES	100
8	0.800	170	136.0	8.5	7.41	24.0	YES	100
9	0.760	170	129.2	8.2	7.56	25.8	YES	100
10	0.720	170	122.4	9.0	7.30	22.2	YES	100
11	0.610	170	103.7	8.1	7.10	21.7	YES	100
12	0.680	170	115.6	7.4	7.24	24.0	YES	100
13	0.780	170	132.6	7.8	7.28	24.0	YES	100
14	0.790	170	134.3	7.7	7.34	24.7	YES	100
15	0.640	170	108.8	7.6	7.36	24.6	YES	100
16	0.660	170	112.2	7.7	7.40	24.9	YES	100
17	0.800	170	136.0	8.3	7.36	23.9	YES	100
18	1.250	170	212.5	8.5	7.32	24.5	YES	100
19	1.170	170	198.9	9.4	7.31	22.8	YES	100
20	1.030	170	175.1	8.6	7.38	24.3	YES	100
21	1.000	170	170.0	8.7	7.46	24.7	YES	100
22	1.100	170	187.0	8.8	7.50	25.2	YES	100
23	0.890	170	151.3	8.7	7.45	24.3	YES	100
24	1.010	170	171.7	9.0	7.34	23.2	YES	100
25	0.920	170	156.4	8.5	7.36	23.9	YES	100
26	0.830	170	141.1	8.8	7.48	24.2	YES	100
27	0.930	170	158.1	8.7	7.38	23.8	YES	100
28	0.950	170	161.5	8.8	7.40	23.9	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013