

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Mar-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.013	OFF	OFF	OFF	OFF	OFF	0.01
2	OFF	OFF	OFF	OFF	OFF	0.013	0.01
3	0.013	0.014	OFF	OFF	OFF	OFF	0.01
4	OFF	0.014	OFF	OFF	OFF	0.013	0.01
5	0.014	OFF	OFF	OFF	OFF	OFF	0.01
6	0.013	0.014	0.014	0.014	OFF	OFF	0.01
7	OFF	OFF	OFF	0.013	0.014	0.013	0.01
8	0.013	OFF	OFF	OFF	OFF	OFF	0.01
9	OFF	0.013	OFF	OFF	OFF	OFF	0.01
10	OFF	OFF	0.013	OFF	0.014	0.013	0.01
11	0.013	OFF	OFF	OFF	OFF	OFF	0.01
12	0.013	0.013	OFF	OFF	OFF	OFF	0.01
13	0.013	0.014	OFF	OFF	OFF	OFF	0.01
14	OFF	0.013	OFF	OFF	OFF	0.013	0.01
15	0.013	0.013	OFF	OFF	OFF	OFF	0.01
16	OFF	0.014	OFF	OFF	OFF	0.013	0.01
17	0.013	0.013	OFF	OFF	OFF	OFF	0.01
18	0.014	0.014	OFF	OFF	OFF	OFF	0.01
19	0.014	0.014	OFF	OFF	OFF	OFF	0.01
20	OFF	0.013	OFF	OFF	OFF	OFF	0.01
21	0.013	0.015	0.014	OFF	OFF	OFF	0.02
22	0.013	OFF	OFF	OFF	OFF	0.015	0.02
23	0.014	OFF	OFF	OFF	OFF	OFF	0.01
24	OFF	0.013	OFF	0.014	OFF	OFF	0.01
25	OFF	OFF	OFF	OFF	0.014	0.013	0.01
26	0.013	OFF	OFF	OFF	OFF	0.013	0.01
27	0.013	0.013	OFF	OFF	0.014	0.013	0.01
28	0.013	OFF	OFF	OFF	OFF	OFF	0.01
29	0.013	0.013	OFF	OFF	OFF	OFF	0.01
30	OFF	OFF	OFF	0.013	0.014	0.014	0.01
31	0.013	OFF	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? ² Yes No
 All daily turbidity readings ≤ 5 NTU? Yes No

CT's met everyday? (see back) Yes No
 All Cl2 residual at entry point ≥ 0.2 mg/l? Yes No

Notes:

PRINTED NAME: David L. Nordman
 SIGNATURE: *[Signature]* 4/6/2021
 PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A
 Disinfection *Giardia*
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Mar-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.910	170	154.7	8.4	7.40	24.4	YES	100
2	0.940	170	159.8	8.5	7.40	24.3	YES	100
3	0.900	170	153.0	8.9	7.44	23.9	YES	100
4	0.710	170	120.7	9.0	7.54	24.1	YES	100
5	0.820	170	139.4	9.5	7.52	23.4	YES	100
6	0.920	170	156.4	9.0	7.52	24.5	YES	100
7	0.890	170	151.3	8.9	7.71	26.3	YES	100
8	0.950	170	161.5	8.7	7.61	25.9	YES	100
9	0.900	170	153.0	8.6	7.64	26.2	YES	100
10	0.860	170	146.2	9.8	7.57	23.5	YES	100
11	0.900	170	153.0	8.6	7.51	25.0	YES	100
12	0.940	170	159.8	9.0	7.66	25.8	YES	100
13	0.860	170	146.2	9.6	7.58	23.9	YES	100
14	0.850	170	144.5	9.4	7.56	24.0	YES	100
15	0.990	170	168.3	9.1	7.52	24.5	YES	100
16	0.990	170	168.3	8.4	7.68	27.2	YES	100
17	0.980	170	166.6	8.3	7.76	28.2	YES	100
18	0.990	170	168.3	9.0	7.43	23.9	YES	100
19	0.940	170	159.8	9.6	7.69	25.1	YES	100
20	0.920	170	156.4	9.0	7.74	26.5	YES	100
21	0.900	170	153.0	9.1	7.70	25.9	YES	100
22	0.960	170	163.2	9.2	7.70	25.9	YES	100
23	0.980	170	166.6	9.1	7.69	26.1	YES	100
24	1.000	170	170.0	9.8	7.71	25.1	YES	100
25	0.890	170	151.3	9.1	7.59	24.9	YES	100
26	0.810	170	137.7	8.9	7.56	24.7	YES	100
27	0.860	170	146.2	9.8	7.10	19.9	YES	100
28	0.890	170	151.3	9.9	7.12	20.0	YES	100
29	0.900	170	153.0	9.8	7.30	21.5	YES	100
30	0.940	170	159.8	9.6	7.33	22.1	YES	100
31	1.000	170	170.0	9.7	7.40	22.6	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013