


OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK  
 Month/Year: Apr-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882		WTP : TP - A					
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.014	0.013	OFF	OFF	OFF	0.013	0.01
2	OFF	0.013	OFF	OFF	OFF	OFF	0.01
3	OFF	OFF	0.018	0.017	OFF	OFF	0.02
4	OFF	OFF	OFF	OFF	OFF	0.014	0.01
5	0.013	0.013	OFF	OFF	OFF	OFF	0.01
6	OFF	0.013	OFF	OFF	OFF	OFF	0.01
7	0.014	0.014	OFF	OFF	OFF	OFF	0.01
8	OFF	0.013	OFF	OFF	0.014	OFF	0.01
9	0.014	OFF	OFF	OFF	OFF	0.013	0.01
10	0.014	0.013	OFF	OFF	OFF	0.013	0.01
11	0.014		OFF	OFF	0.014	OFF	0.01
12	0.013	OFF	0.013	OFF	OFF	OFF	0.01
13	0.013	0.013	OFF	OFF	OFF	OFF	0.01
14	OFF	OFF	OFF	0.014	0.013	0.013	0.01
15	OFF	OFF	OFF	OFF	OFF	0.013	0.01
16	0.013	OFF	OFF	OFF	OFF	0.014	0.01
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	0.013	0.013	OFF	OFF	OFF	OFF	0.01
19	0.013	0.013	OFF	OFF	0.014	OFF	0.01
20	0.013	0.013	OFF	OFF	OFF	OFF	0.01
21	OFF	OFF	OFF	OFF	0.013	0.013	0.01
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	0.014	0.01
24	0.013	0.013	OFF	OFF	OFF	OFF	0.01
25	0.013	0.013	OFF	OFF	OFF	OFF	0.01
26	0.013	0.013	OFF	0.013	OFF	OFF	0.01
27	OFF	OFF	OFF	OFF	0.013	0.013	0.01
28	0.013	OFF	OFF	OFF	OFF	0.013	0.01
29	0.013	0.013	OFF	OFF	0.014	OFF	0.01
30	0.013	0.013	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
		All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
		<input checked="" type="radio"/> Yes <input type="radio"/> No

Notes:	PRINTED NAME: David L. Nordman
	SIGNATURE:  5/4/2021
	PHONE #: ( 503 ) 842- 6462 CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A  
 Disinfection *Giardia*  
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Apr-21

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.790	170	134.3	9.2	7.59	24.4	YES	100
2	0.850	170	144.5	9.0	7.80	26.9	YES	100
3	0.840	170	142.8	10.0	7.70	24.2	YES	100
4	0.860	170	146.2	10.1	7.71	24.2	YES	100
5	0.880	170	149.6	9.8	7.64	24.1	YES	100
6	0.900	170	153.0	9.6	7.61	24.3	YES	100
7	1.060	170	180.2	9.7	7.60	24.5	YES	100
8	0.930	170	158.1	10.4	7.64	23.3	YES	100
9	0.840	170	142.8	9.8	7.66	24.2	YES	100
10	0.840	170	142.8	9.8	7.49	22.8	YES	100
11	0.860	170	146.2	9.7	7.50	23.1	YES	100
12	0.900	170	153.0	9.5	7.52	23.7	YES	100
13	0.940	170	159.8	9.4	7.50	23.8	YES	100
14	1.000	170	170.0	9.2	7.48	24.1	YES	100
15	0.830	170	141.1	10.6	7.67	23.0	YES	100
16	0.880	170	149.6	11.3	7.63	21.8	YES	100
17	0.830	170	141.1	12.0	7.56	20.2	YES	100
18	0.840	170	142.8	12.1	7.59	20.3	YES	100
19	0.860	170	146.2	12.2	7.62	20.4	YES	100
20	0.900	170	153.0	12.3	7.59	20.2	YES	100
21	0.940	170	159.8	12.4	7.61	20.3	YES	100
22	0.910	170	154.7	12.2	7.63	20.6	YES	100
23	0.810	170	137.7	12.3	7.61	20.1	YES	100
24	0.880	170	149.6	11.9	7.62	20.9	YES	100
25	0.890	170	151.3	11.7	7.60	21.0	YES	100
26	0.890	170	151.3	11.8	7.63	21.1	YES	100
27	0.890	170	151.3	11.7	7.66	21.5	YES	100
28	0.840	170	142.8	12.4	7.60	20.0	YES	100
29	0.820	170	139.4	12.3	7.55	19.7	YES	100
30	0.740	170	125.8	12.3	7.63	20.1	YES	100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013