

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK  
 Month/Year: May-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A


Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	0.013	0.013	0.013	0.01
2	OFF	OFF	OFF	OFF	0.013	OFF	0.01
3	0.013	0.013	OFF	OFF	OFF	OFF	0.01
4	OFF	0.013	OFF	OFF	OFF	OFF	0.01
5	0.013	0.013	OFF	0.014	0.014	OFF	0.01
6	OFF	OFF	OFF	OFF	0.013	0.013	0.01
7	0.013	OFF	OFF	OFF	OFF	0.013	0.01
8	0.013	0.013	OFF	OFF	OFF	0.013	0.01
9	0.013	OFF	OFF	OFF	0.013	OFF	0.01
10	0.013	0.013	OFF	OFF	OFF	OFF	0.01
11	0.013	0.013	OFF	OFF	OFF	OFF	0.01
12	OFF	0.013	OFF	OFF	OFF	OFF	0.02
13	OFF	OFF	0.017	0.013	0.013	0.013	0.01
14	0.013	OFF	OFF	OFF	OFF	0.013	0.01
15	0.013	0.014	OFF	OFF	OFF	0.013	0.01
16	OFF	0.014	OFF	OFF	OFF	OFF	0.01
17	OFF	0.013	OFF	OFF	OFF	0.013	0.01
18	0.013	0.013	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	0.02
20	OFF	OFF	0.016	0.013	0.013	0.013	0.01
21	0.013	0.013	OFF	0.013	OFF	0.013	0.01
22	OFF	OFF	OFF	OFF	OFF	0.013	0.01
23	0.013	OFF	OFF	OFF	OFF	OFF	0.01
24	0.013	OFF	OFF	OFF	OFF	OFF	0.01
25	0.013	0.014	OFF	OFF	0.013	OFF	0.01
26	OFF	OFF	OFF	OFF	OFF	0.013	0.01
27	0.013	0.013	OFF	OFF	OFF	OFF	0.01
28	0.013	0.013	OFF	OFF	OFF	0.013	0.01
29	0.013	0.013	OFF	OFF	OFF	OFF	0.01
30	OFF	0.013	OFF	OFF	OFF	0.013	0.01
31	0.013	0.013	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point $\geq$ 0.2 mg/l?	<input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings $\leq$ 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No				

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

PHONE #: ( 503 ) 842- 6462

6/7/2021

CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.



OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A  
 Disinfection *Giardia*  
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: May-21

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.780	170	132.6	12.1	7.44	19.1	YES	100
2	0.800	170	136.0	12.2	7.46	19.2	YES	100
3	0.810	170	137.7	12.0	7.42	19.2	YES	100
4	0.790	170	134.3	12.2	7.48	19.3	YES	100
5	0.840	170	142.8	12.4	7.45	19.0	YES	100
6	0.830	170	141.1	12.3	7.68	20.6	YES	100
7	0.900	170	153.0	12.2	7.33	18.5	YES	100
8	0.850	170	144.5	12.1	7.40	19.0	YES	100
9	0.870	170	147.9	12.2	7.40	18.9	YES	100
10	0.900	170	153.0	12.4	7.45	19.1	YES	100
11	0.910	170	154.7	12.5	7.44	18.7	YES	100
12	0.940	170	159.8	12.4	7.56	19.9	YES	100
13	1.060	170	180.2	12.4	7.35	18.8	YES	100
14	0.990	170	168.3	12.5	7.68	20.7	YES	100
15	1.080	170	183.6	12.4	7.66	20.9	YES	100
16	1.100	170	187.0	12.5	7.69	21.0	YES	100
17	1.060	170	180.2	12.6	7.69	20.8	YES	100
18	1.100	170	187.0	12.5	7.70	21.1	YES	100
19	1.080	170	183.6	11.7	7.69	22.2	YES	100
20	0.950	170	161.5	12.7	7.08	16.3	YES	100
21	0.970	170	164.9	12.3	7.23	17.9	YES	100
22	1.080	170	183.6	12.8	7.06	16.3	YES	100
23	1.090	170	185.3	12.7	7.20	17.3	YES	100
24	1.100	170	187.0	12.8	7.30	17.8	YES	100
25	1.140	170	193.8	12.7	7.28	17.9	YES	100
26	1.000	170	170.0	12.4	7.30	18.3	YES	100
27	0.960	170	163.2	12.8	7.17	16.7	YES	100
28	0.850	170	144.5	13.1	7.08	15.7	YES	100
29	1.000	170	170.0	12.7	7.10	16.5	YES	100
30	1.010	170	171.7	12.8	7.16	16.8	YES	100
31	1.020	170	173.4	12.7	7.15	16.8	YES	100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013