

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Jun-21


System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off	Off	Off	0.013	0.013	0.013	0.01
2	0.012	0.013	Off	0.013	0.013	0.013	0.01
3	Off	Off	Off	Off	0.013	0.013	0.01
4	0.013	0.013	Off	Off	Off	0.013	0.01
5	0.013	Off	Off	Off	0.013	0.013	0.01
6	0.013	Off	Off	Off	Off	0.013	0.01
7	0.013	Off	Off	Off	Off	Off	0.01
8	0.014	0.013	Off	Off	Off	Off	0.01
9	0.014	Off	Off	Off	Off	0.013	0.01
10	0.013	0.013	Off	Off	Off	Off	0.01
11	0.013	0.013	Off	Off	Off	Off	0.01
12	Off	0.013	Off	Off	Off	Off	0.01
13	0.013	0.013	Off	Off	Off	Off	0.01
14	0.014	0.014	Off	0.013	Off	Off	0.01
15	Off	Off	Off	Off	0.013	0.013	0.01
16	0.013	0.013	Off	Off	Off	0.013	0.01
17	0.013	0.013	Off	0.013	0.013	Off	0.01
18	Off	Off	Off	Off	Off	Off	OFF
19	Off	Off	Off	Off	Off	Off	OFF
20	0.014	0.013	Off	Off	Off	Off	0.01
21	0.013	Off	Off	Off	Off	0.013	0.01
22	0.013	0.013	Off	Off	Off	0.013	0.01
23	Off	0.013	Off	Off	Off	0.013	0.01
24	0.013	0.013	Off	Off	Off	0.013	0.01
25	0.013	0.013	Off	Off	0.016	0.013	0.02
26	0.013	Off	Off	Off	0.016	0.013	0.02
27	0.013	Off	Off	Off	Off	0.013	0.01
28	0.014	Off	0.014	Off	Off	Off	0.01
29	0.012	Off		Off	0.013	0.013	0.01
30	0.013	Off	Off	Off	Off	0.013	0.01

Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU? ²	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point \geq 0.2 mg/l?
		<input checked="" type="radio"/> Yes <input type="radio"/> No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE:  7/7/2021

PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jun-21

Disinfection *Giardia*
Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.040	170	176.8	12.6	7.20	17.3	YES	100
2	0.910	170	154.7	14.5	7.03	14.1	YES	100
3	0.890	170	151.3	14.7	6.91	13.3	YES	100
4	0.990	170	168.3	14.4	6.91	13.7	YES	100
5	0.900	170	153.0	14.3	7.05	14.4	YES	100
6	0.930	170	158.1	14.4	7.15	14.9	YES	100
7	0.940	170	159.8	14.6	7.17	14.8	YES	100
8	0.950	170	161.5	14.3	7.20	15.3	YES	100
9	0.900	170	153.0	14.3	7.15	14.9	YES	100
10	0.890	170	151.3	18.2	7.16	11.5	YES	100
11	0.820	170	139.4	13.9	7.31	16.1	YES	100
12	0.840	170	142.8	18.2	7.23	11.8	YES	100
13	0.860	170	146.2	14.4	7.25	15.3	YES	100
14	0.890	170	151.3	14.6	7.29	15.4	YES	100
15	0.840	170	142.8	14.7	7.33	15.4	YES	100
16	0.800	170	136.0	14.6	7.36	15.6	YES	100
17	0.640	170	108.8	15.0	7.27	14.4	YES	100
18	0.520	170	88.4	13.2	7.28	16.1	YES	100
19	0.510	170	86.7	15.0	7.23	14.0	YES	100
20	0.560	170	95.2	15.1	7.26	14.2	YES	100
21	0.600	170	102.0	15.2	7.36	14.7	YES	100
22	0.670	170	113.9	15.4	7.34	14.5	YES	100
23	0.800	170	136.0	15.2	7.35	15.0	YES	100
24	0.650	170	110.5	15.1	7.31	14.6	YES	100
25	0.680	170	115.6	15.7	7.38	14.4	YES	100
26	0.710	170	120.7	16.0	7.30	13.8	YES	100
27	0.720	170	122.4	16.1	7.33	13.9	YES	100
28	0.740	170	125.8	16.2	7.36	13.9	YES	100
29	0.800	170	136.0	16.3	7.34	13.8	YES	100
30	0.640	170	108.8	17.2	7.11	11.7	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013