

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Jul-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.013	OFF	OFF	OFF	OFF	0.013	0.01
2	0.013	OFF	OFF	OFF	0.013	0.013	0.01
3	0.013	0.013	OFF	OFF	OFF	OFF	0.01
4	0.013	0.014	0.013	OFF	OFF	OFF	0.01
5	0.013	0.012	OFF	0.013	0.013	0.012	0.01
6	0.013	OFF	OFF	OFF	OFF	OFF	0.01
7	OFF	OFF	0.013	OFF	0.013	0.013	0.01
8	0.013	0.012	OFF	OFF	OFF	0.013	0.01
9	OFF	OFF	OFF	OFF	0.013	0.013	0.01
10	0.013	OFF	OFF	OFF	0.013	0.012	0.01
11	0.012	OFF	OFF	OFF	OFF	0.013	0.01
12	0.013	OFF	OFF	OFF	OFF	0.013	0.01
13	OFF	OFF	OFF	OFF	0.013	0.013	0.01
14	0.013	OFF	OFF	OFF	0.013	0.013	0.01
15	0.013	OFF	OFF	OFF	0.013	0.013	0.01
16	0.013	OFF	OFF	OFF	OFF	0.013	0.01
17	OFF	OFF	OFF	OFF	0.013	0.013	0.01
18	0.013	OFF	OFF	OFF	OFF	0.013	0.01
19	0.013	OFF	OFF	OFF	OFF	0.013	0.01
20	0.013	0.012	OFF	OFF	0.013	OFF	0.01
21	0.013	0.013	OFF	OFF	0.017	OFF	0.02
22	0.013	0.012	OFF	OFF	0.013	0.012	0.01
23	0.012	OFF	OFF	OFF	0.014	OFF	0.01
24	OFF	OFF	OFF	OFF	OFF	0.013	0.01
25	0.012	OFF	OFF	OFF	OFF	0.012	0.01
26	0.013	OFF	OFF	OFF	OFF	0.013	0.01
27	0.012	OFF	OFF	OFF	0.013	0.012	0.01
28	OFF	OFF	OFF	OFF	0.013	OFF	0.01
29	0.012	OFF	OFF	OFF	0.012	0.012	0.01
30	0.013	OFF	OFF	OFF	0.012	0.012	0.01
31	0.012	OFF	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? ² Yes No

All daily turbidity readings ≤ 5 NTU? Yes No

CT's met everyday? (see back) Yes No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

8-6-2021

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia*
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jul-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.660	170	112.2	17.1	6.95	11.2	YES	100
2	0.630	170	107.1	16.8	7.04	11.7	YES	100
3	0.730	170	124.1	17.2	7.10	11.8	YES	100
4	0.730	170	124.1	17.0	7.15	12.2	YES	100
5	0.790	170	134.3	16.8	7.20	12.7	YES	100
6	0.560	170	95.2	15.1	7.28	14.3	YES	100
7	0.058	170	9.9	15.9	7.29	12.8	NO	100
8	0.630	170	107.1	17.4	7.21	12.0	YES	100
9	0.680	170	115.6	15.9	7.23	13.5	YES	100
10	0.730	170	124.1	16.0	7.20	13.3	YES	100
11	0.740	170	125.8	16.1	7.25	13.5	YES	100
12	0.610	170	103.7	15.9	7.24	13.4	YES	100
13	0.680	170	115.6	15.7	7.21	13.5	YES	100
14	0.710	170	120.7	15.6	7.30	14.1	YES	100
15	0.760	170	129.2	15.7	7.29	14.1	YES	100
16	0.720	170	122.4	15.6	7.34	14.4	YES	100
17	0.610	170	103.7	15.8	7.46	14.6	YES	100
18	0.610	170	103.7	15.9	7.26	13.5	YES	100
19	0.600	170	102.0	15.8	7.29	13.7	YES	100
20	0.610	170	103.7	15.7	7.33	14.1	YES	100
21	0.650	170	110.5	15.8	7.40	14.4	YES	100
22	0.640	170	108.8	15.6	7.52	15.2	YES	100
23	0.660	170	112.2	15.7	7.49	15.0	YES	100
24	0.710	170	120.7	15.7	7.23	13.7	YES	100
25	0.720	170	122.4	15.8	7.29	13.9	YES	100
26	0.740	170	125.8	15.6	7.34	14.4	YES	100
27	0.770	170	130.9	15.8	7.30	14.1	YES	100
28	0.650	170	110.5	15.6	7.38	14.5	YES	100
29	0.570	170	96.9	15.7	7.45	14.6	YES	100
30	0.620	170	105.4	15.5	7.21	13.6	YES	100
31	0.520	170	88.4	15.3	7.29	14.1	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013