

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Aug-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.012	OFF	OFF	OFF	0.013	0.012	0.01
2	0.012	OFF	OFF	OFF	OFF	0.012	0.01
3	0.012	OFF	OFF	OFF	0.013	0.013	0.01
4	OFF	OFF	OFF	OFF	0.015	0.013	0.02
5	0.013	OFF	OFF	OFF	0.013	0.013	0.01
6	0.013	OFF	OFF	OFF	OFF	0.013	0.01
7	0.013	0.013	OFF	OFF	OFF	0.013	0.01
8	0.013	0.013	OFF	OFF	OFF	OFF	0.01
9	OFF	0.013	OFF	OFF	OFF	0.013	0.01
10	0.013	0.013	OFF	OFF	OFF	0.013	0.01
11	0.013	0.013	OFF	OFF	OFF	0.013	0.01
12	0.013	0.013	OFF	OFF	0.014	0.013	0.01
13	0.013	OFF	OFF	OFF	0.013	0.013	0.01
14	OFF	0.013	OFF	OFF	0.013	0.014	0.01
15	0.013	0.013	OFF	0.013	0.013	0.013	0.01
16	0.013	OFF	OFF	OFF	OFF	0.013	0.01
17	0.013	0.013	OFF	OFF	0.013	0.013	0.01
18	0.013	0.013	OFF	OFF	0.013	OFF	0.01
19	0.012	0.012	OFF	OFF	OFF	0.013	0.01
20	0.012	0.012	OFF	OFF	OFF	0.013	0.01
21	0.013	0.012	OFF	OFF	OFF	0.013	0.01
22	0.013	0.012	OFF	OFF	OFF	OFF	0.01
23	OFF	0.013	OFF	OFF	OFF	OFF	0.01
24	OFF	OFF	OFF	OFF	0.013	0.013	0.01
25	0.015	OFF	OFF	0.013	OFF	OFF	0.02
26	0.012	OFF	OFF	OFF	0.252	0.013	0.25
27	0.013	OFF	OFF	OFF	0.012	0.012	0.01
28	0.012	0.012	OFF	OFF	0.013	0.012	0.01
29	0.013	OFF	OFF	OFF	OFF	0.013	0.01
30	0.013	0.013	OFF	OFF	0.013	0.012	0.01
31	0.013	0.012	OFF	OFF	0.013	0.012	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU?² Yes No

All daily turbidity readings ≤ 5 NTU? Yes No

CT's met everyday? (see back) Yes No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

9/9/2021

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A
 Disinfection *Giardia*
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Aug-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.560	170	95.2	15.4	7.31	14.1	YES	100
2	0.610	170	103.7	15.5	7.36	14.4	YES	100
3	0.660	170	112.2	15.4	7.40	14.8	YES	100
4	0.550	170	93.5	15.0	7.30	14.5	YES	100
5	0.700	170	119.0	15.5	6.95	12.5	YES	100
6	0.660	170	112.2	15.7	6.96	12.3	YES	100
7	0.600	170	102.0	15.5	6.91	12.2	YES	100
8	0.580	170	98.6	15.6	7.06	12.7	YES	100
9	0.690	170	117.3	15.8	7.00	12.5	YES	100
10	0.420	170	71.4	15.6	7.06	12.5	YES	100
11	0.520	170	88.4	15.8	6.79	11.3	YES	100
12	0.510	170	86.7	16.2	6.97	11.7	YES	100
13	0.490	170	83.3	16.1	7.07	12.2	YES	100
14	0.540	170	91.8	16.0	7.12	12.6	YES	100
15	0.600	170	102.0	16.1	7.20	13.0	YES	100
16	0.530	170	90.1	16.3	7.24	12.9	YES	100
17	0.550	170	93.5	16.2	7.26	13.1	YES	100
18	0.540	170	91.8	16.2	7.24	13.0	YES	100
19	0.560	170	95.2	16.3	7.27	13.1	YES	100
20	0.770	170	130.9	16.2	7.21	13.2	YES	100
21	0.720	170	122.4	16.3	7.19	13.0	YES	100
22	0.700	170	119.0	16.2	7.20	13.1	YES	100
23	0.680	170	115.6	16.2	7.19	13.0	YES	100
24	0.710	170	120.7	16.3	7.21	13.1	YES	100
25	0.740	170	125.8	16.4	7.18	12.9	YES	100
26	0.770	170	130.9	16.8	7.10	12.2	YES	100
27	0.750	170	127.5	15.8	7.10	13.0	YES	100
28	0.690	170	117.3	15.7	7.00	12.5	YES	100
29	0.750	170	127.5	15.7	7.12	13.2	YES	100
30	0.730	170	124.1	14.9	7.15	14.1	YES	100
31	0.740	170	125.8	14.9	7.19	14.3	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013