

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Sep-21


System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	0.013	0.01
2	0.013	0.013	OFF	OFF	OFF	0.012	0.01
3	0.012	0.012	OFF	OFF	OFF	OFF	0.01
4	OFF	OFF	OFF	OFF	0.013	0.013	0.01
5	OFF	0.013	OFF	0.013	OFF	0.013	0.01
6	OFF	0.013	OFF	0.013	OFF	0.012	0.01
7	0.013	0.012	0.013	OFF	0.014	0.013	0.01
8	0.013	OFF	OFF	OFF	OFF	OFF	0.01
9	OFF	0.013	OFF	OFF	0.013	OFF	0.01
10	0.013	OFF	OFF	OFF	OFF	0.013	0.01
11	0.014	0.013	OFF	OFF	OFF	0.013	0.01
12	0.013	0.014	OFF	OFF	OFF	0.012	0.01
13	0.014	0.013	OFF	OFF	OFF	OFF	0.01
14	OFF	0.013	0.013	OFF	0.012	0.013	0.01
15	0.013	0.013	0.012	0.012	0.012	0.013	0.01
16	0.013	OFF	OFF	OFF	OFF	OFF	0.01
17	OFF	0.013	OFF	OFF	0.012	OFF	0.01
18	0.013	OFF	OFF	OFF	OFF	OFF	0.01
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	0.009	0.011	0.01
22	0.011	0.010	0.012	0.010	OFF	0.010	0.01
23	OFF	0.010	0.014	OFF	OFF	OFF	0.01
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	0.016	0.017	0.014	OFF	0.02
28	OFF	OFF	0.018	0.020	0.013	OFF	0.02
29	OFF	OFF	0.013	0.014	0.016	OFF	0.02
30	OFF	OFF	0.015	0.013	0.014	OFF	0.02

Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE:  9/9/2021

PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia*
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Sep-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.600	170	102.0	14.8	7.15	13.9	YES	100
2	0.660	170	112.2	16.3	7.74	15.8	YES	100
3	0.670	170	113.9	16.0	7.76	16.3	YES	100
4	0.700	170	119.0	15.9	7.70	16.1	YES	100
5	0.690	170	117.3	15.6	7.68	16.3	YES	100
6	0.700	170	119.0	15.6	7.64	16.0	YES	100
7	0.800	170	136.0	14.9	7.74	17.6	YES	100
8	0.740	170	125.8	14.8	7.68	17.2	YES	100
9	0.710	170	120.7	14.8	7.66	17.1	YES	100
10	0.780	170	132.6	18.1	7.81	14.6	YES	100
11	0.750	170	127.5	19.8	7.67	12.3	YES	100
12	0.790	170	134.3	14.2	7.64	17.8	YES	100
13	0.810	170	137.7	14.0	7.70	18.5	YES	100
14	0.800	170	136.0	13.7	7.70	18.8	YES	100
15	0.760	170	129.2	13.8	7.69	18.5	YES	100
16	0.930	170	158.1	13.9	7.83	19.8	YES	100
17	0.540	170	91.8	14.8	7.86	18.0	YES	100
18	0.560	170	95.2	14.6	7.84	18.2	YES	100
19	0.600	170	102.0	14.5	7.72	17.6	YES	100
20	0.790	170	134.3	14.3	7.44	16.4	YES	100
21	0.640	170	108.8	15.1	7.94	18.4	YES	100
22	0.710	170	120.7	14.7	7.53	16.4	YES	100
23	0.680	170	115.6	15.0	7.55	16.1	YES	100
24	0.670	170	113.9	16.6	7.58	14.6	YES	100
25	0.500	170	85.0	15.4	7.34	14.2	YES	100
26	0.460	170	78.2	15.5	7.55	15.2	YES	100
27	0.410	170	69.7	15.1	7.61	15.9	YES	100
28	0.560	170	95.2	14.9	7.70	16.9	YES	100
29	0.580	170	98.6	14.6	7.54	16.3	YES	100
30	0.550	170	93.5	14.7	7.87	18.2	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.