

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK  
 Month/Year: Oct-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	0.091	0.105	0.086	OFF	0.11
2	OFF	OFF	0.086	0.103	0.093	OFF	0.10
3	OFF	OFF	0.094	0.104	0.110	OFF	0.10
4	OFF	OFF	0.092	0.101	0.100	OFF	0.10
5	OFF	OFF	0.091	0.111	0.092	OFF	0.11
6	OFF	OFF	0.090	0.103	0.100	0.104	0.10
7	OFF	OFF	0.091	0.124	0.112	OFF	0.12
8	OFF	OFF	OFF	0.091	0.092	OFF	0.09
9	OFF	OFF	0.109	0.112	0.088	OFF	0.11
10	OFF	OFF	0.110	0.101	0.080	OFF	0.11
11	OFF	OFF	0.102	0.105	0.098	OFF	0.11
12	OFF	OFF	0.098	0.120	0.116	OFF	0.12
13	OFF	OFF	0.098	0.125	0.109	OFF	0.13
14	OFF	OFF	0.100	OFF	0.094	OFF	0.10
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	0.092	0.106	OFF	0.11
17	OFF	OFF	0.094	OFF	OFF	OFF	0.09
18	OFF	OFF	0.098	0.101	0.116	OFF	0.12
19	OFF	OFF	0.111	0.115	0.100	OFF	0.12
20	OFF	OFF	OFF	0.111	0.109	OFF	0.11
21	OFF	OFF	0.123	0.128	0.112	OFF	0.13
22	OFF	OFF	0.132	0.125	0.109	OFF	0.13
23	OFF	OFF	0.104	OFF	OFF	OFF	0.10
24	OFF	OFF	0.102	OFF	OFF	OFF	0.10
25	OFF	OFF	0.104	0.106	0.099	OFF	0.11
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	0.104	OFF	0.10
30	OFF	OFF	0.099	0.109	0.112	OFF	0.11
31	OFF	OFF	0.106	0.098	0.118	OFF	0.12

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings  $\leq$  1 NTU? <sup>2</sup>  Yes  No  
 All daily turbidity readings  $\leq$  5 NTU?  Yes  No

CT's met everyday? (see back)  Yes  No

All Cl2 residual at entry point  $\geq$  0.2 mg/l?  Yes  No

Notes:

PRINTED NAME: David L. Nordman  
 SIGNATURE: *[Signature]* 11/4/2021 9/8/2021  
 PHONE #: ( 503 ) 842-6462 CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A  
 Disinfection *Giardia*  
 Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Oct-21

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.490	170	83.3	13.8	7.64	17.6	YES	100
2	0.640	170	108.8	14.0	7.80	18.8	YES	100
3	0.650	170	110.5	13.9	7.62	17.7	YES	100
4	0.680	170	115.6	13.8	7.69	18.4	YES	100
5	1.060	170	180.2	13.7	7.51	18.1	YES	100
6	0.970	170	164.9	13.4	7.56	18.6	YES	100
7	1.080	170	183.6	12.6	7.36	18.4	YES	100
8	1.400	170	238.0	12.4	7.64	21.6	YES	100
9	1.250	170	212.5	14.0	7.36	17.1	YES	100
10	1.160	170	197.2	13.8	7.40	17.4	YES	100
11	0.570	170	96.9	12.4	7.37	17.9	YES	100
12	0.600	170	102.0	12.1	7.41	18.6	YES	100
13	0.360	170	61.2	11.7	7.32	18.0	YES	100
14	0.480	170	81.6	12.1	7.40	18.3	YES	100
15	0.270	170	45.9	12.1	7.27	17.1	YES	100
16	0.240	170	40.8	13.2	7.26	15.5	YES	100
17	0.490	170	83.3	12.9	7.29	16.5	YES	100
18	0.620	170	105.4	12.0	7.64	20.3	YES	100
19	0.660	170	112.2	12.0	7.50	19.4	YES	100
20	0.700	170	119.0	11.9	7.49	19.5	YES	100
21	0.730	170	124.1	12.8	7.08	15.8	YES	100
22	0.780	170	132.6	12.8	7.25	16.9	YES	100
23	0.620	170	105.4	12.4	7.29	17.5	YES	100
24	0.650	170	110.5	12.3	7.39	18.3	YES	100
25	0.540	170	91.8	12.2	7.30	17.6	YES	100
26	0.220	170	37.4	12.4	7.47	17.8	7.27	100
27	0.260	170	44.2	12.5	7.05	15.1	YES	100
28	0.250	170	42.5	12.8	7.29	16.1	YES	100
29	0.270	170	45.9	12.9	7.35	16.4	YES	100
30	0.780	170	132.6	12.0	7.17	17.5	YES	100
31	0.940	170	159.8	12.4	7.47	19.3	YES	100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013