

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK  
 Month/Year: Nov-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	0.220	0.150	0.125	OFF	0.22
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	0.010	0.012	OFF	OFF	OFF	0.01
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	0.009	0.010	0.010	0.01
7	0.014	0.015	0.014	0.010	0.012	0.014	0.02
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	0.014	0.013	0.015	OFF	0.02
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	0.010	0.010	OFF	0.01
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	0.012	0.014	0.012	OFF	0.01
15	OFF	OFF	0.011	OFF	0.013	OFF	0.01
16	OFF	0.012	0.013	0.013	0.014	0.013	0.01
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	0.011	OFF	0.010	OFF	OFF	0.01
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	0.010	0.010	0.011	OFF	OFF	OFF	0.01
21	0.011	0.013	0.014	OFF	OFF	OFF	0.01
22	OFF	OFF	OFF	0.011	OFF	OFF	0.01
23	OFF	0.013	0.012	0.011	OFF	OFF	0.01
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	0.010	0.010	0.011	0.010	OFF	0.01
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	0.012	0.011	OFF	0.01
28	OFF	OFF	0.014	0.010	0.012	0.013	0.01
29	OFF	0.011	0.012	0.012	0.014	OFF	0.01
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings  $\leq$  1 NTU? <sup>2</sup>  Yes  No  
 All daily turbidity readings  $\leq$  5 NTU?  Yes  No

CT's met everyday? (see back)  Yes  No

All Cl<sub>2</sub> residual at entry point  $\geq$  0.2 mg/l?  Yes  No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE:  12/6/2021

PHONE #: ( 503 ) 842- 6462

CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Nov-21

Disinfection *Giardia*  
Log Inactiv: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.670	170	113.9	12.0	7.20	17.5	YES	100
2	1.070	170	181.9	12.2	7.18	17.9	YES	100
3	1.040	170	176.8	12.1	7.39	19.4	YES	100
4	0.940	170	159.8	12.1	7.36	18.9	YES	100
5	0.960	170	163.2	11.8	7.12	17.8	YES	100
6	0.960	170	163.2	11.2	7.16	18.8	YES	100
7	0.990	170	168.3	11.1	7.24	19.5	YES	100
8	1.000	170	170.0	11.0	7.29	20.0	YES	100
9	0.980	170	166.6	10.9	7.34	20.4	YES	100
10	0.880	170	149.6	10.9	7.29	19.9	YES	100
11	0.840	170	142.8	11.3	7.30	19.3	YES	100
12	0.920	170	156.4	12.1	7.45	19.5	YES	100
13	0.830	170	141.1	11.5	7.42	19.9	YES	100
14	0.860	170	146.2	11.3	7.56	21.2	YES	100
15	0.840	170	142.8	11.3	7.48	20.6	YES	100
16	1.000	170	170.0	11.3	7.50	21.1	YES	100
17	0.990	170	168.3	11.0	7.48	21.3	YES	100
18	0.890	170	151.3	11.5	7.49	20.5	YES	100
19	0.990	170	168.3	11.4	7.51	21.0	YES	100
20	1.060	170	180.2	11.4	7.07	18.2	YES	100
21	1.060	170	180.2	11.2	7.57	21.9	YES	100
22	1.030	170	175.1	11.1	7.56	21.9	YES	100
23	1.030	170	175.1	11.2	7.42	20.7	YES	100
24	1.060	170	180.2	10.8	7.50	21.9	YES	100
25	1.110	170	188.7	10.6	7.32	21.0	YES	100
26	1.110	170	188.7	10.7	7.29	20.6	YES	100
27	1.100	170	187.0	10.9	7.26	20.1	YES	100
28	1.070	170	181.9	10.9	7.36	20.8	YES	100
29	1.040	170	176.8	11.2	7.46	21.0	YES	100
30	1.060	170	180.2	11.1	7.40	20.8	YES	100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hc

0.00

Revised October 2013