


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Dec-21

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.011	0.011	0.011	OFF	OFF	OFF	0.01
2	OFF	OFF	OFF	OFF	OFF	0.011	0.01
3	0.011	0.011	OFF	OFF	OFF	OFF	0.01
4	OFF	OFF	OFF	OFF	0.013	0.014	0.01
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	0.011	0.01
7	0.014	0.101	0.013	0.016	0.014	0.011	0.02
8	0.011	0.012	0.011	0.012	OFF	0.011	0.01
9	0.012	OFF	OFF	OFF	OFF	OFF	0.01
10	OFF	OFF	OFF	0.011	0.011	0.011	0.01
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	0.011	0.011	0.011	0.011	OFF	0.01
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	0.011	0.011	0.011	OFF	OFF	OFF	0.01
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	0.011	0.011	OFF	OFF	OFF	OFF	0.01
17	OFF	OFF	OFF	0.011	0.012	0.012	0.01
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	0.011	0.010	0.010	0.01
20	0.010	0.010	OFF	OFF	OFF	OFF	0.01
21	OFF	OFF	0.010	0.010	OFF	OFF	0.01
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	0.010	0.011	OFF	OFF	0.01
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	0.010	0.010	OFF	OFF	OFF	OFF	0.01
26	OFF	OFF	OFF	0.010	0.011	0.010	0.01
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	0.010	OFF	OFF	OFF	0.01
29	OFF	OFF	OFF	0.010	0.011	0.010	0.01
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	0.010	0.010	0.011	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No

Notes:	PRINTED NAME: David L. Nordman
	SIGNATURE:  1/6/2022
	PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Dec-21

Disinfection *Giardia*
Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.010	170	171.7	11.4	7.48	20.8	YES	100
2	0.970	170	164.9	11.4	7.26	19.2	YES	100
3	0.930	170	158.1	10.8	7.23	19.7	YES	100
4	0.910	170	154.7	10.7	7.32	20.4	YES	100
5	0.890	170	151.3	10.5	7.36	20.9	YES	100
6	0.920	170	156.4	10.3	7.39	21.5	YES	100
7	0.960	170	163.2	10.1	7.40	21.9	YES	100
8	0.860	170	146.2	10.5	7.21	19.8	YES	100
9	0.920	170	156.4	8.9	7.28	22.7	YES	100
10	0.870	170	147.9	1.0	7.27	38.5	YES	100
11	0.860	170	146.2	9.6	7.26	21.3	YES	100
12	0.800	170	136.0	9.5	7.40	22.4	YES	100
13	0.910	170	154.7	9.3	7.41	23.1	YES	100
14	0.900	170	153.0	8.9	7.46	24.1	YES	100
15	0.900	170	153.0	8.8	7.44	24.1	YES	100
16	0.850	170	144.5	7.9	7.40	25.1	YES	100
17	0.920	170	156.4	8.1	7.40	24.9	YES	100
18	0.740	170	125.8	8.2	7.44	24.6	YES	100
19	0.760	170	129.2	8.1	7.46	25.0	YES	100
20	0.720	170	122.4	8.5	7.44	24.1	YES	100
21	0.860	170	146.2	8.4	7.10	21.8	YES	100
22	0.760	170	129.2	8.4	7.24	22.7	YES	100
23	0.860	170	146.2	8.0	7.28	23.9	YES	100
24	1.070	170	181.9	7.8	7.30	25.0	YES	100
25	0.950	170	161.5	7.7	7.29	24.7	YES	100
26	1.080	170	183.6	6.6	7.56	29.8	7.27	100
27	1.010	170	171.7	6.2	7.41	28.7	YES	100
28	1.020	170	173.4	6.4	6.96	24.2	YES	100
29	1.080	170	183.6	6.6	7.25	26.6	YES	100
30	1.040	170	176.8	6.4	7.08	25.3	YES	100
31	1.080	170	183.6	6.7	6.87	23.1	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hc 0.00

Revised October 2013