

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK  
 Month/Year: Jan-22

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882

WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	0.013	0.010	0.011	OFF	0.01
2	OFF	OFF	OFF	OFF	OFF	0.010	0.01
3	OFF	OFF	OFF	OFF	0.010	0.010	0.01
4	0.010	0.010	OFF	OFF	OFF	OFF	0.01
5	OFF	OFF	OFF	0.010	0.011	0.011	0.01
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	0.010	0.010	0.01
8	0.010	0.010	0.010	OFF	OFF	OFF	0.01
9	OFF	OFF	OFF	0.010	0.011	OFF	0.01
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	0.013	0.010	0.011	0.010	0.01
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	0.010	0.010	0.011	0.010	0.01
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	0.030	0.011	0.010	0.010	OFF	OFF	0.03
16	OFF	OFF	OFF	0.010	OFF	OFF	0.01
17	OFF	OFF	OFF	OFF	0.010	0.010	0.01
18	0.010	0.010	OFF	OFF	OFF	OFF	0.01
19	OFF	OFF	OFF	OFF	0.010	OFF	0.01
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	0.010	0.010	OFF	OFF	OFF	0.01
22	OFF	OFF	OFF	0.010	0.010	0.010	0.01
23	OFF	OFF	OFF	OFF	OFF	0.010	0.01
24	0.010	OFF	OFF	OFF	OFF	OFF	0.01
25	0.010	0.010	OFF	OFF	OFF	OFF	0.01
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	0.010	0.011	OFF	0.01
30	OFF	0.012	0.010	0.010	OFF	OFF	0.01
31	OFF	OFF	OFF	0.010	0.010	OFF	

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>

Yes  No

All daily turbidity readings ≤ 5 NTU?

Yes  No

CT's met everyday? (see back)

Yes  No

All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?

Yes  No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

2/8/20

PHONE #: ( 503 ) 842- 6462

CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

Disinfection *Giardia* Log

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jan-22

Inactiv: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.040	170	176.8	6.6	7.11	25.2	YES	100
2	0.920	170	156.4	7.0	7.12	24.3	YES	100
3	0.860	170	146.2	7.1	7.12	24.0	YES	100
4	1.030	170	175.1	7.1	7.15	24.7	YES	100
5	0.960	170	163.2	7.2	7.20	24.8	YES	100
6	0.970	170	164.9	7.5	6.95	22.3	YES	100
7	1.000	170	170.0	7.6	7.14	23.7	YES	100
8	0.870	170	147.9	7.5	7.18	23.9	YES	100
9	0.570	170	96.9	8.0	7.06	21.4	YES	100
10	0.720	170	122.4	8.2	7.27	23.1	YES	100
11	0.850	170	144.5	8.5	7.06	21.4	YES	100
12	0.820	170	139.4	8.9	6.91	19.7	YES	100
13	0.880	170	149.6	9.1	6.92	19.6	YES	100
14	0.900	170	153.0	8.9	7.01	20.6	YES	100
15	1.000	170	170.0	8.7	7.14	22.1	YES	100
16	0.400	170	68.0	9.4	6.92	18.3	YES	100
17	0.610	170	103.7	9.2	7.01	19.5	YES	100
18	0.780	170	132.6	9.4	6.98	19.4	YES	100
19	0.750	170	127.5	9.7	6.99	19.1	YES	100
20	0.850	170	144.5	9.7	7.36	21.9	YES	100
21	0.830	170	141.1	9.5	7.38	22.3	YES	100
22	0.790	170	134.3	9.5	7.59	23.9	YES	100
23	0.890	170	151.3	9.3	7.63	24.9	YES	100
24	0.970	170	164.9	8.9	7.56	25.2	YES	100
25	0.940	170	159.8	9.6	7.47	23.2	YES	100
26	0.960	170	163.2	9.5	7.73	25.7	YES	100
27	0.930	170	158.1	9.5	7.73	25.6	YES	100
28	0.890	170	151.3	9.4	7.82	26.5	YES	100
29	0.870	170	147.9	8.8	7.74	26.7	YES	100
30	1.160	170	197.2	10.0	7.66	24.8	YES	100
31	1.110	170	188.7	9.4	7.72	26.2	YES	100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013