

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **TILLAMOOK**
 Month/Year: **Mar-22**

System Name: **OCEANSIDE WD - CAPE MEARES ID#: 41 00882** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	0.010	0.011	OFF	0.01
4	0.010	0.010	0.010	0.010	0.010	0.010	0.01
5	0.010	0.011	OFF	OFF	OFF	OFF	0.01
6	0.010	0.010	OFF	OFF	OFF	OFF	0.01
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	0.010	0.010	0.010	0.01
11	0.011	0.011	0.010	0.010	OFF	0.010	0.01
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	0.010	0.011	0.010	0.01
15	0.010	0.010	OFF	OFF	OFF	OFF	0.01
16	OFF	OFF	OFF	0.010	0.010	OFF	0.01
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	0.018	OFF	OFF	OFF	OFF	0.02
19	OFF	OFF	OFF	0.010	0.010	0.010	0.01
20	OFF	OFF	OFF	OFF	OFF	0.011	0.01
21	0.010	OFF	OFF	OFF	OFF	OFF	0.01
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	0.010	0.011	0.01
24	OFF	OFF	OFF	0.010	OFF	OFF	0.01
25	OFF	OFF	0.010	0.010	0.010	0.011	0.01
26	OFF	0.010	0.010	0.010	OFF	0.010	0.01
27	OFF	OFF	OFF	OFF	OFF	0.010	0.01
28	0.010	OFF	OFF	OFF	OFF	OFF	0.01
29	OFF	OFF	OFF	0.010	OFF	OFF	0.01
30	OFF	OFF	OFF	0.010	OFF	OFF	0.01
31	OFF	OFF	0.011	0.011	0.011	OFF	.011

Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings \leq 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes / No	Yes / No	Yes / No

Notes:

PRINTED NAME: **David L. Nordman**

SIGNATURE:  **4-3-2022**

PHONE #: **(503) 842- 6462** CERT #: **T08918**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Mar-22

Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.890	170	151.3	9.1	7.41	23.3	YES	100
2	0.850	170	144.5	9.3	7.76	26.0	YES	100
3	0.830	170	141.1	9.3	7.78	26.1	YES	100
4	1.000	170	170.0	9.1	7.61	25.4	YES	100
5	0.780	170	132.6	9.2	7.64	24.8	YES	100
6	0.890	170	151.3	9.2	7.67	25.4	YES	100
7	0.950	170	161.5	9.3	7.89	27.5	YES	100
8	0.890	170	151.3	9.8	7.84	26.0	YES	100
9	0.900	170	153.0	9.4	7.74	25.8	YES	100
10	0.840	170	142.8	9.8	7.74	24.9	YES	100
11	1.010	170	171.7	9.6	7.49	23.5	YES	100
12	1.010	170	171.7	9.1	7.68	26.0	YES	100
13	0.960	170	163.2	9.1	7.56	24.8	YES	100
14	0.860	170	146.2	9.4	7.59	24.3	YES	100
15	0.890	170	151.3	9.5	7.51	23.5	YES	100
16	0.880	170	149.6	9.3	7.57	24.3	YES	100
17	0.930	170	158.1	8.9	7.70	26.3	YES	100
18	0.830	170	141.1	9.8	7.68	24.3	YES	100
19	0.790	170	134.3	9.4	7.47	23.1	YES	100
20	0.880	170	149.6	9.2	7.55	24.3	YES	100
21	0.880	170	149.6	9.4	7.62	24.6	YES	100
22	0.840	170	142.8	11.1	7.39	20.2	YES	100
23	0.760	170	129.2	9.9	7.46	22.2	YES	100
24	0.970	170	164.9	9.8	7.38	22.2	YES	100
25	0.950	170	161.5	10.0	7.51	22.9	YES	100
26	1.030	170	175.1	10.8	7.53	22.1	YES	100
27	0.970	170	164.9	10.4	7.57	22.9	YES	100
28	0.940	170	159.8	10.4	7.55	22.6	YES	100
29	1.010	170	171.7	10.4	7.53	22.6	YES	100
30	0.940	170	159.8	10.7	7.56	22.3	YES	100
31	0.950	170	161.5	10.7	7.62	22.8	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h

0.00

Revised October 2013