

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **TILLAMOOK**
 Month/Year: **Apr-22**

System Name: **OCEANSIDE WD - CAPE MEARES ID#: 41 00882** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	
2	0.011	0.011	OFF	OFF	OFF	OFF	0.01
3	0.011	0.010	OFF	OFF	OFF	OFF	0.01
4	OFF	OFF	0.011	0.011	0.011	0.010	0.01
5	OFF	OFF	0.011	OFF	OFF	0.010	0.01
6	0.010	OFF	OFF	OFF	OFF	OFF	0.01
7	OFF	0.011	OFF	OFF	OFF	OFF	0.01
8	0.011	0.010	OFF	OFF	OFF	OFF	0.01
9	OFF	OFF	0.011	0.011	OFF	OFF	0.01
10	OFF	OFF	OFF	OFF	0.011	OFF	0.01
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	0.011	OFF	0.011	OFF	OFF	0.01
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	0.011	0.011	0.01
15	0.011	OFF	OFF	OFF	OFF	OFF	0.01
16	OFF	0.011	OFF	OFF	OFF	OFF	0.01
17	OFF	OFF	OFF	OFF	OFF	0.011	0.01
18	0.011	OFF	OFF	OFF	OFF	OFF	0.01
19	OFF	OFF	0.011	0.011	0.011	OFF	0.01
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	0.011	0.011	OFF	OFF	OFF	OFF	0.01
22	OFF	OFF	0.011	0.011	0.011	OFF	0.01
23	OFF	OFF	OFF	OFF	OFF	0.010	0.01
24	0.011	OFF	OFF	OFF	OFF	0.011	0.01
25	0.011	OFF	OFF	OFF	OFF	OFF	0.01
26	OFF	OFF	0.011	0.011	0.011	OFF	0.01
27	OFF	OFF	OFF	OFF	OFF	0.011	0.01
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	0.008	0.008	0.01
30	0.008	OFF	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)


95% of daily turbidity readings \leq 1 NTU? ² Yes / No
 All daily turbidity readings \leq 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

5/2/2022

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

Disinfection *Giardia* Log

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Apr-22

Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.980	170	166.6	10.7	7.61	22.8	YES	100
2	0.980	170	166.6	10.8	7.74	23.7	YES	100
3	0.940	170	159.8	10.8	7.78	23.9	YES	100
4	0.950	170	161.5	10.6	7.75	24.0	YES	100
5	0.890	170	151.3	10.8	7.74	23.4	YES	100
6	0.780	170	132.6	10.5	7.83	24.4	YES	100
7	0.920	170	156.4	11.8	7.57	20.7	YES	100
8	0.920	170	156.4	10.9	7.64	22.5	YES	100
9	0.920	170	156.4	11.0	7.71	23.0	YES	100
10	0.900	170	153.0	10.7	7.75	23.7	YES	100
11	0.970	170	164.9	9.7	7.70	25.1	YES	100
12	0.900	170	153.0	9.9	7.59	23.6	YES	100
13	0.890	170	151.3	9.3	7.58	24.5	YES	100
14	1.050	170	178.5	9.0	7.72	26.7	YES	100
15	0.830	170	141.1	9.1	7.53	24.2	YES	100
16	0.890	170	151.3	9.3	7.60	24.6	YES	100
17	0.870	170	147.9	9.2	7.69	25.6	YES	100
18	0.490	170	83.3	9.2	7.50	22.9	YES	100
19	1.010	170	171.7	9.0	7.62	25.7	YES	100
20	1.340	170	227.8	9.1	7.53	25.6	YES	100
21	0.800	170	136.0	9.4	7.63	24.5	YES	100
22	0.870	170	147.9	10.1	7.28	20.8	YES	100
23	0.950	170	161.5	9.5	7.38	22.6	YES	100
24	0.870	170	147.9	10.1	7.37	21.5	YES	100
25	0.840	170	142.8	10.7	7.20	19.4	YES	100
26	0.800	170	136.0	10.6	7.39	20.8	YES	100
27	0.890	170	151.3	10.9	7.35	20.3	YES	100
28	0.870	170	147.9	10.4	7.58	22.7	YES	100
29	1.000	170	170.0	10.9	7.43	21.1	YES	100
30	0.990	170	168.3	11.3	7.47	20.9	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h

0.00

Revised October 2013