


OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK  
 Month/Year: Jun-22

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.008	0.008	OFF	OFF	OFF	OFF	0.01
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	0.008	OFF	OFF	0.01
4	OFF	OFF	OFF	OFF	0.008	0.008	0.01
5	0.008	0.008	0.008	0.008	0.008	0.008	0.01
6	OFF	OFF	OFF	0.008	OFF	0.008	0.01
7	0.008	0.008	0.008	OFF	0.008	0.008	0.01
8	0.008	0.008	0.008	OFF	OFF	OFF	0.01
9	OFF	OFF	OFF	0.008	OFF	0.008	0.01
10	OFF	OFF	OFF	OFF	0.010	OFF	0.01
11	0.058	OFF	OFF	0.010	0.010	OFF	0.01
12	OFF	OFF	0.100	0.010	OFF	0.010	0.10
13	OFF	OFF	OFF	OFF	OFF	0.010	0.01
14	0.010	OFF	OFF	OFF	OFF	0.010	0.01
15	0.010	OFF	OFF	OFF	OFF	OFF	0.01
16	0.010	0.010	OFF	OFF	OFF	OFF	0.01
17	OFF	0.011	OFF	0.010	OFF	OFF	0.01
18	OFF	OFF	OFF	0.010	0.010	0.010	0.01
19	OFF	OFF	OFF	OFF	OFF	0.010	0.01
20	0.010	OFF	OFF	OFF	OFF	0.010	0.01
21	0.011	0.010	OFF	OFF	OFF	0.012	0.01
22	OFF	0.011	0.011	OFF	0.010	OFF	0.01
23	OFF	OFF	OFF	OFF	0.010	OFF	0.01
24	OFF	OFF	OFF	OFF	0.010	0.011	0.01
25	0.011	0.010	OFF	OFF	OFF	OFF	0.01
26	0.011	0.011	OFF	OFF	OFF	OFF	0.01
27	0.010	OFF	0.010	OFF	0.010	0.010	0.01
28	OFF	0.010	0.010	OFF	OFF	0.010	0.01
29	0.010	OFF	OFF	OFF	OFF	0.010	0.01
30	OFF	0.010	OFF	OFF	OFF	0.010	0.01

95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings $\leq$ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No All Cl2 residual at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	7/5/2022
	PHONE #: ( 503 ) 842- 6462	CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

WTP- : **A**  
 Disinfection *Giardia* Log Inactiv: **0.5**

System Name: **Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jun-22**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.830	170	141.1	12.7	7.30	17.4	YES	100
2	0.830	170	141.1	12.9	7.37	17.6	YES	100
3	0.820	170	139.4	13.3	7.45	17.7	YES	100
4	0.740	170	125.8	13.6	7.50	17.5	YES	100
5	0.720	170	122.4	13.5	7.53	17.7	YES	100
6	0.640	170	108.8	13.5	7.51	17.5	YES	100
7	0.650	170	110.5	13.9	7.62	17.7	YES	100
8	0.730	170	124.1	13.2	7.40	17.3	YES	100
9	0.680	170	115.6	12.9	7.17	16.1	YES	100
10	0.590	170	100.3	13.6	7.25	15.7	YES	100
11	0.510	170	86.7	13.6	6.99	14.1	YES	100
12	0.350	170	59.5	13.4	7.30	15.7	YES	100
13	0.840	170	142.8	12.2	7.30	18.2	YES	100
14	0.510	170	86.7	13.5	7.30	15.9	YES	100
15	0.570	170	96.9	12.0	7.24	17.6	YES	100
16	0.490	170	83.3	13.3	7.27	15.9	YES	100
17	0.390	170	66.3	13.2	7.26	15.8	YES	100
18	0.550	170	93.5	13.4	7.24	15.7	YES	100
19	0.600	170	102.0	13.5	7.26	15.8	YES	100
20	0.630	170	107.1	13.9	7.28	15.6	YES	100
21	0.590	170	100.3	14.1	7.25	15.1	YES	100
22	0.710	170	120.7	14.4	7.25	15.0	YES	100
23	0.820	170	139.4	14.3	7.28	15.5	YES	100
24	0.950	170	161.5	14.7	7.31	15.5	YES	100
25	0.850	170	144.5	15.0	7.40	15.5	YES	100
26	0.800	170	136.0	15.6	7.30	14.3	YES	100
27	0.880	170	149.6	15.3	7.43	15.4	YES	100
28	0.920	170	156.4	14.9	7.54	16.6	YES	100
29	0.880	170	149.6	14.9	7.58	16.8	YES	100
30	0.890	170	151.3	15.4	7.56	16.1	YES	100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013