

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **TILLAMOOK**
 Month/Year: **Jul-22**

System Name: **OCEANSIDE WD - CAPE MEARES ID#: 41 00882** WTP: TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.010	0.010	OFF	OFF	0.010	0.010	0.01
2	0.010	0.010	0.010	0.010	OFF	OFF	0.01
3	0.010	0.010	0.010	0.010	0.010	OFF	0.01
4	0.010	0.011	OFF	OFF	OFF	OFF	0.01
5	OFF	OFF	OFF	0.010	0.010	OFF	0.01
6	0.010	0.010	0.011	OFF	0.010	0.010	0.01
7	OFF	0.010	0.010	0.010	0.010	OFF	0.01
8	OFF	OFF	OFF	OFF	0.010	0.010	0.01
9	0.010	OFF	OFF	OFF	0.011	0.010	0.01
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	0.010	0.010	0.010	0.01
13	0.010	OFF	OFF	OFF	0.010	0.012	0.01
14	OFF	OFF	0.010	0.010	0.010	0.010	0.01
15	0.010	0.010	OFF	OFF	OFF	OFF	0.01
16	OFF	OFF	0.010	OFF	OFF	OFF	0.01
17	OFF	OFF	0.010	0.010	0.010	OFF	0.01
18	0.010	0.010	0.010	OFF	OFF	OFF	0.01
19	OFF	OFF	0.010	0.010	0.010	0.010	0.01
20	OFF	OFF	OFF	OFF	OFF	0.014	0.01
21	OFF	OFF	OFF	OFF	0.010	0.010	0.01
22	0.010	OFF	OFF	OFF	OFF	0.010	0.01
23	0.010	OFF	OFF	OFF	0.010	0.011	0.01
24	OFF	0.010	OFF	OFF	OFF	0.010	0.01
25	0.010	OFF	OFF	OFF	0.010	0.010	0.01
26	0.011	OFF	OFF	OFF	OFF	OFF	0.01
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	0.011	OFF	OFF	0.01
29	OFF	OFF	OFF	OFF	OFF	0.012	0.01
30	0.011	0.011	0.011	0.011	0.011	0.011	0.01
31	0.012	0.011	OFF	0.010	0.010	0.010	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ² Yes / No
 All daily turbidity readings \leq 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

8/3/2022

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

Disinfection *Giardia* Log

Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jun-22

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.870	170	147.9	18.9	7.56	12.7	YES	100
2	0.870	170	147.9	15.1	7.52	16.2	YES	100
3	0.760	170	129.2	15.0	7.49	15.9	YES	100
4	0.670	170	113.9	15.8	7.48	14.9	YES	100
5	0.890	170	151.3	15.1	7.58	16.6	YES	100
6	0.610	170	103.7	15.5	7.52	15.3	YES	100
7	0.700	170	119.0	15.1	7.51	15.8	YES	100
8	0.680	170	115.6	15.4	7.52	15.5	YES	100
9	0.580	170	98.6	15.3	7.51	15.4	YES	100
10	0.710	170	120.7	15.8	7.50	15.0	YES	100
11	0.730	170	124.1	15.9	7.55	15.3	YES	100
12	0.710	170	120.7	16.0	7.56	15.2	YES	100
13	0.860	170	146.2	16.4	7.52	14.8	YES	100
14	0.910	170	154.7	16.4	7.55	15.1	YES	100
15	0.950	170	161.5	15.9	7.51	15.4	YES	100
16	0.890	170	151.3	16.1	7.53	15.2	YES	100
17	0.820	170	139.4	16.1	7.52	15.0	YES	100
18	0.890	170	151.3	16.0	7.52	15.3	YES	100
19	0.880	170	149.6	16.1	7.52	15.1	YES	100
20	0.820	170	139.4	15.9	7.51	15.2	YES	100
21	0.650	170	110.5	16.0	7.23	13.3	YES	100
22	0.660	170	112.2	16.2	7.13	12.7	YES	100
23	0.730	170	124.1	16.0	7.18	13.2	YES	100
24	0.600	170	102.0	15.7	7.22	13.5	YES	100
25	0.860	170	146.2	15.9	7.23	13.7	YES	100
26	0.840	170	142.8	16.2	7.22	13.4	YES	100
27	0.830	170	141.1	16.4	7.29	13.5	YES	100
28	0.730	170	124.1	16.5	7.30	13.4	YES	100
29	0.740	170	125.8	16.5	7.30	13.4	YES	100
30	0.720	170	122.4	16.0	7.26	13.6	YES	100
31	0.890	170	151.3	16.4	7.36	14.0	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013