

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **TILLAMOOK**
 Month/Year: **Aug-22**

System Name: **OCEANSIDE WD - CAPE MEARES ID#: 41 00882** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.010	OFF	OFF	OFF	OFF	OFF	0.01
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	0.011	0.011	0.011	0.011	0.01
4	0.011	0.011	0.011	0.010	OFF	0.011	0.01
5	0.011	OFF	OFF	OFF	0.011	0.011	0.01
6	0.011	OFF	OFF	OFF	0.011	OFF	0.01
7	0.011	0.011	0.011	OFF	OFF	OFF	0.01
8	OFF	OFF	OFF	0.011	0.011	0.011	0.01
9	0.011	0.011	0.011	0.011	OFF	0.011	0.01
10	0.012	OFF	OFF	OFF	OFF	0.012	0.01
11	0.011	OFF	OFF	OFF	OFF	0.011	0.01
12	0.011	OFF	OFF	OFF	0.012	0.011	0.01
13	0.011	OFF	OFF	OFF	0.011	0.011	0.01
14	0.011	OFF	OFF	OFF	0.011	0.012	0.01
15	0.011	OFF	OFF	OFF	0.011	0.012	0.01
16	0.012	0.010	OFF	OFF	0.012	0.011	0.01
17	0.011	OFF	OFF	OFF	0.012	0.012	0.01
18	0.012	OFF	OFF	OFF	OFF	OFF	0.01
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	0.012	0.012	0.012	0.01
22	0.012	0.011	0.012	0.012	0.012	0.012	0.01
23	0.011	0.012	0.012	0.013	0.012	0.012	0.01
24	OFF	0.012	OFF	0.012	0.012	0.012	0.01
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	0.012	0.012	OFF	OFF	OFF	0.012	0.01
27	0.012	OFF	OFF	OFF	OFF	0.012	0.01
28	0.012	OFF	OFF	OFF	0.012	0.011	0.01
29	0.011	OFF	OFF	OFF	0.012	0.012	0.01
30	0.012	OFF	OFF	OFF	OFF	0.012	0.01
31	0.012	OFF	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ² Yes / No
 All daily turbidity readings \leq 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

9/7/2022

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Aug-22

Disinfection *Giardia* Log

Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.840	170	142.8	16.3	7.40	14.2	YES	100
2	0.810	170	137.7	16.0	7.33	14.1	YES	100
3	0.770	170	130.9	16.1	7.38	14.2	YES	100
4	0.780	170	132.6	16.6	7.41	13.9	YES	100
5	0.800	170	136.0	16.6	7.45	14.1	YES	100
6	0.850	170	144.5	16.1	7.46	14.8	YES	100
7	0.770	170	130.9	16.6	7.52	14.5	YES	100
8	0.780	170	132.6	15.7	7.48	15.1	YES	100
9	0.820	170	139.4	16.2	7.50	14.8	YES	100
10	0.870	170	147.9	16.0	7.52	15.2	YES	100
11	0.800	170	136.0	11.1	7.46	20.6	YES	100
12	0.800	170	136.0	16.3	7.46	14.5	YES	100
13	0.740	170	125.8	16.2	7.44	14.4	YES	100
14	0.620	170	105.4	16.6	7.39	13.5	YES	100
15	0.890	170	151.3	16.2	7.53	15.1	YES	100
16	0.750	170	127.5	16.8	7.53	14.3	YES	100
17	0.690	170	117.3	16.5	7.57	14.7	YES	100
18	0.850	170	144.5	16.8	7.52	14.4	YES	100
19	0.630	170	107.1	16.5	7.53	14.4	YES	100
20	0.570	170	96.9	16.6	7.50	14.0	YES	100
21	0.610	170	103.7	17.4	7.47	13.2	YES	100
22	0.700	170	119.0	17.3	7.54	13.8	YES	100
23	0.740	170	125.8	17.2	7.57	14.1	YES	100
24	0.720	170	122.4	16.4	7.54	14.7	YES	100
25	0.750	170	127.5	16.7	7.52	14.3	YES	100
26	0.760	170	129.2	16.9	7.56	14.4	YES	100
27	0.730	170	124.1	16.5	7.54	14.6	YES	100
28	0.710	170	120.7	16.5	7.51	14.4	YES	100
29	0.590	170	100.3	16.4	7.50	14.2	YES	100
30	0.650	170	110.5	16.6	7.48	14.1	YES	100
31	0.750	170	127.5	16.9	7.53	14.2	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013