

**OHA - Drinking Water Services - Turbidity Monitoring Report Form
Membrane**

County:	Tillamook
Month/Year:	Oct-22

System Name: Oceanside, City of ID#: 41 00882 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.012	0.012	OFF	OFF	0.012	0.012	0.012
2	OFF	0.012	OFF	0.012	0.012	OFF	0.012
3	OFF	OFF	OFF	0.013	0.012	0.012	0.013
4	0.012	0.012	0.012	OFF	0.015	0.012	0.015
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	0.012	OFF	OFF	OFF	OFF	OFF	0.012
7	0.012	OFF	OFF	OFF	OFF	OFF	0.012
8	0.012	0.012	OFF	OFF	OFF	OFF	0.012
9	0.013	0.012	0.012	0.012	0.012	0.012	0.012
10	0.012	OFF	OFF	OFF	OFF	OFF	0.012
11	0.012	OFF	OFF	0.013	0.012	0.012	0.013
12	0.012	OFF	OFF	OFF	OFF	OFF	0.012
13	0.012	OFF	OFF	0.014	0.012	0.013	0.013
14	0.012	OFF	OFF	0.012	0.012	0.012	0.012
15	0.012	0.012	OFF	0.012	0.012	OFF	0.012
16	0.012	OFF	OFF	0.012	0.012	0.012	0.012
17	0.012	OFF	0.012	OFF	0.012	0.012	0.012
18	0.012	OFF	OFF	0.013	0.012	0.012	0.013
19	OFF	OFF	OFF	OFF	0.014	0.014	0.014
20	0.014	0.014	0.014	0.014	OFF	OFF	0.014
21	OFF	0.014	OFF	OFF	0.014	0.014	0.014
22	0.014	OFF	OFF	0.014	OFF	0.014	0.014
23	0.014	0.014	0.014	0.014	0.014	0.014	0.014
24	0.014	0.014	0.014	0.014	OFF	0.015	0.015
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	0.015	0.015	OFF	0.015
27	0.014	0.014	0.014	0.014	OFF	OFF	0.014
28	0.014	0.014	0.014	0.015	OFF	OFF	0.015
29	OFF	0.014	OFF	0.014	0.014	0.014	0.014
30	0.015	0.014	OFF	OFF	OFF	OFF	0.015
31	0.014	0.014	OFF	OFF	0.015	0.014	0.015

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes: PRINTED NAME: David L. Nordman

SIGNATURE: *David L. Nordman* DATE: 11/4/2022

PHONE #: (503) 842-6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside Water District ID#: 41 00882 Month/Year: Oct-22

Disinfection *Giardia* Log

Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.65	80	52.0	13.2	7.49	17.7	YES	300
2	0.6	80	48.0	13.4	7.45	17.1	YES	300
3	0.61	80	48.8	15.2	7.56	15.8	YES	300
4	0.67	80	53.6	15.4	7.50	15.4	YES	300
5	0.57	80	45.6	15.1	7.47	15.3	YES	300
6	0.51	80	40.8	14.7	7.45	15.5	YES	300
7	0.62	80	49.6	14.8	7.39	15.3	YES	300
8	0.59	80	47.2	14.5	7.41	15.6	YES	300
9	0.52	80	41.6	14.4	7.44	15.8	YES	300
10	0.57	80	45.6	14.2	7.54	16.7	YES	300
11	0.57	80	45.6	14.3	7.53	16.5	YES	300
12	0.63	80	50.4	14.0	7.53	17.0	YES	300
13	0.66	80	52.8	14.1	7.57	17.2	YES	300
14	0.58	80	46.4	13.9	7.55	17.1	YES	300
15	0.7	80	56.0	14.4	7.47	16.3	YES	300
16	0.63	80	50.4	13.9	7.70	18.2	YES	300
17	0.59	80	47.2	14.7	7.61	16.6	YES	300
18	0.57	80	45.6	14.2	7.65	17.4	YES	300
19	0.48	80	38.4	14.4	7.64	16.9	YES	300
20	0.55	80	44.0	15.2	7.62	16.1	YES	300
21	0.66	80	52.8	14.2	7.59	17.2	YES	300
22	0.67	80	53.6	13.5	7.59	18.0	YES	300
23	0.63	80	50.4	13.3	7.53	17.8	YES	300
24	0.67	80	53.6	13.3	7.61	18.4	YES	300
25	0.63	80	50.4	12.7	7.60	19.0	YES	300
26	0.6	80	48.0	12.7	7.62	19.1	YES	300
27	0.75	80	60.0	12.5	7.59	19.5	YES	300
28	0.74	80	59.2	12.5	7.60	19.5	YES	300
29	0.87	80	69.6	11.6	7.56	20.8	YES	300
30	0.68	80	54.4	12.4	7.66	20.0	YES	300
31	0.68	80	54.4	12.4	7.67	20.1	YES	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013