

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Nov-22

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A


Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.012	0.012	0.01
2	0.012	0.012	0.012	OFF	OFF	OFF	0.01
3	OFF	0.013	0.017	0.012	OFF	OFF	0.02
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	0.014	0.015	0.02
6	0.015	0.016	OFF	0.016	0.016	OFF	0.02
7	OFF	OFF	OFF	OFF	0.012	0.019	0.02
8	0.016	OFF	OFF	OFF	OFF	OFF	0.02
9	0.017	0.017	OFF	OFF	OFF	OFF	0.02
10	OFF	0.018	OFF	OFF	OFF	OFF	0.02
11	OFF	OFF	OFF	0.022	0.020	0.017	0.02
12	0.016	OFF	OFF	OFF	0.020	0.017	0.02
13	0.016	0.016	OFF	OFF	0.016	0.016	0.02
14	0.017	OFF	OFF	OFF	OFF	0.019	0.02
15	0.016	0.016	OFF	OFF	OFF	OFF	0.02
16	0.017	0.018	0.018	0.020	OFF	OFF	0.02
17	OFF	OFF	OFF	0.020	0.020	0.018	0.02
18	0.018	OFF	OFF	0.018	0.020	0.018	0.02
19	0.018	0.018	0.015	0.019	0.019	OFF	0.02
20	OFF	OFF	0.017	0.019	0.016	0.017	0.02
21	0.018	0.017	OFF	OFF	0.019	0.019	0.02
22	0.019	0.018	0.019	0.018	OFF	OFF	0.02
23	OFF	OFF	OFF	0.020	0.020	OFF	0.02
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	0.018	OFF	OFF	OFF	OFF	0.019	0.02
26	OFF	OFF	OFF	OFF	OFF	0.020	0.02
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	0.021	OFF	OFF	OFF	OFF	0.02
29	OFF	OFF	0.016	0.019	0.019	OFF	0.02
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE:  12/9/2022

PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Nov-22 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.820	170	139.4	11.4	7.54	20.8	YES	100
2	0.870	170	147.9	10.5	7.39	21.1	YES	100
3	1.050	170	178.5	10.4	7.26	20.7	YES	100
4	0.560	170	95.2	10.9	7.29	19.2	YES	100
5	0.610	170	103.7	10.6	7.35	20.1	YES	100
6	0.720	170	122.4	10.2	7.18	19.7	YES	100
7	0.850	170	144.5	9.6	7.32	21.8	YES	100
8	0.650	170	110.5	9.7	7.31	21.1	YES	100
9	0.700	170	119.0	9.4	7.46	22.8	YES	100
10	0.670	170	113.9	9.9	7.31	20.9	YES	100
11	0.730	170	124.1	9.7	7.31	21.3	YES	100
12	0.850	170	144.5	10.5	7.32	20.5	YES	100
13	0.800	170	136.0	9.3	7.41	22.8	YES	100
14	0.800	170	136.0	9.1	7.47	23.6	YES	100
15	0.790	170	134.3	9.6	7.45	22.6	YES	100
16	0.750	170	127.5	9.7	7.45	22.4	YES	100
17	0.930	170	158.1	9.5	7.48	23.4	YES	100
18	0.600	170	102.0	9.3	7.42	22.4	YES	100
19	0.770	170	130.9	9.2	7.51	23.7	YES	100
20	0.900	170	153.0	9.6	7.39	22.4	YES	100
21	0.890	170	151.3	9.3	7.44	23.3	YES	100
22	0.870	170	147.9	9.6	7.44	22.8	YES	100
23	0.980	170	166.6	9.6	7.51	23.6	YES	100
24	0.960	170	163.2	9.2	7.41	23.4	YES	100
25	0.890	170	151.3	9.3	7.43	23.2	YES	100
26	0.990	170	168.3	10.1	7.38	21.9	YES	100
27	0.700	170	119.0	9.5	7.35	21.8	YES	100
28	0.760	170	129.2	8.5	7.36	23.5	YES	100
29	0.780	170	132.6	8.1	7.43	24.8	YES	100
30	0.790	170	134.3	8.0	7.40	24.7	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013