

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Feb-23

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.019	0.019	OFF	OFF	OFF	0.019	0.02
2	0.018	0.018	0.018	0.018	OFF	OFF	0.02
3	OFF	OFF	OFF	0.018	0.016	0.019	0.02
4	0.019	OFF	OFF	OFF	OFF	OFF	0.02
5	OFF	OFF	OFF	OFF	0.019	0.020	0.02
6	0.019	OFF	OFF	OFF	OFF	OFF	0.02
7	0.020	0.020	OFF	OFF	OFF	OFF	0.02
8	OFF	OFF	0.020	0.020	0.020	OFF	0.02
9	OFF	OFF	OFF	OFF	OFF	0.021	0.02
10	0.023	OFF	OFF	OFF	OFF	OFF	0.02
11	0.024	0.024	0.023	OFF	OFF	OFF	0.02
12	OFF	0.024	0.023	0.021	0.019	OFF	0.02
13	OFF	OFF	OFF	0.022	0.023	0.023	0.02
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	0.023	0.024	OFF	OFF	OFF	OFF	0.02
16	OFF	OFF	OFF	0.016	0.019	0.023	0.02
17	OFF	OFF	OFF	OFF	OFF	0.023	0.02
18	0.024	0.023	OFF	OFF	OFF	0.023	0.02
19	0.023	0.023	OFF	OFF	OFF	0.022	0.02
20	0.023	OFF	OFF	OFF	OFF	0.024	0.02
21	0.024	0.024	OFF	OFF	OFF	OFF	0.02
22	OFF	0.024	0.023	OFF	OFF	OFF	0.02
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	0.023	0.022	0.023	0.02
25	0.023	0.023	0.023	OFF	OFF	OFF	0.02
26	OFF	0.023	0.019	OFF	OFF	OFF	0.02
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	0.020	0.018	0.023	0.02


Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ² Yes / No
 All daily turbidity readings \leq 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman
 SIGNATURE:  3/8/2023
 PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Feb-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.860	170	146.2	8.0	7.98	30.7	YES	100
2	0.810	170	137.7	7.6	8.01	31.7	YES	100
3	0.830	170	141.1	8.0	8.20	33.2	YES	100
4	0.790	170	134.3	8.3	7.83	28.3	YES	100
5	0.850	170	144.5	8.4	7.83	28.3	YES	100
6	0.810	170	137.7	8.6	7.76	27.1	YES	100
7	0.800	170	136.0	8.6	7.90	28.5	YES	100
8	0.750	170	127.5	8.6	7.76	26.9	YES	100
9	0.770	170	130.9	8.8	7.58	24.9	YES	100
10	0.740	170	125.8	8.8	7.49	24.1	YES	100
11	0.760	170	129.2	8.4	7.62	26.0	YES	100
12	1.060	170	180.2	8.7	7.61	26.2	YES	100
13	0.970	170	164.9	8.9	7.51	24.7	YES	100
14	0.730	170	124.1	8.9	7.43	23.4	YES	100
15	0.670	170	113.9	9.0	7.30	22.0	YES	100
16	0.970	170	164.9	8.3	7.48	25.5	YES	100
17	0.730	170	124.1	8.6	7.60	25.3	YES	100
18	0.840	170	142.8	8.5	7.81	27.9	YES	100
19	0.880	170	149.6	8.7	7.41	23.9	YES	100
20	0.870	170	147.9	8.7	7.41	23.9	YES	100
21	0.890	170	151.3	8.3	7.52	25.6	YES	100
22	0.880	170	149.6	7.8	7.49	26.2	YES	100
23	1.070	170	181.9	7.0	7.60	29.4	YES	100
24	0.970	170	164.9	6.2	7.84	33.4	YES	100
25	0.940	170	159.8	7.2	7.55	28.0	YES	100
26	0.470	170	79.9	7.0	7.60	27.4	YES	100
27	0.790	170	134.3	6.7	7.60	29.0	YES	100
28	0.500	170	85.0	6.8	7.62	28.1	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013