

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Mar-23

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP : TP - 1.0

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	3/1/2023
1	0.023	0.023	0.022	0.021	0.021	0.022	0.02
2	0.023	OFF	OFF	OFF	OFF	0.024	OFF
3	0.024	0.025	OFF	OFF	OFF	0.025	0.03
4	0.025	0.024	OFF	OFF	OFF	OFF	0.03
5	OFF	OFF	OFF	0.018	0.019	0.025	0.03
6	0.024	0.024	OFF	OFF	OFF	OFF	0.02
7	OFF	0.023	0.024	OFF	0.014	0.013	0.02
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	0.015	OFF	OFF	OFF	OFF	OFF	0.02
11	OFF	0.015	0.016	0.016	OFF	OFF	0.02
12	OFF	OFF	0.023	0.023	0.024	OFF	0.02
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	0.023	0.028	0.03
15	0.029	0.028	0.025	OFF	OFF	0.023	0.03
16	0.030	0.028	OFF	0.028	0.028	OFF	0.03
17	OFF	OFF	OFF	0.019	0.023	0.027	0.03
18	OFF	OFF	OFF	OFF	0.025	0.028	0.03
19	OFF	OFF	OFF	OFF	0.022	OFF	0.02
20	0.027	OFF	OFF	OFF	OFF	0.023	0.03
21	0.028	OFF	OFF	OFF	OFF	0.029	0.03
22	0.027	0.027	OFF	OFF	OFF	0.029	0.03
23	0.026	0.025	OFF	OFF	OFF	OFF	0.03
24	OFF	OFF	OFF	0.023	0.026	0.028	0.03
25	0.027	OFF	OFF	OFF	OFF	OFF	0.03
26	0.027	OFF	OFF	OFF	0.022	0.024	0.03
27	0.026	OFF	OFF	OFF	OFF	OFF	0.03
28	0.025	0.028	OFF	OFF	OFF	OFF	0.03
29	OFF	0.027	OFF	OFF	OFF	0.030	0.03
30	0.028	0.026	OFF	OFF	OFF	0.024	0.03
31	0.028	0.028	OFF	OFF	OFF	0.026	0.03

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point \geq 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No				

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: *[Signature]* 4-2-2023

PHONE #: (503) 842- 6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Mar-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.750	170	127.5	6.7	7.54	28.3	YES	100
2	0.740	170	125.8	6.4	7.63	29.7	YES	100
3	0.700	170	119.0	6.5	7.67	29.8	YES	100
4	0.810	170	137.7	6.0	7.69	31.5	YES	100
5	0.740	170	125.8	6.5	7.62	29.4	YES	100
6	0.760	170	129.2	6.4	7.57	29.2	YES	100
7	0.810	170	137.7	8.5	7.51	24.9	YES	100
8	0.950	170	161.5	6.2	7.39	28.3	YES	100
9	0.840	170	142.8	6.5	7.64	30.0	YES	100
10	0.890	170	151.3	5.8	7.36	28.6	YES	100
11	0.720	170	122.4	7.8	7.11	22.4	YES	100
12	0.790	170	134.3	7.0	7.20	24.6	YES	100
13	0.840	170	142.8	7.4	7.29	24.9	YES	100
14	0.900	170	153.0	7.9	7.28	24.2	YES	100
15	0.920	170	156.4	7.7	7.38	25.4	YES	100
16	0.850	170	144.5	8.2	7.57	26.1	YES	100
17	0.890	170	151.3	8.4	7.34	23.9	YES	100
18	0.880	170	149.6	9.1	7.49	24.0	YES	100
19	0.850	170	144.5	8.8	7.40	23.6	YES	100
20	0.910	170	154.7	9.2	7.42	23.3	YES	100
21	0.930	170	158.1	9.9	7.38	22.0	YES	100
22	0.930	170	158.1	9.7	7.48	23.1	YES	100
23	0.990	170	168.3	8.9	7.64	26.0	YES	100
24	0.940	170	159.8	8.5	7.71	27.2	YES	100
25	0.990	170	168.3	8.3	7.62	26.8	YES	100
26	0.740	170	125.8	8.4	7.56	25.4	YES	100
27	0.890	170	151.3	8.4	7.47	25.0	YES	100
28	0.890	170	151.3	8.1	7.56	26.3	YES	100
29	0.780	170	132.6	9.7	7.43	22.3	YES	100
30	0.810	170	137.7	8.3	7.30	23.5	YES	100
31	0.870	170	147.9	8.4	7.29	23.4	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h

0.00

Revised October 2013