

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **TILLAMOOK**
 Month/Year: **Apr-23**
 WTP : TP - **1.0**

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	4/1/2023
1	0.028	0.027	0.016	0.029	OFF	OFF	0.03
2	OFF	OFF	OFF	0.028	0.027	0.029	0.03
3	0.027	OFF	OFF	OFF	0.021	OFF	0.03
4	OFF	OFF	OFF	OFF	OFF	0.027	0.03
5	0.028	OFF	OFF	OFF	OFF	OFF	0.03
6	0.024	0.021	OFF	OFF	OFF	OFF	0.02
7	OFF	OFF	0.024	0.028	0.025	0.028	0.03
8	0.028	0.028	OFF	OFF	OFF	OFF	0.03
9	0.026	0.026	OFF	OFF	OFF	OFF	0.03
10	OFF	0.028	OFF	OFF	OFF	OFF	0.03
11	OFF	OFF	OFF	0.024	OFF	0.027	0.03
12	0.028	OFF	OFF	OFF	OFF	0.028	0.03
13	0.026	OFF	OFF	OFF	OFF	0.033	0.03
14	0.027	0.026	OFF	OFF	OFF	OFF	0.03
15	0.028	0.027	OFF	OFF	OFF	0.032	0.03
16	0.029	0.029	OFF	OFF	OFF	0.029	0.03
17	0.025	OFF	OFF	OFF	OFF	OFF	0.03
18	0.027	0.026	OFF	OFF	OFF	OFF	0.03
19	0.030	0.029	OFF	OFF	OFF	OFF	0.03
20	0.033	0.029	0.025	OFF	OFF	OFF	0.03
21	OFF	OFF	0.028	0.024	OFF	OFF	0.03
22	OFF	OFF	OFF	0.015	0.019	OFF	0.02
23	OFF	OFF	OFF	OFF	0.017	OFF	0.02
24	0.019	OFF	OFF	OFF	OFF	OFF	0.02
25	0.020	OFF	OFF	OFF	OFF	0.024	0.02
26	0.020	OFF	OFF	OFF	OFF	OFF	0.02
27	0.020	0.019	OFF	0.014	OFF	0.023	0.02
28	0.022	OFF	OFF	OFF	OFF	OFF	0.02
29	OFF	OFF	0.026	0.022	OFF	OFF	0.03
30	OFF	0.021	OFF	OFF	OFF	0.021	0.02

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ² Yes / No
 All daily turbidity readings \leq 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

5/9/2023

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

Disinfection *Giardia* Log

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Apr-23

Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.820	170	139.4	8.7	7.28	22.7	YES	100
2	0.840	170	142.8	8.2	7.48	25.3	YES	100
3	0.810	170	137.7	8.2	7.33	23.9	YES	100
4	0.820	170	139.4	7.8	7.60	27.0	YES	100
5	0.770	170	130.9	8.2	7.46	24.9	YES	100
6	0.720	170	122.4	8.3	7.44	24.4	YES	100
7	0.720	170	122.4	8.8	7.36	22.9	YES	100
8	0.720	170	122.4	8.5	7.44	24.1	YES	100
9	0.750	170	127.5	9.2	7.26	21.6	YES	100
10	0.640	170	108.8	9.0	7.39	22.7	YES	100
11	0.660	170	112.2	9.2	7.37	22.3	YES	100
12	0.630	170	107.1	8.8	7.60	24.7	YES	100
13	0.680	170	115.6	9.1	7.38	22.6	YES	100
14	0.670	170	113.9	9.9	7.38	21.4	YES	100
15	0.690	170	117.3	9.5	7.53	23.2	YES	100
16	0.700	170	119.0	9.8	7.54	22.8	YES	100
17	0.800	170	136.0	9.4	7.47	23.1	YES	100
18	0.850	170	144.5	9.0	7.50	24.1	YES	100
19	0.900	170	153.0	9.4	7.49	23.6	YES	100
20	0.810	170	137.7	8.9	7.51	24.3	YES	100
21	0.790	170	134.3	9.4	7.47	23.1	YES	100
22	0.930	170	158.1	9.8	7.51	23.2	YES	100
23	0.960	170	163.2	9.8	7.39	22.3	YES	100
24	0.980	170	166.6	10.0	7.34	21.7	YES	100
25	0.950	170	161.5	10.7	7.58	22.4	YES	100
26	0.960	170	163.2	11.0	7.69	22.9	YES	100
27	0.990	170	168.3	10.7	7.56	22.4	YES	100
28	0.970	170	164.9	11.7	7.53	20.7	YES	100
29	1.050	170	178.5	11.5	7.41	20.3	YES	100
30	1.010	170	171.7	12.4	7.54	19.9	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013