

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Jun-23

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.044	OFF	OFF	OFF	OFF	OFF	0.04
2	OFF	OFF	OFF	OFF	0.034	0.034	0.03
3	0.050	OFF	OFF	OFF	OFF	0.038	0.05
4	0.050	OFF	OFF	OFF	0.040	0.041	0.05
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	0.070	0.060	0.070	0.044	0.07
7	0.058	OFF	OFF	OFF	0.131	0.136	0.14
8	0.150	OFF	OFF	OFF	OFF	0.084	0.15
9	0.116	OFF	OFF	OFF	0.100	0.084	0.12
10	0.098	OFF	OFF	OFF	0.136	0.103	0.14
11	0.094	OFF	OFF	OFF	0.116	0.119	0.12
12	0.138	OFF	OFF	OFF	0.104	0.138	0.14
13	0.115	OFF	OFF	OFF	OFF	0.115	0.12
14	0.091	OFF	OFF	OFF	0.060	0.054	0.09
15	0.051	OFF	OFF	OFF	0.016	0.016	0.05
16	0.017	OFF	OFF	OFF	OFF	0.031	0.03
17	0.052	OFF	OFF	OFF	0.044	0.082	0.08
18	0.068	OFF	OFF	OFF	OFF	OFF	0.07
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	0.047	0.051	OFF	OFF	OFF	0.049	0.05
22	0.049	OFF	OFF	OFF	0.035	0.069	0.07
23	0.043	OFF	OFF	OFF	OFF	0.065	0.07
24	0.066	OFF	OFF	OFF	0.093	0.082	0.09
25	0.062	OFF	OFF	OFF	0.080	OFF	0.08
26	OFF	OFF	OFF	0.088	0.093	0.085	0.09
27	0.075	OFF	OFF	OFF	0.056	0.064	0.08
28	0.060	OFF	OFF	OFF	OFF	0.050	0.06
29	0.041	OFF	OFF	OFF	OFF	0.052	0.05
30	0.045	OFF	OFF	OFF	OFF	0.017	0.05

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU?² Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

3/8/2023

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jun-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.720	170	122.4	14.1	7.48	16.7	YES	100
2	0.750	170	127.5	13.9	7.44	16.8	YES	100
3	0.740	170	125.8	13.9	7.48	17.0	YES	100
4	0.730	170	124.1	13.9	7.53	17.3	YES	100
5	0.720	170	122.4	14.2	7.73	18.2	YES	100
6	0.760	170	129.2	14.9	7.63	16.8	YES	100
7	0.750	170	127.5	14.3	7.66	17.7	YES	100
8	0.810	170	137.7	14.2	7.59	17.5	YES	100
9	0.750	170	127.5	14.3	7.74	18.2	YES	100
10	0.760	170	129.2	15.1	7.68	16.9	YES	100
11	0.720	170	122.4	14.7	7.63	17.0	YES	100
12	0.600	170	102.0	14.3	7.73	17.9	YES	100
13	0.660	170	112.2	14.8	7.62	16.7	YES	100
14	0.690	170	117.3	14.7	7.59	16.7	YES	100
15	0.700	170	119.0	14.2	7.59	17.3	YES	100
16	0.630	170	107.1	14.2	7.69	17.8	YES	100
17	0.630	170	107.1	14.3	7.84	18.7	YES	100
18	0.670	170	113.9	14.4	7.72	17.8	YES	100
19	0.630	170	107.1	13.9	7.67	18.0	YES	100
20	0.610	170	103.7	14.0	7.70	18.0	YES	100
21	0.620	170	105.4	14.3	7.73	17.9	YES	100
22	0.550	170	93.5	14.6	7.72	17.4	YES	100
23	0.590	170	100.3	14.5	7.46	15.9	YES	100
24	0.620	170	105.4	14.7	7.46	15.8	YES	100
25	0.580	170	98.6	14.4	7.58	16.8	YES	100
26	0.560	170	95.2	14.8	7.59	16.3	YES	100
27	0.560	170	95.2	14.5	7.59	16.7	YES	100
28	0.580	170	98.6	15.2	7.59	15.9	YES	100
29	0.570	170	96.9	15.0	7.58	16.1	YES	100
30	0.560	170	95.2	16.2	7.54	14.6	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013