


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **TILLAMOOK**
 Month/Year: **May-23** 
 WTP : TP - **A**

System Name: **OCEANSIDE WD - CAPE MEARES ID#: 41 00882**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.016	OFF	OFF	OFF	0.016	0.016	0.02
2	0.016	OFF	OFF	OFF	0.016	0.016	0.02
3	0.016	OFF	OFF	OFF	0.016	0.016	0.02
4	0.016	OFF	OFF	OFF	OFF	OFF	0.02
5	0.016	OFF	OFF	OFF	OFF	OFF	0.02
6	0.017	OFF	OFF	OFF	0.016	OFF	0.02
7	OFF	OFF	OFF	OFF	0.016	0.016	0.02
8	0.016	OFF	OFF	OFF	OFF	OFF	0.02
9	OFF	OFF	OFF	0.018	0.018	0.017	0.02
10	0.017	0.017	0.017	0.017	OFF	OFF	0.02
11	OFF	OFF	OFF	0.017	0.017	0.016	0.02
12	0.016	OFF	OFF	OFF	0.017	0.016	0.02
13	0.017	OFF	OFF	0.017	0.016	0.016	0.02
14	0.017	OFF	OFF	OFF	0.017	0.017	0.02
15	0.017	OFF	OFF	OFF	0.016	0.017	0.02
16	OFF	OFF	OFF	OFF	0.017	0.017	0.02
17	0.017	OFF	OFF	OFF	0.017	0.017	0.02
18	0.017	OFF	OFF	OFF	OFF	OFF	0.02
19	OFF	OFF	OFF	OFF	0.018	0.018	0.02
20	0.018	OFF	OFF	OFF	0.017	0.017	0.02
21	0.017	OFF	OFF	OFF	0.018	0.017	0.02
22	0.017	OFF	OFF	OFF	OFF	OFF	0.02
23	OFF	OFF	0.017	0.018	0.017	0.017	0.02
24	0.017	OFF	OFF	OFF	OFF	0.017	0.02
25	0.018	OFF	OFF	OFF	OFF	0.014	0.02
26	0.018	OFF	OFF	OFF	OFF	0.015	0.02
27	0.015	OFF	OFF	OFF	OFF	0.014	0.02
28	0.014	OFF	OFF	OFF	OFF	0.014	0.01
29	0.014	OFF	OFF	OFF	OFF	0.014	0.01
30	0.014	0.014	OFF	OFF	OFF	0.014	0.01
31	0.014	OFF	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ² **Yes / No**
 All daily turbidity readings \leq 5 NTU? **Yes / No**

CT's met everyday? (see back) **Yes / No**

All Cl₂ residual at entry point \geq 0.2 mg/l? **Yes / No**

Notes:

PRINTED NAME: **David L. Nordman**

SIGNATURE: 

9/7/2023

PHONE #: **(503) 842- 6462**

CERT #: **T08918**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia* Log Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: May-23

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.800	170	136.0	16.3	7.42	14.3	YES	100
2	0.670	170	113.9	16.4	7.45	14.1	YES	100
3	0.740	170	125.8	16.8	7.45	13.9	YES	100
4	0.720	170	122.4	17.4	7.44	13.2	YES	100
5	0.560	170	95.2	16.8	7.34	13.0	YES	100
6	0.620	170	105.4	17.9	7.52	13.0	YES	100
7	0.710	170	120.7	18.0	7.53	13.1	YES	100
8	0.530	170	90.1	17.8	7.39	12.4	YES	100
9	0.840	170	142.8	17.4	7.44	13.4	YES	100
10	0.380	170	64.6	17.0	7.63	14.0	YES	100
11	0.320	170	54.4	16.8	7.37	12.8	YES	100
12	0.800	170	136.0	18.8	7.41	12.0	YES	100
13	0.410	170	69.7	17.1	7.41	12.9	YES	100
14	0.470	170	79.9	17.7	7.45	12.6	YES	100
15	0.500	170	85.0	18.4	7.39	11.8	YES	100
16	0.370	170	62.9	17.6	7.38	12.3	YES	100
17	0.500	170	85.0	17.1	7.52	13.6	YES	100
18	0.710	170	120.7	18.9	7.40	11.8	YES	100
19	0.750	170	127.5	17.6	7.44	13.1	YES	100
20	0.690	170	117.3	16.5	7.49	14.3	YES	100
21	0.660	170	112.2	16.8	7.51	14.0	YES	100
22	0.880	170	149.6	18.2	7.40	12.6	YES	100
23	0.650	170	110.5	16.4	7.61	14.9	YES	100
24	0.760	170	129.2	16.8	7.60	14.7	YES	100
25	0.700	170	119.0	16.8	7.51	14.1	YES	100
26	0.810	170	137.7	17.1	7.57	14.3	YES	100
27	0.700	170	119.0	16.9	7.70	15.0	YES	100
28	0.720	170	122.4	17.4	7.70	14.6	YES	100
29	0.740	170	125.8	17.4	7.67	14.4	YES	100
30	0.690	170	117.3	17.7	7.73	14.4	YES	100
31	0.750	170	127.5	17.8	7.75	14.5	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h

0.00

Revised October 2013