

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Sep-23

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.015	0.014	OFF	OFF	OFF	OFF	0.02
2	OFF	OFF	OFF	OFF	0.015	OFF	0.02
3	0.014	OFF	0.015	0.015	0.015	0.015	0.02
4	0.015	OFF	OFF	OFF	0.014	0.015	0.02
5	0.015	OFF	OFF	OFF	OFF	OFF	0.02
6	0.015	0.015	OFF	OFF	OFF	OFF	0.02
7	0.015	0.015	OFF	OFF	OFF	OFF	0.02
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	0.015	0.015	OFF	OFF	OFF	0.015	0.02
10	0.015	OFF	OFF	OFF	0.015	0.015	0.02
11	0.015	OFF	OFF	OFF	OFF	OFF	0.02
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	0.015	OFF	0.016	OFF	0.02
14	OFF	OFF	OFF	OFF	0.020	0.015	0.02
15	0.016	OFF	0.015	0.015	0.015	OFF	0.02
16	OFF	OFF	OFF	0.015	0.015	0.015	0.02
17	0.015	OFF	OFF	OFF	OFF	0.015	0.02
18	0.015	0.015	0.016	0.015	0.015	OFF	0.02
19	OFF	OFF	OFF	0.015	0.015	0.015	0.02
20	0.015	OFF	OFF	OFF	OFF	0.016	0.02
21	0.016	0.016	OFF	OFF	OFF	0.016	0.02
22	0.016	0.016	OFF	OFF	OFF	0.016	0.02
23	0.016	0.016	OFF	OFF	OFF	OFF	0.02
24	0.016	0.016	OFF	OFF	OFF	OFF	0.02
25	0.016	0.016	OFF	OFF	OFF	OFF	0.02
26	OFF	OFF	0.016	OFF	0.016	OFF	0.02
27	OFF	OFF	OFF	OFF	0.016	0.016	0.02
28	0.016	OFF	OFF	OFF	OFF	OFF	0.02
29	0.016	0.016	OFF	OFF	OFF	OFF	0.02
30	OFF	0.016	0.016	OFF	OFF	OFF	0.02

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

10/9/2023

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Sep-23

Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.780	170	132.6	18.0	7.74	14.3	YES	100
2	0.820	170	139.4	19.5	7.56	12.2	YES	100
3	0.760	170	129.2	16.9	7.80	15.7	YES	100
4	0.810	170	137.7	16.7	7.82	16.1	YES	100
5	0.690	170	117.3	17.4	7.73	14.7	YES	100
6	0.500	170	85.0	17.0	7.83	15.3	YES	100
7	0.600	170	102.0	16.1	7.89	16.8	YES	100
8	1.260	170	214.2	16.1	7.83	17.7	YES	100
9	0.620	170	105.4	16.7	7.84	15.9	YES	100
10	0.550	170	93.5	16.5	7.82	15.9	YES	100
11	0.430	170	73.1	17.2	7.69	14.2	YES	100
12	0.640	170	108.8	17.0	7.69	14.8	YES	100
13	0.610	170	103.7	17.3	7.61	14.0	YES	100
14	0.890	170	151.3	16.7	7.66	15.3	YES	100
15	0.640	170	108.8	17.0	7.60	14.3	YES	100
16	0.530	170	90.1	16.8	7.66	14.6	YES	100
17	0.760	170	129.2	15.8	7.79	16.8	YES	100
18	0.540	170	91.8	13.7	7.70	18.3	YES	100
19	0.460	170	78.2	16.3	7.77	15.6	YES	100
20	0.430	170	73.1	16.3	7.72	15.3	YES	100
21	0.470	170	79.9	16.2	7.72	15.5	YES	100
22	0.550	170	93.5	16.2	7.78	15.9	YES	100
23	0.660	170	112.2	15.4	7.75	16.8	YES	100
24	0.690	170	117.3	15.0	7.78	17.6	YES	100
25	0.610	170	103.7	14.8	7.70	17.1	YES	100
26	0.550	170	93.5	15.0	7.65	16.5	YES	100
27	0.480	170	81.6	15.6	7.66	15.8	YES	100
28	0.690	170	117.3	15.1	7.74	17.2	YES	100
29	0.540	170	91.8	14.8	7.66	16.7	YES	100
30	0.590	170	100.3	15.2	7.63	16.2	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00