

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: **TILLAMOOK**
 Month/Year: **Nov-23**

System Name: **OCEANSIDE WD - CAPE MEARES ID#: 41 00882** WTP : TP - **1.0**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	4/1/2023
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	0.021	0.021	0.022	OFF	0.02
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	0.021	0.021	0.022	0.02
6	0.022	0.024	OFF	OFF	OFF	OFF	0.02
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	0.021	0.021	0.022	0.02
9	0.022	0.024	OFF	OFF	OFF	OFF	0.02
10	OFF	OFF	0.023	OFF	OFF	0.022	0.02
11	0.022	0.022	OFF	OFF	OFF	0.022	0.02
12	0.022	0.022	OFF	OFF	OFF	OFF	0.02
13	0.022	0.022	OFF	OFF	OFF	OFF	0.02
14	OFF	OFF	OFF	0.022	0.022	0.022	0.02
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	0.022	0.022	0.022	0.02
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	0.023	0.022	0.022	OFF	OFF	0.02
19	OFF	OFF	OFF	OFF	0.022	0.022	0.02
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	0.021	OFF	0.022	0.02
22	0.022	0.022	OFF	OFF	OFF	0.022	0.02
23	0.022	0.021	OFF	OFF	OFF	0.022	0.02
24	0.022	0.021	OFF	OFF	OFF	0.022	0.02
25	0.022	OFF	OFF	OFF	0.022	0.022	0.02
26	0.022	OFF	OFF	OFF	OFF	0.022	0.02
27	0.022	OFF	OFF	OFF	OFF	OFF	0.02
28	0.022	0.022	OFF	OFF	OFF	OFF	0.02
29	0.023	0.023	0.022	OFF	OFF	OFF	0.02
30	OFF	OFF	OFF	0.022	0.022	0.022	0.02

Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point \geq 0.2 mg/l?
		<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:

PRINTED NAME: David L. Nordman	
SIGNATURE: 	12/10/2023
PHONE #: (503) 842- 6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

Disinfection *Giardia* Log

Inactiv: 0.5

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Nov-23

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.540	170	91.8	12.8	7.84	20.4	YES	100
2	0.540	170	91.8	13.1	7.73	19.2	YES	100
3	0.530	170	90.1	13.1	7.70	19.0	YES	13.2
4	0.440	170	74.8	13.2	7.73	18.9	YES	100
5	0.310	170	52.7	13.4	7.67	18.0	YES	100
6	0.420	170	71.4	13.3	7.45	16.9	YES	100
7	0.220	170	37.4	13.4	7.53	16.9	YES	100
8	0.200	170	34.0	13.1	7.61	17.7	YES	100
9	0.360	170	61.2	12.5	7.54	18.3	YES	100
10	0.590	170	100.3	12.7	7.61	19.0	YES	100
11	0.490	170	83.3	12.5	7.55	18.6	YES	100
12	0.510	170	86.7	12.2	7.70	20.2	YES	100
13	0.420	170	71.4	12.6	7.44	17.6	YES	100
14	0.410	170	69.7	12.0	7.54	19.1	YES	100
15	0.450	170	76.5	12.0	7.60	19.6	YES	100
16	0.310	170	52.7	11.4	7.66	20.5	YES	100
17	0.360	170	61.2	12.4	7.56	18.7	YES	100
18	0.410	170	69.7	11.7	7.51	19.3	YES	100
19	0.500	170	85.0	11.4	7.59	20.4	YES	100
20	0.580	170	98.6	11.6	7.46	19.5	YES	100
21	0.520	170	88.4	12.0	7.56	19.5	YES	100
22	0.520	170	88.4	11.7	7.68	20.7	YES	100
23	1.380	170	234.6	10.8	7.63	23.8	YES	100
24	1.420	170	241.4	10.6	7.60	24.0	YES	100
25	1.140	170	193.8	10.1	7.76	25.4	YES	100
26	1.040	170	176.8	10.4	7.57	23.0	YES	100
27	0.910	170	154.7	10.9	7.56	21.9	YES	100
28	0.870	170	147.9	10.7	7.69	23.1	YES	100
29	0.780	170	132.6	10.1	7.79	24.7	YES	100
30	0.770	170	130.9	9.7	7.49	22.8	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 ho 0.00

Revised October 2013