

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: TILLAMOOK
 Month/Year: Oct-23
 WTP: TP - 1.0

System Name:	OCEANSIDE WD - CAPE MEARES ID#: 41 00882						4/1/2023
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	
1	OFF	OFF	OFF	OFF	OFF	0.022	0.02
2	0.022	0.023	OFF	OFF	OFF	OFF	0.02
3	0.022	OFF	OFF	OFF	OFF	OFF	0.02
4	OFF	OFF	OFF	0.022	0.023	OFF	0.02
5	OFF	0.027	0.022	0.022	OFF	OFF	0.03
6	OFF	OFF	OFF	OFF	0.022	0.023	0.02
7	0.024	0.024	0.024	OFF	OFF	OFF	0.02
8	OFF	OFF	OFF	OFF	0.036	OFF	0.04
9	0.022	0.022	OFF	OFF	OFF	OFF	0.02
10	0.023	OFF	OFF	OFF	OFF	OFF	0.02
11	0.022	0.023	0.024	OFF	OFF	OFF	0.02
12	OFF	OFF	0.023	OFF	OFF	OFF	0.02
13	OFF	OFF	OFF	OFF	0.021	0.023	0.02
14	OFF	OFF	OFF	OFF	OFF	0.022	0.02
15	0.024	OFF	OFF	OFF	OFF	OFF	0.02
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	0.011	OFF	OFF	OFF	OFF	OFF	0.01
18	0.012	0.012	OFF	OFF	OFF	OFF	0.01
19	0.011	0.011	OFF	OFF	OFF	OFF	0.01
20	0.011	0.011	0.012	OFF	OFF	OFF	0.01
21	OFF	0.011	0.011	0.011	OFF	OFF	0.01
22	OFF	OFF	OFF	0.011	0.011	0.011	0.01
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	0.011	0.01
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	0.011	0.011	OFF	OFF	OFF	OFF	0.01
27	0.011	0.011	OFF	OFF	OFF	OFF	0.01
28	OFF	OFF	OFF	0.012	0.012	0.012	0.01
29	0.011	OFF	OFF	OFF	OFF	OFF	0.01
30	0.011	0.012	0.012	OFF	OFF	0.011	0.01
31	0.011	0.011	OFF	OFF	OFF	OFF	0.01

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes / No	Yes / No	Yes / No

Notes:

PRINTED NAME: David L. Nordman
 SIGNATURE: 
 PHONE #: (503) 842- 6462
 1/9/2024
 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

Disinfection *Giardia* Log

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Oct-23

Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.720	170	122.4	9.8	7.61	23.5	YES	100
2	0.690	170	117.3	10.0	7.61	23.1	YES	100
3	0.670	170	113.9	10.3	7.67	23.0	YES	100
4	0.480	170	81.6	10.7	7.58	21.3	YES	100
5	0.420	170	71.4	11.5	7.41	18.9	YES	100
6	0.300	170	51.0	11.3	7.61	20.3	YES	100
7	0.210	170	35.7	10.9	7.45	19.5	YES	100
8	0.580	170	98.6	10.5	7.64	22.3	YES	100
9	0.770	170	130.9	10.2	7.57	22.7	YES	100
10	0.530	170	90.1	11.0	7.63	21.4	YES	100
11	0.520	170	88.4	10.6	7.56	21.4	YES	100
12	0.620	170	105.4	10.8	7.78	23.0	YES	100
13	0.650	170	110.5	10.4	7.63	22.5	YES	100
14	0.590	170	100.3	10.8	7.78	23.0	YES	100
15	0.870	170	147.9	10.7	7.80	24.0	YES	100
16	0.950	170	161.5	10.2	7.72	24.4	YES	100
17	0.910	170	154.7	10.8	7.82	24.2	YES	100
18	0.810	170	137.7	11.2	7.69	22.2	YES	100
19	0.870	170	147.9	11.3	7.83	23.3	YES	100
20	0.860	170	146.2	11.0	7.62	22.1	YES	100
21	0.800	170	136.0	11.3	7.76	22.6	YES	100
22	0.730	170	124.1	10.5	7.69	23.1	YES	100
23	0.730	170	124.1	9.8	7.64	23.7	YES	100
24	0.730	170	124.1	10.0	7.62	23.3	YES	100
25	0.785	170	133.5	10.6	7.67	22.9	YES	100
26	0.730	170	124.1	10.1	7.73	24.0	YES	100
27	0.790	170	134.3	10.6	7.55	22.0	YES	100
28	0.710	170	120.7	10.7	7.59	21.9	YES	100
29	0.700	170	119.0	11.0	7.77	22.9	YES	100
30	0.930	170	158.1	10.8	7.65	22.8	YES	100
31	1.180	170	200.6	10.4	7.84	25.8	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h

0.00

Revised October 2013