

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: TILLAMOOK
 Month/Year: Jan-23

System Name: OCEANSIDE WD - CAPE MEARES ID#: 41 00882 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.012	0.012	0.01
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	0.011	OFF	OFF	OFF	OFF	OFF	0.01
4	0.012	0.011	OFF	OFF	OFF	OFF	0.01
5	0.011	0.011	OFF	OFF	OFF	OFF	0.01
6	0.011	0.011	OFF	OFF	OFF	OFF	0.01
7	0.011	OFF	OFF	OFF	OFF	OFF	0.01
8	OFF	0.011	0.011	OFF	OFF	OFF	0.01
9	OFF	0.013	0.012	OFF	OFF	OFF	0.01
10	OFF	OFF	0.012	0.011	0.011	0.011	0.01
11	OFF	OFF	OFF	OFF	0.011	OFF	0.01
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	0.011	OFF	OFF	OFF	OFF	OFF	0.01
14	OFF	OFF	OFF	0.012	0.012	OFF	0.01
15	0.012	0.012	0.012	0.012	OFF	OFF	0.01
16	OFF	OFF	OFF	0.012	0.011	0.012	0.01
17	OFF	OFF	OFF	OFF	OFF	0.012	0.01
18	0.012	0.012	OFF	OFF	OFF	0.012	0.01
19	0.012	0.012	OFF	OFF	OFF	0.011	0.01
20	0.011	0.011	OFF	OFF	OFF	0.012	0.01
21	0.012	0.012	OFF	OFF	OFF	0.012	0.01
22	0.012	0.011	OFF	OFF	OFF	0.011	0.01
23	0.012	0.012	OFF	OFF	OFF	OFF	0.01
24	0.012	0.012	0.012	OFF	OFF	OFF	0.01
25	0.012	0.012	OFF	OFF	OFF	OFF	0.01
26	0.011	0.011	0.012	OFF	OFF	OFF	0.01
27	0.011	OFF	0.012	OFF	OFF	OFF	0.01
28	OFF	OFF	OFF	OFF	0.011	0.011	0.01
29	OFF	0.011	0.011	OFF	OFF	OFF	0.01
30	OFF	0.011	0.011	OFF	OFF	OFF	0.01
31	OFF	OFF	OFF	0.011	0.011	OFF	0.01

Monthly Summary (Answer Yes or No)


95% of daily turbidity readings ≤ 1 NTU? ² Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: David L. Nordman

SIGNATURE: 

2/9/2024

PHONE #: (503) 842- 6462

CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Oceanside WD - Cape Meares ID#: 41 00882 Month/Year: Jan-24

Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.870	170	147.9	12.1	7.57	20.2	YES	100
2	0.880	170	149.6	12.1	7.75	21.6	YES	100
3	0.900	170	153.0	10.3	7.68	23.7	YES	100
4	0.910	170	154.7	10.2	7.73	24.4	YES	100
5	1.050	170	178.5	10.2	7.42	22.2	YES	100
6	0.980	170	166.6	9.7	7.48	23.2	YES	100
7	0.790	170	134.3	9.7	7.59	23.6	YES	100
8	0.780	170	132.6	12.3	7.57	19.8	YES	100
9	0.880	170	149.6	9.5	7.54	23.8	YES	100
10	0.860	170	146.2	9.2	7.35	22.6	YES	100
11	0.720	170	122.4	11.8	7.53	20.0	YES	100
12	0.480	170	81.6	9.2	7.39	22.0	YES	100
13	0.800	170	136.0	7.5	7.34	25.1	YES	100
14	0.800	170	136.0	7.5	7.35	25.2	YES	100
15	0.890	170	151.3	6.6	7.49	28.4	YES	100
16	0.850	170	144.5	7.2	7.48	27.0	YES	100
17	0.810	170	137.7	8.0	7.49	25.6	YES	100
18	0.760	170	129.2	8.0	7.68	27.2	YES	100
19	0.770	170	130.9	8.0	7.04	21.7	YES	100
20	0.850	170	144.5	7.8	7.63	27.4	YES	100
21	0.820	170	139.4	8.5	7.81	27.8	YES	100
22	0.790	170	134.3	8.9	7.65	25.5	YES	100
23	0.830	170	141.1	9.4	7.70	25.2	YES	100
24	0.870	170	147.9	10.1	7.82	25.2	YES	100
25	0.760	170	129.2	10.2	7.56	22.5	YES	100
26	0.780	170	132.6	9.8	7.63	23.8	YES	100
27	0.870	170	147.9	10.3	7.63	23.2	YES	100
28	0.960	170	163.2	10.9	7.66	22.8	YES	100
29	0.730	170	124.1	11.6	7.52	20.2	YES	100
30	0.680	170	115.6	11.9	7.59	20.2	YES	100
30	0.750	170	127.5	12.1	7.66	20.6	YES	100

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 h 0.00

Revised October 2013