


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	5/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.028	0.022	0.030	0.026	0.026	0.025	0.030	
2	OFF	0.030	0.021	0.040	0.026	0.026	0.040	
3	0.023	0.021	0.049	0.027	0.027	0.033	0.049	
4	0.028	OFF	0.028	0.028	0.049	0.028	0.049	
5	0.024	OFF	0.026	0.026	0.026	0.026	0.026	
6	0.032	0.023	0.042	0.029	0.029	0.026	0.042	
7	0.027	0.027	0.029	0.026	0.026	0.026	0.029	
8	0.024	0.024	0.024	0.024	0.027	0.027	0.027	
9	OFF	OFF	0.024	0.037	0.026	0.029	0.037	
10	0.030	0.026	0.031	0.033	0.028	0.028	0.033	
11	0.023	OFF	0.031	0.031	0.026	0.023	0.031	
12	0.029	0.025	0.025	0.032	0.023	0.029	0.032	
13	0.028	0.040	0.023	0.025	0.032	0.022	0.032	
14	0.023	0.023	0.024	0.023	0.024	0.023	0.024	
15	0.022	OFF	0.030	0.028	0.028	0.028	0.030	
16	0.023	OFF	OFF	0.028	0.024	0.025	0.028	
17	0.022	OFF	0.020	0.027	0.027	0.027	0.027	
18	0.026	0.026	0.030	0.030	0.032	0.028	0.032	
19	0.031	OFF	0.032	0.039	0.030	0.029	0.039	
20	0.032	0.029	0.028	0.027	0.026	0.030	0.032	
21	0.030	0.030	0.030	0.031	0.031	0.031	0.031	
22	0.029	0.029	0.027	0.023	0.040	0.029	0.040	
23	0.031	OFF	0.030	0.033	0.033	0.030	0.033	
24	0.029	0.031	0.031	0.035	0.030	0.028	0.035	
25	0.038	0.030	OFF	0.038	0.031	0.049	0.049	
26	0.028	OFF	0.038	0.038	0.033	0.033	0.038	
27	0.040	0.037	0.049	0.028	0.030	0.040	0.049	
28	0.032	0.049	0.049	0.029	0.029	0.030	0.049	
29	0.049	0.049	OFF	0.034	0.037	0.034	0.049	
30	OFF	OFF	OFF	0.032	0.035	0.035	0.035	
31	OFF	OFF	OFF	0.028	0.042	0.037	0.042	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			6/7/2021
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	May-20	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.60	115	69.0	10.7	7.97	48.3	YES	1000
2	0.59	115	67.9	10.4	8.08	26.2	YES	1000
3	0.60	115	69.0	10.5	7.91	24.6	YES	1000
4	0.60	115	69.0	10.5	7.71	22.9	YES	1000
5	0.59	115	67.9	10.4	7.77	23.5	YES	1000
6	0.59	115	67.9	10.8	7.73	22.6	YES	1000
7	0.59	115	67.9	10.4	7.80	23.8	YES	1000
8	0.58	115	66.7	10.2	7.80	24.0	YES	1000
9	0.58	115	66.7	10.2	7.78	23.9	YES	1000
10	0.56	115	64.4	10.4	7.74	23.2	YES	1000
11	0.60	115	69.0	10.4	7.77	23.5	YES	1000
12	0.60	115	69.0	10.7	7.73	22.7	YES	1000
13	0.60	115	69.0	11.0	7.74	22.4	YES	1000
14	0.60	115	69.0	11.2	7.75	22.2	YES	1000
15	0.60	115	69.0	10.9	7.79	22.9	YES	1000
16	0.60	115	69.0	11.1	7.73	22.1	YES	1000
17	0.60	115	69.0	11.1	7.72	22.1	YES	1000
18	0.60	115	69.0	10.8	7.72	22.5	YES	1000
19	0.59	115	67.9	10.4	7.71	23.0	YES	1000
20	0.58	115	66.7	10.4	7.77	23.5	YES	1000
21	0.58	115	66.7	10.4	7.71	23.0	YES	1000
22	0.59	115	67.9	10.6	7.73	49.7	YES	1000
23	0.60	115	69.0	10.8	7.70	22.4	YES	1000
24	0.60	115	69.0	10.7	7.71	22.6	YES	1000
25	0.59	115	67.9	10.8	8.38	28.4	YES	1000
26	0.59	115	67.9	10.6	7.73	22.9	YES	1000
27	0.58	115	66.7	10.9	7.71	22.2	YES	1000
28	0.56	115	64.4	10.6	8.18	26.7	YES	1000
29	0.54	115	62.1	10.5	8.21	27.2	YES	1000
30	0.51	115	58.7	11.1	7.85	22.9	YES	1000
31	0.49	115	56.4	11.4	7.82	22.2	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012