


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	8/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	0.024	0.024	OFF	0.024	
2	OFF	OFF	OFF	0.024	OFF	0.022	0.024	
3	OFF	OFF	OFF	0.025	0.025	OFF	0.025	
4	OFF	OFF	OFF	0.023	0.022	0.023	0.023	
5	OFF	OFF	OFF	0.025	0.025	0.024	0.025	
6	OFF	OFF	OFF	0.021	OFF	OFF	0.021	
7	OFF	OFF	OFF	0.025	0.025	0.025	0.025	
8	0.021	OFF	0.020	0.020	0.020	0.020	0.021	
9	0.020	0.021	0.021	0.044	0.022	0.020	0.044	
10	0.020	0.020	0.027	OFF	0.025	0.024	0.027	
11	0.022	OFF	OFF	0.021	0.020	0.026	0.026	
12	OFF	OFF	OFF	0.022	0.024	0.024	0.024	
13	OFF	OFF	OFF	0.020	OFF	0.027	0.027	
14	OFF	OFF	OFF	0.028	OFF	0.026	0.028	
15	OFF	OFF	OFF	0.021	0.021	0.021	0.021	
16	OFF	OFF	OFF	0.020	OFF	0.020	0.020	
17	OFF	OFF	OFF	0.025	OFF	0.022	0.025	
18	OFF	OFF	OFF	0.020	0.020	0.020	0.020	
19	OFF	OFF	OFF	0.020	0.022	OFF	0.022	
20	OFF	OFF	OFF	0.023	0.020	OFF	0.023	
21	OFF	OFF	OFF	0.025	OFF	OFF	0.025	
22	OFF	OFF	OFF	0.030	OFF	OFF	0.030	
23	OFF	OFF	OFF	0.024	0.032	0.032	0.032	
24	OFF	OFF	OFF	0.038	0.040	0.040	0.040	
25	OFF	OFF	OFF	0.021	0.021	0.022	0.022	
26	OFF	OFF	OFF	0.024	OFF	0.023	0.024	
27	OFF	OFF	OFF	0.024	0.022	OFF	0.024	
28	OFF	OFF	0.026	0.032	OFF	OFF	0.032	
29	OFF	OFF	OFF	0.026	0.026	0.025	0.026	
30	OFF	OFF	OFF	0.025	0.028	0.026	0.028	
31	0.021	0.021	OFF	0.031	0.028	0.028	0.028	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		9/1/2021	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Aug-21	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.92	115	105.8	13.1	8.34	49.8	YES	800
2	0.92	115	105.8	13.2	8.33	24.9	YES	800
3	0.92	115	105.8	13.2	8.33	24.9	YES	800
4	0.91	115	104.7	13.2	8.34	24.9	YES	800
5	0.91	115	104.7	13.3	8.33	24.7	YES	800
6	0.91	115	104.7	13.1	8.66	28.2	YES	800
7	0.90	115	103.5	12.9	8.28	24.8	YES	800
8	0.89	115	102.4	12.5	8.28	25.5	YES	800
9	0.87	115	100.1	12.4	8.20	24.7	YES	800
10	0.88	115	101.2	12.5	8.22	24.9	YES	800
11	0.87	115	100.1	12.9	8.23	24.3	YES	800
12	0.87	115	100.1	13.3	8.29	24.2	YES	800
13	0.87	115	100.1	13.5	8.30	24.0	YES	800
14	0.86	115	98.9	13.5	8.32	24.1	YES	800
15	0.85	115	97.8	13.5	8.32	24.1	YES	800
16	0.85	115	97.8	13.5	8.37	24.5	YES	800
17	0.85	115	97.8	13.2	8.67	27.9	YES	800
18	0.85	115	97.8	13.0	8.42	25.8	YES	800
19	0.85	115	97.8	13.1	8.39	25.4	YES	800
20	0.85	115	97.8	12.8	8.33	25.3	YES	800
21	0.85	115	97.8	12.9	8.37	25.5	YES	800
22	0.84	115	96.6	12.8	8.37	55.4	YES	800
23	0.83	115	95.5	12.7	8.72	29.3	YES	800
24	0.84	115	96.6	12.6	8.37	26.0	YES	800
25	0.85	115	97.8	12.7	8.31	25.3	YES	800
26	0.85	115	97.8	12.7	8.33	25.5	YES	800
27	0.85	115	97.8	12.7	8.30	25.2	YES	800
28	0.84	115	96.6	12.6	8.36	25.9	YES	800
29	0.83	115	95.5	12.6	8.39	26.2	YES	800
30	0.84	115	96.6	12.6	8.47	27.0	YES	800
31	0.87	115	100.1	12.3	8.65	29.2	YES	800

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012