


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	9/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.024	0.024	OFF	OFF	0.027	0.023	0.027	
2	0.022	OFF	OFF	0.022	0.025	0.026	0.026	
3	0.027	OFF	OFF	0.022	0.023	OFF	0.027	
4	OFF	OFF	OFF	0.035	0.030	OFF	0.035	
5	OFF	OFF	OFF	0.030	0.023	0.022	0.030	
6	OFF	OFF	OFF	OFF	0.028	0.032	0.032	
7	OFF	OFF	OFF	0.027	0.027	0.025	0.027	
8	0.025	OFF	OFF	0.022	0.024	OFF	0.025	
9	OFF	OFF	OFF	0.029	0.029	0.021	0.029	
10	OFF	OFF	OFF	0.021	OFF	0.021	0.021	
11	OFF	OFF	OFF	0.021	0.021	OFF	0.021	
12	OFF	OFF	OFF	0.024	0.031	OFF	0.031	
13	OFF	OFF	OFF	0.028	0.029	0.029	0.029	
14	OFF	OFF	OFF	0.023	0.022	0.030	0.030	
15	OFF	OFF	0.026	0.026	0.029	0.029	0.029	
16	OFF	OFF	OFF	0.038	0.032	0.028	0.038	
17	OFF	OFF	OFF	0.027	0.027	OFF	0.027	
18	OFF	OFF	OFF	0.030	OFF	OFF	0.030	
19	OFF	OFF	OFF	0.023	0.020	OFF	0.023	
20	OFF	OFF	OFF	0.020	OFF	0.021	0.021	
21	0.021	OFF	OFF	0.023	OFF	OFF	0.023	
22	OFF	OFF	OFF	0.023	0.028	0.023	0.028	
23	0.022	OFF	0.026	0.022	0.022	0.022	0.026	
24	0.022	0.023	0.023	0.020	0.020	0.020	0.023	
25	0.021	0.021	OFF	0.020	0.020	OFF	0.021	
26	OFF	OFF	OFF	0.022	0.022	0.021	0.022	
27	OFF	OFF	OFF	0.020	0.023	0.040	0.040	
28	0.028	OFF	OFF	0.049	0.024	OFF	0.049	
29	OFF	OFF	OFF	0.021	0.033	0.022	0.033	
30	OFF	OFF	OFF	0.022	0.022	0.028	0.028	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		10/1/2021	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Sep-21	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	115	101.2	11.8	8.74	59.9	YES	800
2	0.89	115	102.4	12.0	8.76	31.2	YES	800
3	0.89	115	102.4	12.2	8.61	29.1	YES	650
4	0.85	115	97.8	12.2	8.63	29.2	YES	650
5	0.81	115	93.2	12.4	8.62	28.6	YES	650
6	0.71	115	81.7	12.4	8.57	27.7	YES	650
7	0.64	115	73.6	12.5	8.55	27.3	YES	650
8	0.56	115	64.4	12.6	8.61	27.5	YES	650
9	0.54	115	62.1	12.7	8.68	28.0	YES	650
10	0.54	115	62.1	12.7	8.55	26.7	YES	650
11	0.56	115	64.4	12.5	8.58	27.4	YES	650
12	0.57	115	65.6	12.5	8.55	27.1	YES	650
13	0.59	115	67.9	12.5	8.55	27.2	YES	650
14	0.61	115	70.2	12.4	8.57	27.4	YES	650
15	0.65	115	74.8	12.4	8.56	27.4	YES	650
16	0.69	115	79.4	12.3	8.60	28.2	YES	600
17	0.77	115	88.6	12.2	8.57	28.3	YES	600
18	0.81	115	93.2	12.1	8.56	28.5	YES	600
19	0.80	115	92.0	12.4	10.20	50.9	YES	600
20	0.83	115	95.5	12.0	9.25	37.0	YES	600
21	0.84	115	96.6	11.9	8.65	30.0	YES	800
22	0.83	115	95.5	12.0	7.96	50.8	YES	800
23	0.80	115	92.0	11.9	7.75	21.6	YES	800
24	0.80	115	92.0	11.6	7.79	22.4	YES	800
25	0.83	115	95.5	11.9	7.97	23.5	YES	800
26	0.80	115	92.0	12.0	7.86	22.3	YES	800
27	0.80	115	92.0	12.1	7.86	22.2	YES	800
28	0.80	115	92.0	11.9	7.82	22.2	YES	800
29	0.77	115	88.6	11.7	7.80	22.2	YES	800
30	0.72	115	82.8	11.7	7.83	22.4	YES	800
31		115	0.0			4.4	YES	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012