


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	3/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	0.040	0.022	0.026	0.040	
2	0.032	OFF	0.020	0.020	0.020	0.020	0.032	
3	0.026	0.026	0.021	0.021	0.022	0.022	0.026	
4	0.028	0.021	0.023	0.020	0.032	0.025	0.032	
5	0.024	0.021	0.024	0.040	0.038	0.027	0.040	
6	0.020	0.027	0.027	0.030	0.022	0.022	0.030	
7	0.026	0.022	0.022	0.035	0.028	0.022	0.035	
8	0.022	0.038	0.032	0.049	0.021	0.021	0.049	
9	0.022	OFF	0.024	0.021	0.023	0.023	0.024	
10	0.023	0.026	0.025	0.025	0.049	0.024	0.049	
11	0.022	0.025	0.025	0.025	0.025	0.021	0.025	
12	0.022	0.025	OFF	0.024	0.024	0.022	0.025	
13	0.039	OFF	0.028	0.024	0.030	OFF	0.039	
14	0.032	OFF	0.038	0.022	0.022	OFF	0.038	
15	0.022	0.021	0.020	0.028	0.020	0.023	0.028	
16	0.024	0.022	0.022	0.029	0.029	0.031	0.031	
17	0.030	0.042	0.027	0.022	0.022	0.021	0.042	
18	0.023	0.022	0.021	0.020	0.024	0.020	0.024	
19	0.020	OFF	0.019	0.032	0.023	0.024	0.032	
20	0.026	0.026	0.024	0.023	0.021	0.022	0.026	
21	0.021	OFF	0.025	0.021	0.021	0.021	0.025	
22	0.021	0.026	0.026	0.023	0.021	0.027	0.027	
23	0.021	0.028	0.028	0.022	0.022	0.024	0.028	
24	0.022	OFF	0.021	0.026	0.022	0.023	0.026	
25	0.024	0.026	0.023	0.021	0.022	0.024	0.026	
26	0.037	0.022	0.026	0.026	0.026	0.025	0.037	
27	0.024	OFF	0.028	0.025	0.022	0.022	0.028	
28	0.025	0.025	0.025	0.024	0.023	0.023	0.025	
29	0.022	OFF	0.026	0.026	0.023	0.022	0.026	
30	0.022	0.022	0.037	0.028	0.049	0.023	0.049	
31	OFF	OFF	0.022	0.022	0.023	0.030	0.030	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		4/5/2022	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Feb-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.72	115	82.8	9.1	8.14	56.7	YES	1000
2	0.69	115	79.4	9.4	7.60	23.9	YES	1000
3	0.70	115	80.5	9.2	7.76	25.7	YES	1000
4	0.73	115	84.0	9.1	8.13	29.6	YES	1000
5	0.76	115	87.4	8.7	7.78	26.9	YES	1000
6	0.77	115	88.6	9.0	7.84	27.0	YES	1000
7	0.77	115	88.6	8.7	7.88	28.0	YES	1000
8	0.77	115	88.6	8.8	7.88	27.8	YES	1000
9	0.78	115	89.7	9.2	8.22	30.6	YES	1000
10	0.78	115	89.7	8.6	7.92	28.6	YES	1000
11	0.77	115	88.6	8.4	7.92	28.9	YES	1000
12	0.67	115	77.1	8.5	7.91	28.3	YES	1000
13	0.63	115	72.5	8.9	7.99	28.2	YES	1000
14	0.63	115	72.5	8.9	0.58	3.6	YES	1000
15	0.58	115	66.7	9.2	7.82	25.9	YES	1000
16	0.63	115	72.5	9.1	7.84	26.4	YES	1000
17	0.67	115	77.1	8.9	7.85	27.0	YES	1000
18	0.71	115	81.7	9.2	7.85	26.6	YES	1000
19	0.74	115	85.1	9.4	7.90	26.8	YES	1000
20	0.74	115	85.1	8.8	7.87	27.6	YES	1000
21	0.73	115	84.0	9.1	7.97	28.0	YES	1000
22	0.73	115	84.0	9.4	7.66	50.7	YES	1000
23	0.72	115	82.8	9.8	7.92	26.2	YES	1000
24	0.74	115	85.1	9.3	8.01	28.0	YES	1000
25	0.78	115	89.7	9.4	8.43	32.6	YES	1000
26	0.80	115	92.0	9.5	7.96	27.4	YES	1000
27	0.82	115	94.3	9.9	8.00	27.1	YES	1000
28	0.84	115	96.6	10.0	7.95	26.5	YES	1000
29	0.83	115	95.5	9.8	8.53	33.1	YES	1000
30	0.84	115	96.6	9.7	8.00	27.5	YES	1000
31	0.83	115	95.5	9.9	8.09	28.0	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012