

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook	
Conventional or Direct Filtration							Month/Year:	5/1/2022	
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.030	0.030	OFF	0.030	0.030	0.028	0.030		
2	0.028	0.030	0.030	0.028	0.028	0.025	0.030		
3	0.025	0.032	0.028	0.030	0.049	0.028	0.049		
4	0.028	0.040	0.029	0.029	0.029	0.029	0.040		
5	0.029	0.029	0.029	0.028	0.041	0.030	0.041		
6	0.029	0.029	0.029	0.036	0.028	0.028	0.036		
7	0.030	0.049	0.049	0.030	0.030	0.030	0.049		
8	0.049	0.049	0.049	0.030	0.030	0.030	0.049		
9	0.030	0.028	0.028	0.030	0.030	0.031	0.031		
10	0.031	0.029	0.031	0.032	0.032	0.028	0.032		
11	0.032	0.032	0.030	0.028	0.030	0.030	0.032		
12	0.030	0.030	0.032	0.032	0.032	0.028	0.032		
13	0.030	0.030	0.030	0.031	0.031	0.031	0.031		
14	0.030	0.030	OFF	0.036	0.029	0.029	0.036		
15	0.028	0.028	0.028	0.030	0.030	0.029	0.030		
16	0.030	0.030	0.030	0.028	0.028	0.029	0.030		
17	0.029	0.029	0.029	0.030	0.032	0.032	0.032		
18	0.032	0.028	0.038	0.029	0.029	0.029	0.038		
19	0.030	0.030	0.030	0.030	0.030	0.032	0.032		
20	0.030	0.030	0.032	0.028	0.028	0.028	0.032		
21	0.028	0.030	0.030	0.030	0.034	0.030	0.034		
22	0.030	0.030	OFF	0.030	0.030	0.030	0.030		
23	0.030	0.030	0.030	0.028	0.028	0.030	0.030		
24	0.030	0.030	0.030	0.028	0.028	0.032	0.032		
25	0.032	0.040	0.032	0.029	0.029	0.030	0.040		
26	0.030	0.030	0.030	0.030	0.036	0.030	0.030		
27	0.032	0.032	0.032	0.032	0.034	0.034	0.034		
28	0.049	0.034	0.030	0.030	0.030	0.030	0.049		
29	0.030	0.030	0.030	0.032	0.032	0.032	0.032		
30	0.030	0.030	0.028	0.032	0.032	0.034	0.034		
31	0.029	0.030	0.032	0.034	0.034	0.035	0.035		
Conventional or Direct Filtration							Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes		
All turbidity readings < IFE ² triggers				Yes					
							PRINTED NAME: Lévi Beachy		
							SIGNATURE: 	6/9/2022	
							PHONE #: (503) 812-8804		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2 OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	May-22	Disinfection Giardia Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.83	115	95.5	9.6	7.91	58.8	YES	1000
2	0.81	115	93.2	9.8	8.02	27.4	YES	1000
3	0.82	115	94.3	9.6	7.99	27.5	YES	1000
4	0.79	115	90.9	9.5	8.03	28.0	YES	1000
5	0.82	115	94.3	9.9	8.46	32.0	YES	1000
6	0.83	115	95.5	9.8	7.99	27.2	YES	1000
7	0.82	115	94.3	9.9	8.59	33.5	YES	1000
8	0.79	115	90.9	9.4	8.24	30.4	YES	1000
9	0.80	115	92.0	9.3	7.96	27.7	YES	1000
10	0.81	115	93.2	9.3	8.19	30.2	YES	1000
11	0.83	115	95.5	9.4	7.95	27.5	YES	1000
12	0.84	115	96.6	9.8	8.10	28.3	YES	1000
13	0.84	115	96.6	9.4	7.94	27.5	YES	1000
14	0.83	115	95.5	9.8	7.76	25.1	YES	1000
15	0.83	115	95.5	10.0	7.31	21.1	YES	1000
16	0.83	115	95.5	10.1	7.87	25.5	YES	1000
17	0.83	115	95.5	9.7	7.98	27.3	YES	1000
18	0.85	115	97.8	9.9	7.94	26.6	YES	1000
19	0.86	115	98.9	9.9	7.93	26.5	YES	1000
20	0.85	115	97.8	9.7	8.22	29.8	YES	1000
21	0.85	115	97.8	9.7	7.95	27.1	YES	1000
22	0.86	115	98.9	10.1	7.96	53.2	YES	1000
23	0.85	115	97.8	10.4	7.93	25.6	YES	1000
24	0.86	115	98.9	10.5	7.98	25.9	YES	1000
25	0.86	115	98.9	10.6	8.40	30.0	YES	1000
26	0.85	115	97.8	10.6	7.93	25.3	YES	1000
27	0.85	115	97.8	10.7	7.98	25.6	YES	1000
28	0.85	115	97.8	10.5	7.96	25.7	YES	1000
29	0.84	115	96.6	10.5	8.14	27.4	YES	1000
30	0.81	115	93.2	10.2	7.93	25.9	YES	1000
31	0.80	115	92.0	10.1	8.03	27.0	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012