


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	12/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	OFF	OFF	0.044	0.044	
2	OFF	OFF	OFF	0.035	0.038	OFF	0.038	
3	OFF	OFF	0.026	0.020	0.020	0.020	0.026	
4	0.020	0.040	0.022	0.028	0.028	0.027	0.040	
5	0.032	0.025	0.025	0.038	0.032	0.021	0.038	
6	0.022	0.022	0.027	0.027	0.023	0.023	0.027	
7	0.022	0.025	0.025	0.030	0.024	0.022	0.030	
8	0.021	OFF	0.023	OFF	OFF	OFF	0.023	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	0.046	0.038	0.037	0.046	
14	0.037	OFF	0.041	0.040	0.035	0.025	0.041	
15	0.026	0.049	0.032	0.024	0.024	0.024	0.049	
16	0.025	0.025	0.026	0.025	0.024	0.024	0.026	
17	0.023	OFF	0.031	0.031	0.031	0.027	0.031	
18	0.026	0.026	OFF	0.026	OFF	0.027	0.027	
19	0.032	0.040	0.035	0.028	OFF	0.029	0.040	
20	0.027	0.035	0.030	0.033	0.029	OFF	0.035	
21	OFF	OFF	OFF	0.037	0.037	0.038	0.038	
22	0.039	0.039	0.041	0.040	0.033	0.037	0.041	
23	0.038	0.038	0.039	OFF	OFF	OFF	0.039	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	0.022	OFF	0.022	
28	0.049	OFF	0.040	OFF	OFF	OFF	0.040	
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		01/03/2023	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Dec-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.80	115	92.0	8.5	8.17	62.5	YES	800
2	0.78	115	89.7	8.5	8.03	30.0	YES	800
3	0.77	115	88.6	8.7	8.39	33.6	YES	800
4	0.79	115	90.9	8.3	8.09	31.1	YES	800
5	0.82	115	94.3	8.3	8.07	30.9	YES	800
6	0.85	115	97.8	8.6	8.10	30.8	YES	800
7	0.87	115	100.1	8.6	8.04	30.2	YES	800
8	0.87	115	100.1	8.7	8.14	31.1	YES	800
9	0.85	115	97.8	8.6	9.41	49.8	YES	OFF
10	0.84	115	96.6	8.8	9.46	50.0	YES	OFF
11	0.83	115	95.5	8.8	9.41	49.0	YES	OFF
12	0.82	115	94.3	8.7	9.34	48.0	YES	OFF
13	0.81	115	93.2	8.7	9.26	46.5	YES	800
14	0.82	115	94.3	8.5	8.56	36.5	YES	800
15	0.84	115	96.6	8.1	8.30	34.2	YES	800
16	0.86	115	98.9	8.1	8.09	31.7	YES	800
17	0.87	115	100.1	7.9	8.10	32.3	YES	800
18	0.88	115	101.2	8.2	8.08	31.5	YES	800
19	0.87	115	100.1	8.2	8.14	32.1	YES	800
20	0.87	115	100.1	8.2	8.30	34.1	YES	800
21	0.86	115	98.9	8.6	10.08	64.1	YES	800
22	0.85	115	97.8	7.6	8.25	59.1	YES	800
23	0.85	115	97.8	7.7	8.38	36.2	YES	800
24	0.83	115	95.5	8.1	8.23	33.3	YES	OFF
25	0.82	115	94.3	8.3	8.24	32.9	YES	OFF
26	0.80	115	92.0	8.6	8.22	31.9	YES	800
27	0.80	115	92.0	8.9	8.20	31.1	YES	1000
28	0.78	115	89.7	9.2	7.50	23.6	YES	1000
29	0.78	115	89.7	8.8	8.30	32.4	YES	OFF
30	0.76	115	87.4	8.9	8.32	32.3	YES	OFF
31	0.76	115	87.4	8.9	8.40	33.3	YES	OFF

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012