


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	2/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.024	0.049	0.030	0.049	0.021	0.022	0.049	
2	OFF	0.023	0.023	0.023	0.022	0.028	0.028	
3	0.049	OFF	0.025	0.025	0.032	0.022	0.049	
4	0.022	0.022	0.027	0.049	0.023	0.037	0.049	
5	0.049	0.049	0.022	0.022	0.023	0.049	0.049	
6	OFF	0.032	OFF	0.022	0.022	0.023	0.032	
7	0.023	0.023	0.049	0.023	0.025	0.026	0.049	
8	0.024	OFF	0.049	0.049	0.023	0.026	0.049	
9	0.026	OFF	0.024	0.024	0.024	0.022	0.026	
10	0.025	0.025	0.029	0.024	0.022	0.023	0.029	
11	0.028	0.028	0.030	0.030	0.030	0.030	0.030	
12	OFF	0.035	0.028	0.024	0.022	0.024	0.035	
13	0.023	0.037	0.023	0.030	0.024	0.024	0.037	
14	0.028	OFF	0.027	0.027	0.027	0.025	0.028	
15	0.038	OFF	0.049	0.030	0.030	0.030	0.049	
16	0.028	OFF	0.030	0.030	0.022	0.022	0.030	
17	0.030	0.025	0.032	0.024	0.024	0.023	0.032	
18	OFF	0.022	0.030	0.030	0.027	0.027	0.030	
19	OFF	0.022	0.040	0.030	0.030	0.025	0.040	
20	OFF	0.029	0.037	0.049	0.032	0.023	0.049	
21	OFF	0.028	0.038	0.032	0.032	0.032	0.038	
22	OFF	0.032	OFF	0.036	0.033	0.027	0.036	
23	0.025	0.025	OFF	0.042	0.030	0.049	0.049	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	0.027	0.027	
26	OFF	OFF	0.026	OFF	OFF	0.049	0.049	
27	0.037	OFF	OFF	OFF	0.022	0.022	0.037	
28	0.026	0.026	0.033	0.024	0.025	0.026	0.033	
29								
30								
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		3/8/2023	
PHONE #: ( 503 ) 812-8804								

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Feb-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.76	115	87.4	7.8	8.15	64.1	YES	1000
2	0.77	115	88.6	7.5	8.11	33.0	YES	1000
3	0.74	115	85.1	8.1	8.08	31.2	YES	1000
4	0.76	115	87.4	8.6	8.27	32.4	YES	1000
5	0.75	115	86.3	8.6	8.19	31.4	YES	1000
6	0.74	115	85.1	8.5	8.57	36.3	YES	1000
7	0.73	115	84.0	8.7	8.43	34.0	YES	1000
8	0.74	115	85.1	8.6	8.03	29.6	YES	1000
9	0.73	115	84.0	8.5	8.22	31.9	YES	1000
10	0.76	115	87.4	8.9	8.51	34.6	YES	1000
11	0.76	115	87.4	8.5	8.16	31.3	YES	1000
12	0.76	115	87.4	8.3	8.14	31.5	YES	1000
13	0.78	115	89.7	8.7	8.32	32.8	YES	1000
14	0.77	115	88.6	8.1	8.07	31.2	YES	1000
15	0.77	115	88.6	7.9	8.15	32.6	YES	1000
16	0.76	115	87.4	7.8	8.11	32.3	YES	1000
17	0.76	115	87.4	8.2	8.03	30.5	YES	1000
18	0.76	115	87.4	8.4	8.31	33.3	YES	1000
19	0.76	115	87.4	8.5	8.00	29.6	YES	1000
20	0.75	115	86.3	8.7	8.40	33.7	YES	1000
21	0.74	115	85.1	8.7	8.01	29.2	YES	1000
22	0.74	115	85.1	8.0	8.06	55.5	YES	1000
23	0.73	115	84.0	7.7	8.47	36.9	YES	1000
24	0.69	115	79.4	7.7	8.10	32.1	YES	OFF
25	0.69	115	79.4	7.7	8.10	32.1	YES	1000
26	0.69	115	79.4	7.5	8.06	32.1	YES	1000
27	0.69	115	79.4	7.6	7.96	30.7	YES	1000
28	0.70	115	80.5	7.7	8.07	31.8	YES	1000
29		115	0.0			4.2		
30		115	0.0			4.2		
31		115	0.0			4.2		

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012