


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	7/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.032	OFF	0.032	0.032	0.032	OFF	0.032	
2	0.038	OFF	0.035	OFF	0.036	0.037	0.038	
3	OFF	OFF	OFF	OFF	0.036	0.036	0.036	
4	OFF	OFF	OFF	0.038	OFF	OFF	0.038	
5	OFF	OFF	OFF	0.038	0.036	OFF	0.038	
6	OFF	OFF	OFF	OFF	0.030	OFF	0.030	
7	OFF	OFF	OFF	OFF	0.037	OFF	0.037	
8	OFF	OFF	OFF	OFF	0.036	OFF	0.036	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	0.031	0.031	
11	OFF	OFF	OFF	0.038	0.038	0.038	0.038	
12	OFF	0.033	0.038	0.037	0.037	0.037	0.038	
13	0.039	OFF	0.038	0.038	OFF	0.036	0.038	
14	0.036	OFF	0.036	0.036	0.036	0.039	0.039	
15	OFF	OFF	0.037	0.040	OFF	0.037	0.040	
16	OFF	OFF	0.039	OFF	0.035	OFF	0.039	
17	OFF	OFF	OFF	0.035	0.040	0.039	0.040	
18	OFF	OFF	0.038	0.038	0.038	0.038	0.038	
19	0.040	0.044	0.039	0.039	0.040	OFF	0.044	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	0.038	0.038	0.037	0.038	
30	0.035	0.038	0.037	OFF	0.035	0.036	0.038	
31	0.038	0.037	OFF	0.036	0.031	OFF	0.038	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		8/1/2023	
PHONE #: (503) 812-8804								
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jul-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.60	115	69.0	12.6	8.23	47.3	YES	1000
2	0.58	115	66.7	12.6	8.25	24.2	YES	1000
3	0.58	115	66.7	12.5	8.16	23.5	YES	1000
4	0.56	115	64.4	12.6	8.17	23.4	YES	1000
5	0.56	115	64.4	12.8	8.19	23.3	YES	1000
6	0.55	115	63.3	13.0	8.21	23.1	YES	1000
7	0.53	115	61.0	12.8	8.25	23.7	YES	1000
8	0.51	115	58.7	12.7	8.24	23.7	YES	1000
9	0.50	115	57.5	12.8	8.73	28.2	YES	1000
10	0.50	115	57.5	12.9	8.24	23.4	YES	1000
11	0.50	115	57.5	12.8	8.24	23.5	YES	1000
12	0.51	115	58.7	13.1	8.32	23.8	YES	1000
13	0.51	115	58.7	12.9	8.13	22.5	YES	1000
14	0.51	115	58.7	13.0	7.99	21.2	YES	1000
15	0.50	115	57.5	13.2	8.11	21.9	YES	1000
16	0.49	115	56.4	13.4	8.14	21.8	YES	1000
17	0.49	115	56.4	13.5	8.15	21.7	YES	1000
18	0.49	115	56.4	13.1	8.18	22.6	YES	1000
19	0.50	115	57.5	12.9	7.98	21.3	YES	1000
20	0.49	115	56.4	13.2	8.06	21.4	YES	OFF
21	0.45	115	51.8	13.2	8.06	21.3	YES	OFF
22	0.44	115	50.6	13.2	8.07	50.9	YES	OFF
23	0.42	115	48.3	13.3	8.08	21.3	YES	OFF
24	0.42	115	48.3	13.3	8.08	21.3	YES	OFF
25	0.41	115	47.2	13.2	8.08	21.4	YES	OFF
26	0.40	115	46.0	13.2	8.07	21.3	YES	OFF
27	0.38	115	43.7	13.2	8.06	21.2	YES	OFF
28	0.37	115	42.6	13.4	8.06	20.9	YES	OFF
29	0.36	115	41.4	13.4	8.05	20.8	YES	1000
30	0.38	115	43.7	12.8	7.94	20.8	YES	1000
31	0.40	115	46.0	13.0	8.05	21.4	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012