


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	10/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	0.037	0.038	OFF	0.038	
24	OFF	OFF	OFF	OFF	0.038	OFF	0.038	
25	OFF	OFF	OFF	0.046	OFF	OFF	0.046	
26	OFF	OFF	OFF	0.059	OFF	OFF	0.059	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31	OFF	OFF	OFF	OFF	0.051	OFF	0.051	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
				5	PRINTED NAME: Levi Beachy			
					SIGNATURE: 			
					PHONE #: (503) 812-8804			
					11/2/2023			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Oct-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.41	115	47.2	11.7	8.02	44.3	YES	OFF
2	0.41	115	47.2	11.9	8.02	22.8	YES	OFF
3	0.43	115	49.5	11.9	7.86	21.6	YES	OFF
4	0.66	115	75.9	11.6	8.11	24.7	YES	OFF
5	0.37	115	42.6	11.9	7.83	21.2	YES	OFF
6	0.35	115	40.3	12.1	7.86	21.1	YES	OFF
7	0.37	115	42.6	12.2	7.89	21.2	YES	OFF
8	0.34	115	39.1	12.2	7.91	21.3	YES	OFF
9	0.34	115	39.1	12.3	7.92	21.2	YES	OFF
10	0.33	115	38.0	12.1	7.93	21.6	YES	OFF
11	0.31	115	35.7	12.1	7.93	21.5	YES	OFF
12	0.32	115	36.8	11.8	7.92	21.9	YES	OFF
13	0.30	115	34.5	11.9	7.90	21.6	YES	OFF
14	0.29	115	33.4	11.9	7.91	21.6	YES	OFF
15	0.28	115	32.2	11.9	7.91	21.6	YES	OFF
16	0.26	115	29.9	12.0	7.91	21.4	YES	OFF
17	0.25	115	28.8	11.9	7.91	21.5	YES	OFF
18	0.23	115	26.5	11.8	7.90	21.5	YES	OFF
19	0.23	115	26.5	11.7	7.89	21.6	YES	OFF
20	0.21	115	24.2	12.0	7.89	21.1	YES	OFF
21	0.21	115	24.2	12.0	7.89	21.1	YES	OFF
22	0.20	115	23.0	12.0	7.89	21.1	YES	OFF
23	0.25	115	28.8	11.9	7.88	21.3	YES	1000
24	0.23	115	26.5	11.6	7.83	21.3	YES	1000
25	0.23	115	26.5	11.2	7.80	21.6	YES	1000
26	0.35	115	40.3	10.6	7.22	18.6	YES	1000
27	0.53	115	61.0	10.4	7.33	20.0	YES	OFF
28	0.48	115	55.2	10.4	7.52	21.3	YES	OFF
29	0.65	115	74.8	10.2	7.52	22.0	YES	OFF
30	0.65	115	74.8	10.2	7.51	21.9	YES	OFF
31	0.64	115	73.6	10.3	7.50	21.7	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012