

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	3/1/2024
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.039	OFF	0.038	0.045	0.039	0.040	0.045	
2	0.040	0.042	0.044	0.040	0.040	0.043	0.044	
3	0.037	0.038	0.037	0.041	0.040	0.038	0.041	
4	0.037	0.039	0.042	0.040	0.040	0.040	0.042	
5	0.040	0.038	0.036	0.042	0.038	0.038	0.042	
6	0.039	OFF	0.040	0.038	0.042	0.038	0.042	
7	0.039	OFF	0.040	0.038	0.038	0.040	0.040	
8	0.040	0.040	0.039	0.040	0.040	0.020	0.040	
9	0.040	0.040	0.039	0.040	0.040	0.040	0.040	
10	0.040	0.041	OFF	OFF	OFF	OFF	0.041	
11	OFF	OFF	OFF	OFF	0.038	0.040	0.040	
12	OFF	OFF	OFF	0.042	0.039	0.039	0.042	
13	0.038	0.038	0.040	0.039	0.041	0.040	0.041	
14	0.039	0.058	0.038	0.039	0.018	0.040	0.058	
15	0.040	0.040	0.040	0.040	0.041	0.041	0.041	
16	0.038	OFF	0.040	0.020	0.040	0.041	0.041	
17	0.039	0.040	0.040	0.040	0.037	0.037	0.040	
18	0.040	0.040	OFF	0.042	0.039	0.038	0.042	
19	0.020	OFF	0.038	0.040	0.038	0.042	0.042	
20	0.041	0.038	0.040	0.036	0.039	0.038	0.041	
21	0.038	OFF	0.040	0.040	0.044	0.040	0.044	
22	0.040	0.040	0.020	0.040	0.040	0.040	0.040	
23	0.040	0.038	0.040	0.040	0.050	0.040	0.050	
24	OFF	0.040	0.038	0.040	0.040	0.040	0.040	
25	0.040	0.039	0.040	0.040	0.040	0.041	0.041	
26	0.040	0.040	0.020	0.038	0.036	0.037	0.040	
27	0.036	0.037	OFF	0.038	0.038	0.040	0.040	
28	0.035	0.035	0.039	0.038	0.038	0.022	0.038	
29	0.039	OFF	0.058	0.038	0.038	0.036	0.058	
30	0.039	OFF	0.036	0.038	0.037	0.038	0.039	
31	0.036	0.033	0.038	0.038	0.034	0.037	0.038	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Lpvi Beachy					SIGNATURE: 		4/4/2024	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Mar-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.71	115	81.7	8.6	7.72	26.4	YES	1000
2	0.71	115	81.7	8.6	8.00	29.2	YES	1000
3	0.71	115	81.7	8.4	7.87	28.2	YES	1000
4	0.73	115	84.0	8.1	8.04	30.7	YES	1000
5	0.73	115	84.0	8.1	7.97	29.9	YES	1000
6	0.74	115	85.1	8.2	8.05	30.6	YES	1000
7	0.75	115	86.3	8.1	8.04	30.8	YES	1000
8	0.75	115	86.3	8.3	8.39	34.5	YES	1000
9	0.75	115	86.3	8.9	8.13	30.1	YES	1000
10	0.74	115	85.1	8.8	8.24	31.5	YES	1000
11	0.73	115	84.0	8.8	7.84	27.3	YES	1000
12	0.72	115	82.8	9.0	8.12	29.7	YES	1000
13	0.72	115	82.8	8.8	8.43	33.7	YES	1000
14	0.72	115	82.8	8.7	8.17	30.9	YES	1000
15	0.73	115	84.0	9.0	8.18	30.4	YES	1000
16	0.74	115	85.1	9.8	8.25	29.6	YES	1000
17	0.73	115	84.0	9.5	8.16	29.2	YES	1000
18	0.74	115	85.1	9.4	8.18	29.6	YES	1000
19	0.74	115	85.1	9.9	8.21	28.9	YES	1000
20	0.74	115	85.1	9.6	8.23	29.7	YES	1000
21	0.75	115	86.3	9.7	8.15	28.7	YES	1000
22	0.76	115	87.4	9.7	8.12	28.5	YES	1000
23	0.73	115	84.0	9.5	8.16	29.2	YES	1000
24	0.72	115	82.8	9.7	8.30	30.2	YES	1000
25	0.72	115	82.8	9.6	8.61	34.1	YES	1000
26	0.72	115	82.8	9.6	8.39	31.4	YES	1000
27	0.72	115	82.8	9.7	8.19	29.1	YES	1000
28	0.71	115	81.7	9.5	8.35	31.2	YES	1000
29	0.72	115	82.8	9.2	8.11	29.2	YES	1000
30	0.70	115	80.5	9.4	8.14	29.1	YES	1000
31	0.71	115	81.7	9.5	8.15	29.0	YES	1000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012