


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	4/1/2024
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.037	0.036	0.036	0.033	0.037	0.037	0.037	
2	0.038	OFF	0.045	0.040	0.036	0.035	0.045	
3	0.037	0.037	OFF	0.039	0.038	0.040	0.040	
4	0.034	0.036	0.039	0.040	0.040	0.040	0.040	
5	0.035	0.035	0.035	0.040	0.036	0.036	0.040	
6	0.036	0.037	0.040	0.040	0.036	0.036	0.040	
7	0.037	0.035	OFF	0.039	0.038	0.038	0.039	
8	0.037	0.037	0.038	0.037	0.040	0.036	0.040	
9	0.040	OFF	0.037	0.036	0.035	0.048	0.048	
10	0.035	0.035	0.036	0.040	0.037	0.037	0.040	
11	0.019	0.036	0.025	0.038	0.038	0.039	0.039	
12	0.039	0.053	0.040	0.038	0.039	0.037	0.053	
13	0.041	0.037	0.038	0.038	0.040	0.039	0.041	
14	0.039	0.038	0.038	0.040	0.040	0.038	0.040	
15	0.038	0.038	0.040	0.039	0.040	0.038	0.040	
16	0.038	0.037	0.040	0.039	0.037	0.040	0.040	
17	0.038	0.040	OFF	0.040	0.040	0.038	0.040	
18	0.040	0.038	0.038	0.038	0.038	0.040	0.040	
19	0.040	0.040	0.038	0.040	0.038	0.020	0.040	
20	0.039	0.039	0.040	0.040	0.038	0.039	0.040	
21	0.038	0.040	0.040	0.022	0.037	0.040	0.040	
22	0.038	0.038	OFF	OFF	OFF	0.040	0.040	
23	0.040	OFF	0.038	0.036	0.040	0.040	0.040	
24	0.054	0.040	0.040	0.039	0.039	0.039	0.054	
25	0.039	0.040	0.040	0.040	0.036	0.041	0.041	
26	0.040	0.040	0.040	0.040	0.038	0.040	0.040	
27	OFF	OFF	0.040	0.042	0.045	0.038	0.045	
28	0.040	0.044	0.052	0.040	0.042	0.042	0.052	
29	0.040	OFF	0.042	0.038	0.040	0.054	0.054	
30	0.039	0.040	0.039	0.045	OFF	0.038	0.045	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			5/1/2024
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Apr-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.72	115	82.8	9.6	8.48	32.5	YES	1000
2	0.73	115	84.0	9.9	8.16	28.4	YES	1000
3	0.73	115	84.0	10.0	8.13	27.9	YES	1000
4	0.72	115	82.8	9.5	8.16	29.1	YES	1000
5	0.70	115	80.5	9.2	8.45	32.9	YES	1000
6	0.70	115	80.5	9.4	8.10	28.6	YES	1000
7	0.70	115	80.5	9.4	8.16	29.3	YES	1000
8	0.70	115	80.5	9.5	8.14	28.9	YES	1000
9	0.70	115	80.5	9.7	8.16	28.7	YES	1000
10	0.69	115	79.4	9.2	8.12	29.2	YES	1000
11	0.70	115	80.5	9.5	8.13	28.8	YES	1000
12	0.72	115	82.8	9.6	8.12	28.5	YES	1000
13	0.72	115	82.8	9.9	8.14	28.2	YES	1000
14	0.72	115	82.8	10.2	8.15	27.7	YES	1000
15	0.72	115	82.8	10.0	8.13	27.9	YES	1000
16	0.71	115	81.7	9.7	8.25	29.7	YES	1000
17	0.72	115	82.8	9.4	8.13	29.0	YES	1000
18	0.72	115	82.8	9.6	8.20	29.4	YES	1000
19	0.72	115	82.8	10.1	8.10	27.4	YES	1000
20	0.72	115	82.8	10.3	8.14	27.4	YES	1000
21	0.71	115	81.7	9.9	8.19	28.6	YES	1000
22	0.73	115	84.0	9.7	8.14	28.6	YES	1000
23	0.70	115	80.5	10.0	8.07	27.2	YES	1000
24	0.70	115	80.5	10.4	8.09	26.7	YES	1000
25	0.70	115	80.5	10.3	8.09	26.9	YES	1000
26	0.69	115	79.4	10.2	8.03	26.4	YES	1000
27	0.66	115	75.9	10.1	7.93	25.6	YES	1000
28	0.63	115	72.5	10.0	8.05	26.8	YES	1000
29	0.63	115	72.5	9.8	8.07	27.4	YES	1000
30	0.64	115	73.6	9.7	8.37	30.7	YES	1000
31		115	0.0			4.4	YES	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012