


| OHA - Drinking Water Program -Turbidity Monitoring Report Form | | | | | | | County: | Tillamook |
|--|-------------------|------------|------------|------------------------------------|--|------------|--|-----------|
| Conventional or Direct Filtration | | | | | | | Month/Year: | 6/1/2024 |
| System Name: | City of Tillamook | | | ID#: 41 | 00893 | | WTP : TP - | Combined |
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] | |
| 1 | 0.042 | 0.045 | 0.048 | 0.046 | 0.045 | 0.042 | 0.048 | |
| 2 | 0.048 | 0.052 | 0.044 | 0.046 | 0.044 | 0.051 | 0.052 | |
| 3 | 0.053 | 0.042 | 0.052 | 0.042 | 0.044 | 0.058 | 0.058 | |
| 4 | OFF | OFF | OFF | 0.040 | 0.036 | 0.036 | 0.040 | |
| 5 | 0.037 | 0.038 | 0.037 | 0.036 | 0.036 | 0.038 | 0.038 | |
| 6 | 0.069 | 0.069 | 0.038 | 0.038 | 0.036 | 0.037 | 0.069 | |
| 7 | 0.037 | 0.037 | 0.036 | 0.069 | 0.069 | 0.036 | 0.069 | |
| 8 | 0.037 | 0.036 | 0.040 | 0.038 | 0.036 | 0.041 | 0.041 | |
| 9 | 0.040 | 0.037 | 0.038 | 0.036 | 0.038 | 0.038 | 0.040 | |
| 10 | 0.038 | 0.044 | 0.037 | 0.039 | 0.040 | 0.037 | 0.044 | |
| 11 | 0.039 | 0.039 | 0.037 | 0.038 | 0.038 | 0.037 | 0.039 | |
| 12 | 0.039 | 0.037 | 0.037 | 0.036 | 0.037 | 0.037 | 0.039 | |
| 13 | 0.037 | 0.037 | 0.039 | 0.039 | 0.036 | 0.037 | 0.039 | |
| 14 | 0.037 | OFF | 0.041 | 0.038 | 0.038 | 0.038 | 0.041 | |
| 15 | 0.039 | 0.037 | 0.040 | 0.039 | 0.036 | 0.045 | 0.045 | |
| 16 | 0.038 | 0.036 | 0.036 | 0.037 | 0.038 | OFF | 0.038 | |
| 17 | OFF | OFF | 0.038 | 0.037 | 0.040 | 0.040 | 0.040 | |
| 18 | 0.037 | 0.040 | 0.037 | 0.037 | 0.040 | 0.040 | 0.040 | |
| 19 | 0.037 | 0.037 | 0.038 | 0.038 | 0.037 | 0.040 | 0.040 | |
| 20 | 0.037 | 0.037 | 0.038 | 0.038 | 0.038 | 0.040 | 0.040 | |
| 21 | 0.040 | 0.040 | 0.038 | 0.039 | 0.039 | 0.038 | 0.040 | |
| 22 | 0.038 | 0.038 | 0.038 | 0.038 | 0.038 | 0.040 | 0.040 | |
| 23 | 0.040 | 0.040 | 0.040 | 0.040 | 0.038 | 0.040 | 0.040 | |
| 24 | 0.040 | 0.040 | 0.038 | 0.037 | 0.037 | 0.039 | 0.040 | |
| 25 | 0.039 | 0.039 | 0.043 | 0.039 | 0.039 | 0.039 | 0.043 | |
| 26 | 0.037 | 0.042 | 0.036 | 0.037 | 0.046 | 0.036 | 0.046 | |
| 27 | 0.037 | 0.036 | 0.040 | 0.037 | 0.037 | 0.038 | 0.040 | |
| 28 | 0.039 | 0.041 | 0.038 | 0.037 | 0.036 | 0.037 | 0.041 | |
| 29 | 0.038 | 0.038 | 0.038 | 0.021 | 0.037 | 0.040 | 0.040 | |
| 30 | 0.038 | 0.038 | 0.038 | 0.038 | 0.037 | 0.038 | 0.038 | |
| 31 | | | | | | | | |
| Conventional or Direct Filtration | | | | Monthly Summary (Answer Yes or No) | | | | |
| 95% of daily turbidity readings \leq 0.3 NTU? | | | | Yes | CT's met everyday? (see back) | | All Cl2 residual at entry point \geq 0.2 mg/l? | |
| All daily turbidity readings \leq 1 NTU? | | | | Yes | Yes | | Yes | |
| All turbidity readings < IFE ² triggers | | | | Yes | | | | |
| PRINTED NAME: Levi Beachy | | | | | SIGNATURE:  | | 7/1/2024 | |
| PHONE #: (503) 812-8804 | | | | | | | | |
| ¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C)) | | | | | | | | |

| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | | | WTP - : | A |
|--|---|---------------------|--------------|-------|-------------|-------------|---|----------------------------|
| System Name: | City of Tillamook | | ID#: 41 | 00893 | Month/Year: | Jun-24 | Disinfection <i>Giardia</i> Log Inactiv: | 0.5 |
| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 0.69 | 115 | 79.4 | 11.1 | 8.20 | 26.4 | YES | 1000 |
| 2 | 0.68 | 115 | 78.2 | 11.2 | 8.17 | 26.0 | YES | 1000 |
| 3 | 0.69 | 115 | 79.4 | 11.1 | 8.09 | 25.4 | YES | 1000 |
| 4 | 0.65 | 115 | 74.8 | 11.0 | 8.55 | 30.1 | YES | 1000 |
| 5 | 0.63 | 115 | 72.5 | 10.6 | 8.56 | 30.9 | YES | 1000 |
| 6 | 0.63 | 115 | 72.5 | 10.9 | 8.57 | 30.4 | YES | 1000 |
| 7 | 0.65 | 115 | 74.8 | 10.9 | 8.15 | 26.2 | YES | 1000 |
| 8 | 0.68 | 115 | 78.2 | 11.4 | 8.36 | 27.4 | YES | 1000 |
| 9 | 0.68 | 115 | 78.2 | 11.3 | 8.17 | 25.8 | YES | 1000 |
| 10 | 0.70 | 115 | 80.5 | 11.1 | 8.16 | 26.1 | YES | 1000 |
| 11 | 0.72 | 115 | 82.8 | 11.4 | 8.13 | 25.4 | YES | 1000 |
| 12 | 0.72 | 115 | 82.8 | 10.9 | 8.18 | 26.7 | YES | 1000 |
| 13 | 0.74 | 115 | 85.1 | 11.0 | 8.49 | 29.7 | YES | 1000 |
| 14 | 0.73 | 115 | 84.0 | 11.0 | 8.48 | 29.6 | YES | 1000 |
| 15 | 0.73 | 115 | 84.0 | 11.0 | 8.15 | 26.3 | YES | 1000 |
| 16 | 0.70 | 115 | 80.5 | 10.9 | 8.43 | 29.1 | YES | 1000 |
| 17 | 0.67 | 115 | 77.1 | 11.0 | 8.44 | 28.9 | YES | 1000 |
| 18 | 0.63 | 115 | 72.5 | 10.5 | 8.34 | 28.8 | YES | 1000 |
| 19 | 0.60 | 115 | 69.0 | 10.9 | 8.12 | 25.8 | YES | 1000 |
| 20 | 0.57 | 115 | 65.6 | 11.5 | 8.13 | 24.8 | YES | 1000 |
| 21 | 0.59 | 115 | 67.9 | 11.7 | 8.20 | 25.1 | YES | 1000 |
| 22 | 0.67 | 115 | 77.1 | 11.7 | 8.16 | 25.0 | YES | 1000 |
| 23 | 0.63 | 115 | 72.5 | 11.9 | 8.21 | 25.0 | YES | 1000 |
| 24 | 0.68 | 115 | 78.2 | 11.2 | 8.13 | 25.6 | YES | 1000 |
| 25 | 0.69 | 115 | 79.4 | 11.6 | 8.21 | 25.7 | YES | 1000 |
| 26 | 0.70 | 115 | 80.5 | 11.9 | 8.14 | 24.6 | YES | 1000 |
| 27 | 0.69 | 115 | 79.4 | 11.6 | 8.15 | 25.1 | YES | 1000 |
| 28 | 0.70 | 115 | 80.5 | 11.4 | 8.16 | 25.6 | YES | 1000 |
| 29 | 0.69 | 115 | 79.4 | 11.8 | 8.16 | 24.9 | YES | 1000 |
| 30 | 0.70 | 115 | 80.5 | 11.9 | 8.16 | 24.7 | YES | 1000 |
| 31 | | 115 | 0.0 | | | 4.4 | YES | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012