

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook	
Conventional or Direct Filtration							Month/Year:	8/1/2024	
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.042	0.042	0.042	0.042	0.042	0.044	0.044		
2	0.046	0.044	0.044	0.046	0.050	0.043	0.050		
3	0.043	0.043	0.052	0.052	0.052	0.052	0.052		
4	0.021	0.046	0.053	0.056	0.056	0.050	0.056		
5	0.051	0.051	0.035	0.030	0.030	0.030	0.051		
6	0.028	0.029	0.033	0.033	0.028	0.028	0.033		
7	0.032	0.028	0.034	0.030	0.032	0.030	0.034		
8	0.028	0.033	0.042	0.036	0.030	0.030	0.042		
9	0.029	0.022	0.028	0.029	0.029	0.029	0.029		
10	0.028	0.027	0.028	0.036	0.028	0.028	0.036		
11	0.029	0.028	0.030	0.035	0.035	0.029	0.035		
12	0.027	0.028	0.027	0.043	0.031	0.034	0.043		
13	0.033	0.030	0.037	0.035	0.031	0.031	0.037		
14	0.031	0.030	0.049	0.030	0.030	0.030	0.049		
15	0.030	0.032	0.042	0.036	0.027	0.027	0.042		
16	0.029	0.029	0.029	0.030	0.030	0.032	0.032		
17	0.032	0.031	0.033	0.033	0.037	0.034	0.037		
18	0.021	0.031	0.030	0.039	0.035	0.029	0.039		
19	0.029	0.028	0.030	0.030	0.026	0.032	0.032		
20	0.032	0.028	0.029	0.026	0.026	0.026	0.032		
21	0.024	0.026	0.024	0.027	0.028	0.026	0.028		
22	0.028	0.029	0.027	0.022	0.040	0.028	0.040		
23	0.025	0.024	0.028	0.030	0.029	0.026	0.030		
24	0.029	0.029	0.030	0.020	0.028	0.024	0.030		
25	0.028	0.027	0.026	0.026	0.024	0.027	0.028		
26	0.027	0.028	0.028	0.028	0.022	0.024	0.028		
27	0.029	0.026	0.030	0.030	0.030	0.029	0.030		
28	0.029	0.029	0.031	0.069	0.069	0.028	0.069		
29	0.028	0.028	0.028	0.027	0.029	0.069	0.069		
30	0.029	0.029	0.027	0.026	0.027	0.028	0.029		
31	OFF	OFF	OFF	0.027	0.025	0.025	0.027		
Conventional or Direct Filtration							Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes		
All turbidity readings < IFE ² triggers				Yes					
							PRINTED NAME: Levi Beachy		
							SIGNATURE: 	9/9/2024	
							PHONE #: (503) 812-8804		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2 OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Aug-24	Disinfection Giardia Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.64	115	73.6	12.7	8.07	22.6	YES	1000
2	0.63	115	72.5	13.3	8.11	22.0	YES	1000
3	0.64	115	73.6	13.0	8.14	22.8	YES	1000
4	0.64	115	73.6	13.0	8.16	22.9	YES	1000
5	0.64	115	73.6	13.0	8.14	22.8	YES	1000
6	0.65	115	74.8	12.8	8.19	23.5	YES	1000
7	0.67	115	77.1	12.7	8.31	24.8	YES	1000
8	0.68	115	78.2	12.9	8.13	22.9	YES	1000
9	0.69	115	79.4	12.9	8.16	23.2	YES	1000
10	0.68	115	78.2	12.8	8.13	23.1	YES	1000
11	0.69	115	79.4	13.1	8.23	23.5	YES	1000
12	0.70	115	80.5	12.7	8.20	23.9	YES	1000
13	0.68	115	78.2	12.5	8.30	25.1	YES	1000
14	0.69	115	79.4	12.2	8.17	24.3	YES	1000
15	0.70	115	80.5	12.8	8.17	23.5	YES	1000
16	0.73	115	84.0	12.7	8.14	23.4	YES	1000
17	0.71	115	81.7	12.7	8.18	23.7	YES	1000
18	0.70	115	80.5	12.6	8.05	22.8	YES	1000
19	0.66	115	75.9	12.3	8.19	24.2	YES	1000
20	0.64	115	73.6	12.7	8.29	24.5	YES	1000
21	0.65	115	74.8	12.9	8.12	22.8	YES	1000
22	0.64	115	73.6	12.6	8.09	22.9	YES	1000
23	0.63	115	72.5	12.3	8.10	23.4	YES	1000
24	0.64	115	73.6	12.0	8.11	24.0	YES	1000
25	0.64	115	73.6	12.0	8.17	24.5	YES	1000
26	0.64	115	73.6	12.2	8.19	24.3	YES	1000
27	0.62	115	71.3	12.6	8.40	25.6	YES	1000
28	0.67	115	77.1	12.0	8.13	24.2	YES	1000
29	0.67	115	77.1	12.3	8.12	23.7	YES	1000
30	0.67	115	77.1	12.7	8.16	23.5	YES	1000
31	0.65	115	74.8	12.9	8.53	26.5	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2