


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	9/1/2024
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	0.069	0.069	0.069	0.069	
2	OFF	OFF	OFF	0.069	0.069	0.069	0.069	
3	OFF	OFF	OFF	0.069	0.069	0.069	0.069	
4	OFF	OFF	0.069	0.069	0.069	0.069	0.069	
5	OFF	OFF	0.069	0.069	0.069	0.069	0.069	
6	OFF	OFF	OFF	0.069	0.069	0.069	0.069	
7	OFF	OFF	OFF	0.069	0.069	0.069	0.069	
8	OFF	OFF	OFF	0.069	0.069	0.069	0.069	
9	OFF	OFF	OFF	0.069	0.069	OFF	0.069	
10	OFF	OFF	OFF	0.069	0.069	OFF	0.069	
11	OFF	OFF	OFF	0.069	0.069	OFF	0.069	
12	OFF	OFF	OFF	0.069	0.069	OFF	0.069	
13	OFF	OFF	OFF	0.069	OFF	OFF	0.069	
14	OFF	OFF	OFF	0.069	OFF	OFF	0.069	
15	OFF	OFF	OFF	OFF	0.069	OFF	0.069	
16	OFF	OFF	OFF	0.069	0.069	OFF	0.069	
17	OFF	OFF	0.069	0.069	OFF	OFF	0.069	
18	0.069	0.069	0.069	0.069	OFF	OFF	0.069	
19	OFF	OFF	OFF	OFF	OFF	0.030	0.030	
20	OFF	OFF	OFF	0.040	0.030	0.060	0.060	
21	0.040	0.030	0.030	0.060	OFF	OFF	0.060	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	OFF	0.030	OFF	0.030	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	0.030	OFF	0.030	
26	OFF	OFF	OFF	OFF	0.030	OFF	0.030	
27	OFF	OFF	OFF	0.030	0.060	OFF	0.060	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		10/2/2024	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Sep-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.63	115	72.5	13.0	8.25	23.7	YES	1000
2	0.62	115	71.3	12.9	8.22	23.5	YES	1000
3	0.61	115	70.2	12.8	8.24	23.8	YES	1000
4	0.61	115	70.2	12.8	8.23	23.8	YES	1000
5	0.61	115	70.2	13.0	8.44	25.3	YES	1000
6	0.60	115	69.0	13.2	8.22	23.0	YES	1000
7	0.59	115	67.9	13.3	8.22	22.8	YES	1000
8	0.59	115	67.9	13.2	8.26	23.3	YES	1000
9	0.58	115	66.7	13.2	8.29	23.6	YES	1000
10	0.56	115	64.4	13.1	8.19	22.8	YES	1000
11	0.56	115	64.4	13.1	8.20	22.9	YES	1000
12	0.56	115	64.4	13.1	8.15	22.5	YES	1000
13	0.50	115	57.5	12.7	8.22	23.5	YES	1000
14	0.55	115	63.3	12.7	8.15	23.1	YES	1000
15	0.44	115	50.6	12.6	8.30	24.2	YES	1000
16	0.52	115	59.8	12.4	8.32	24.8	YES	1000
17	0.47	115	54.1	12.5	8.17	23.3	YES	1000
18	0.56	115	64.4	12.3	8.00	22.4	YES	1000
19	0.60	115	69.0	13.0	8.12	22.5	YES	1000
20	0.54	115	62.1	12.3	7.74	20.4	YES	1000
21	0.56	115	64.4	11.7	7.90	22.5	YES	1000
22	0.53	115	61.0	11.9	7.64	20.2	YES	OFF
23	0.45	115	51.8	12.2	7.96	22.0	YES	1000
24	0.51	115	58.7	12.3	7.96	22.0	YES	OFF
25	0.49	115	56.4	12.5	7.94	21.5	YES	1000
26	0.49	115	56.4	12.2	7.94	21.9	YES	1000
27	0.48	115	55.2	12.3	8.05	22.6	YES	1000
28	0.47	115	54.1	12.0	8.69	28.9	YES	OFF
29	0.47	115	54.1	11.9	7.97	22.5	YES	OFF
30	0.45	115	51.8	11.7	7.90	22.2	YES	OFF
31		115	0.0			4.3	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012