


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	10/1/2024
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.030	0.030	0.030	0.030	0.030	
2	0.030	0.030	0.030	0.030	0.030	OFF	0.030	
3	OFF	OFF	0.030	0.030	0.030	OFF	0.030	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	0.030	0.030	0.030	OFF	0.030	
7	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
8	0.040	0.060	0.030	0.030	0.030	OFF	0.060	
9	OFF	OFF	OFF	OFF	0.020	OFF	0.020	
10	OFF	OFF	OFF	0.030	0.050	OFF	0.050	
11	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
12	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
13	OFF	OFF	OFF	0.060	0.030	0.030	0.060	
14	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
15	OFF	OFF	OFF	0.060	0.030	0.030	0.060	
16	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
17	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
18	OFF	OFF	OFF	0.030	OFF	OFF	0.030	
19	OFF	OFF	OFF	0.030	0.030	0.020	0.030	
20	OFF	OFF	OFF	0.040	0.030	0.030	0.040	
21	OFF	0.030	OFF	OFF	OFF	OFF	0.030	
22	OFF	OFF	OFF	0.020	0.020	OFF	0.020	
23	OFF	OFF	OFF	0.040	0.020	OFF	0.040	
24	OFF	OFF	OFF	0.020	0.020	0.020	0.020	
25	OFF	OFF	OFF	0.030	0.020	0.040	0.040	
26	OFF	OFF	OFF	0.020	0.030	OFF	0.030	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	0.030	0.030	0.030	
29	OFF	OFF	OFF	0.030	0.020	OFF	0.030	
30	OFF	OFF	0.030	0.050	0.020	0.030	0.050	
31	OFF	0.030	0.040	0.020	0.030	0.030	0.040	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		10/4/2024	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Oct-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.44	115	50.6	11.9	7.70	20.4	YES	1000
2	0.47	115	54.1	11.5	7.59	20.2	YES	1000
3	0.52	115	59.8	11.6	7.68	20.9	YES	1000
4	0.49	115	56.4	11.6	8.03	23.5	YES	OFF
5	0.51	115	58.7	11.5	8.31	26.2	YES	OFF
6	0.52	115	59.8	11.6	8.22	25.3	YES	1000
7	0.55	115	63.3	11.7	8.24	25.4	YES	1000
8	0.55	115	63.3	11.7	8.49	27.7	YES	1000
9	0.55	115	63.3	11.5	8.53	28.5	YES	1000
10	0.55	115	63.3	11.3	8.66	30.3	YES	1000
11	0.57	115	65.6	11.4	8.42	27.7	YES	1000
12	0.60	115	69.0	11.5	8.48	28.2	YES	1000
13	0.60	115	69.0	11.5	8.34	26.8	YES	1000
14	0.60	115	69.0	11.6	8.36	26.8	YES	1000
15	0.60	115	69.0	11.6	8.72	30.5	YES	1000
16	0.58	115	66.7	11.4	8.71	30.7	YES	1000
17	0.56	115	64.4	10.9	8.57	30.2	YES	1000
18	0.54	115	62.1	11.5	8.69	30.2	YES	1000
19	0.53	115	61.0	11.6	8.48	27.7	YES	1000
20	0.54	115	62.1	11.4	8.52	28.6	YES	1000
21	0.51	115	58.7	11.1	8.72	31.2	YES	1000
22	0.49	115	56.4	10.6	8.73	32.4	YES	1000
23	0.50	115	57.5	10.3	8.69	32.6	YES	1000
24	0.61	115	70.2	10.3	8.52	31.0	YES	1000
25	0.64	115	73.6	11.0	9.05	36.0	YES	1000
26	0.60	115	69.0	10.9	9.13	37.2	YES	1000
27	0.50	115	57.5	11.1	9.58	42.7	YES	OFF
28	0.49	115	56.4	10.5	8.33	28.2	YES	1000
29	0.47	115	54.1	10.3	8.25	27.7	YES	1000
30	0.50	115	57.5	10.3	9.39	42.1	YES	1000
31	0.50	115	57.5	10.6	9.46	42.3	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012