


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	1/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	0.070	0.070	OFF	0.070	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31	OFF	OFF	OFF	0.030	0.030	0.090	0.090	
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			02/03/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Jan-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

115

0.0

4.2

YES

OFF

2

115

0.0

4.2

YES

OFF

3

115

0.0

4.2

YES

OFF

4

115

0.0

4.2

YES

OFF

5

115

0.0

4.2

YES

OFF

6

115

0.0

4.2

YES

OFF

7

115

0.0

4.2

YES

OFF

8

115

0.0

4.2

YES

OFF

9

115

0.0

4.2

YES

OFF

10

115

0.0

4.2

YES

OFF

11

115

0.0

4.2

YES

OFF

12

115

0.0

4.2

YES

OFF

13

115

0.0

4.2

YES

OFF

14

115

0.0

4.2

YES

OFF

15

115

0.0

4.2

YES

OFF

16

115

0.0

4.2

YES

OFF

17

115

0.0

4.2

YES

OFF

18

115

0.0

4.2

YES

OFF

19

115

0.0

4.2

YES

OFF

20

115

0.0

4.2

YES

OFF

21

115

0.0

4.2

YES

OFF

22

115

0.0

4.2

YES

OFF

23

115

0.0

4.2

YES

OFF

24

115

0.0

4.2

YES

OFF

25

115

0.0

4.2

YES

OFF

26

115

0.0

4.2

YES

OFF

27

115

0.0

4.2

YES

OFF

28

115

0.0

4.2

YES

OFF

29

0.35

115

40.3

5.8

7.28

26.1

YES

1000

30

115

0.0

4.2

YES

OFF

31

0.35

115

40.3

7.8

8.62

35.5

YES

1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2