

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	2/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	OFF	OFF	0.050	0.080	0.070	0.080	0.080	
4	OFF	OFF	OFF	OFF	0.070	0.090	0.090	
5	0.040	0.080	OFF	OFF	0.030	OFF	0.030	
6	0.020	OFF	0.020	0.030	0.030	0.030	0.030	
7	0.030	0.060	0.030	0.030	0.030	0.030	0.030	
8	0.030	OFF	0.030	0.030	0.030	0.030	0.030	
9	0.030	0.030	0.030	0.020	0.030	0.030	0.030	
10	0.030	0.030	0.030	0.030	0.030	0.030	0.030	
11	0.030	0.030	0.030	0.040	0.030	0.030	0.040	
12	0.030	0.030	0.030	0.030	0.030	0.030	0.030	
13	OFF	OFF	0.030	0.040	0.080	0.030	0.080	
14	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
15	0.030	0.030	OFF	0.030	0.030	0.030	0.030	
16	0.030	0.030	0.030	0.030	0.040	OFF	0.040	
17	OFF	OFF	OFF	0.040	0.050	OFF	0.050	
18	OFF	OFF	OFF	0.050	0.050	0.050	0.050	
19	OFF	OFF	0.050	OFF	0.050	OFF	0.050	
20	OFF	OFF	OFF	OFF	0.050	0.050	0.050	
21	OFF	OFF	OFF	0.060	OFF	0.060	0.060	
22	OFF	OFF	OFF	0.060	OFF	0.060	0.060	
23	OFF	OFF	0.080	OFF	OFF	OFF	0.080	
24	OFF	OFF	OFF	0.020	0.020	OFF	0.020	
25	0.050	OFF	0.020	0.020	OFF	0.030	0.050	
26	0.090	0.090	0.090	0.040	0.030	0.030	0.090	
27	0.090	0.090	OFF	0.090	0.090	0.090	0.090	
28	OFF	OFF	OFF	0.020	0.090	OFF	0.090	
29								
30								
31								
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: AJ Harmon			
					SIGNATURE: 			3/3/2025
					PHONE #: (503) 812-3791			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Feb-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.36	115	41.4	7.5	8.45	35.6	YES	OFF
2	0.35	115	40.3	7.8	8.28	32.7	YES	OFF
3	0.34	115	39.1	6.7	8.27	35.1	YES	1000
4	0.43	115	49.5	6.6	7.47	26.7	YES	1000
5	0.41	115	47.2	5.7	8.86	47.1	YES	1000
6	0.46	115	52.9	4.9	8.32	41.1	YES	1000
7	0.57	115	65.6	4.8	8.28	41.3	YES	1000
8	0.57	115	65.6	5.6	8.25	38.6	YES	1000
9	0.60	115	69.0	5.9	8.24	37.8	YES	1000
10	0.66	115	75.9	5.6	8.30	39.8	YES	1000
11	0.69	115	79.4	4.7	8.27	42.0	YES	1000
12	0.72	115	82.8	3.8	8.84	55.5	YES	1000
13	0.73	115	84.0	4.5	8.40	44.9	YES	1000
14	0.74	115	85.1	5.2	8.35	42.0	YES	1000
15	0.74	115	85.1	5.9	8.26	38.7	YES	1000
16	0.75	115	86.3	7.4	8.27	35.1	YES	1000
17	0.75	115	86.3	8.0	7.83	28.7	YES	1000
18	0.73	115	84.0	8.1	7.43	24.7	YES	1000
19	0.69	115	79.4	8.3	7.93	29.0	YES	1000
20	0.62	115	71.3	8.5	8.25	31.8	YES	1000
21	0.76	115	87.4	8.4	8.15	31.4	YES	1000
22	0.85	115	97.8	9.5	8.29	31.0	YES	1000
23	0.77	115	88.6	10.1	8.12	27.7	YES	1000
24	0.76	115	87.4	12.0	7.76	21.5	YES	1000
25	0.83	115	95.5	12.2	8.33	26.1	YES	1000
26	0.72	115	82.8	9.0	8.00	28.4	YES	1000
27	0.71	115	81.7	9.6	8.01	27.4	YES	1000
28	0.64	115	73.6	9.6	8.05	27.6	YES	1000
29		115	0.0			4.2		
30		115	0.0			4.2		
31		115	0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2